

### SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

Owner:                      Applicant:  
 Address:                      Date Evaluated: **3-12-19**  
 Proposed Facility: **3 bedrooms**      Design Flow (.1949): **360 gal/day**      Property Size:  
 Location of Site:                      Property Recorded:  
 Water Supply:                       Public  Individual  Well  Spring  Other  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:                       Sewage  Industrial Process  Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR	
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz		
										1
		8-37"	SBKCL	Fr s/p	10YR 7/1 @ 31"					PS .35
2		0-19"	Gr SL	VFr Ns/Np						
		19-44"	SBKCL	Fr s/p						PS .35

Description	Initial System	Repair System	Other Factors (.1946):
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Site Classification (.1948): <b>PS</b>
System Type(s)	<b>25% bed</b>	<b>25% bed</b>	Evaluated By: <b>GT</b>
Site LTAR	<b>.35</b>	<b>.35</b>	Others Present: <b>BD</b>