

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address:
 Proposed Facility: 3000m Date Evaluated:
 Location of Site: Design Flow (.1949): 360 gpd Property Size:
 Water Supply: Property Recorded:
 Evaluation Method: Auger Boring Public Individual Well Spring Other
 Type of Wastewater: Sewage Pit Cut Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941		.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
			.1941 Structure/ Texture	.1941 Consistence Mineralogy					
1	05 2-5	0-21	G LS	VFA NS/MP					
		21-36	SBK C	F2 S/SP					P5 .4
2		0-42	G LS	VFA NS/MP					
		42-28	SBK SCL	F2 SS/SP					P5 .5
3		0-12	G LS	VFA NS/MP					
		12-48	SBK C	F2 S/SP					P5 .4

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): P5 Evaluated By: [Signature] Others Present: -
Available Space (.1945)	✓	✓	
System Type(s)	.4	.4	
Site LTAR	.25 3/4 (25)		

