

DAVID MILLER, PE

6300 Creedmoor Rd, STE 170#363

Raleigh, NC 27612

(919) 422-8932 (Office); DAVE@DMA-PA.COM

April 16,2019

Micheal Ford Building %
On Top Building Company, LLC
101 Ferndale Court
Clayton, NC 27520
Email to: ontopbuildingcompany@gmail.com
Brandie 919-201-1133

RE: Engineering - Field Observation
Lot 18 Wynnridge Subdivision, Angier, NC
Project No.:19DDM-0416E


To Whom It May Concern/Inspections Dept.:


The undersigned arrived on-site 4-16-19 to observe to the foundation excavations for the planned residential structure. Based on the observations the exposed foundation bearing soils at the planned footing bearing level were gray to tan silty sands and are adequate support of the planned loading conditions per the 2018 North Carolina State Building Code (NCSBC) per R404.1.2 (2000 PSF bearing capacity).

Sincerely,

David Miller, PE

DEM/19DDM-0416E

DocuSigned by:

AED026D4715F4DC...



4/16/2019