

Harnett County Government Complex
307 W. Cornelius Harnett Boulevard
Lillington, NC 27546

ph: 910-893-7547
fax: 910-893-9371

April 2nd, 2019

Ryan Thomas
28 True Blue Dr
Broadway, NC 27505

Re: Status of Permit Application– SFD1903-0029


Mr. Thomas,

An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible. (\$25.00 Fee incurred)
- 2. Use orange flags to mark house box.
- 3. Directions not clear to property (\$25.00 fee incurred)
- 4. Property needs all underbrush cleared prior to permitting
- 5. Driveway not shown on site plan
- 6. Backhoe pits required
- 7. Other-

Your application will be put on hold until the selected items above have been addressed. When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Oliver Tolksdorf, R.E.H.S
Environmental Health Supervisor
Soil Scientist
Harnett County Department of Public Health

OT/kh
Copy: Central Permitting