

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:                      Applicant:  
 Address:                      Date Evaluated:  
 Proposed Facility: 3 BORDEN                      Design Flow (.1949): 360 gpd                      Property Size:  
 Location of Site:                      Property Recorded:  
 Water Supply:                       Public  Individual                       Well                       Spring                       Other  
 Evaluation Method:  Auger Boring                       Pit                       Cut  
 Type of Wastewater:                       Sewage                       Industrial Process                       Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L9 2.5	0-42	G S	VF2 NS/VP					
		42-48	G S2	VF1 NS/VP					S.6
2		0-48	G S	VF2 NS/VP					S.8
3		0-24	G S	VF1 NS/VP					S.2
4		0-24	G S	VF2 NS/VP					S.8
5		0-24	G S	VF2 NS/VP					S.8
SOILS NEAR HOUSE STATE US. PITS DUG TO CONFIRM AND FIND USEABLE									
AREA, USEABLE AREA INVESTIGATED IN DETAIL BY PITS.									

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): S Evaluated By: OT Others Present: —
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
System Type(s)	CON	CON	
Site LTAR	.6	.6	