

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated:
 Proposed Facility: WSP Design Flow (.1949): 400 gpd Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 2-5	0-34	G LS	VFI NS/VP					
		34-42	SBX SCL	FI SS/SP					PS .5
2		0-48	G S	VFI NS/VP					S .8
		0-26	G LS	VFI NS/VP					
		26-34	SBX SCL	FI SS/SP					PS .5
		34	NSO/gpm						
4		0-28	G LS	VFI NS/VP					
		28-36	SBX SCL	FI SS/SP					PS .45
		36	NSO/gpm						
5		0-35	G LS	VFI NS/VP					
		35	SBX SCL	FI SS/SP					PS, LS
6		0-27	G LS	VFI NS/VP					
		27-34	SBX SCL	FI SS/SP					PS, LS
		34							

Description	Initial System <input checked="" type="checkbox"/>	Repair System <input checked="" type="checkbox"/>	Other Factors (.1946):
Available Space (.1945)			Site Classification (.1948): PS
System Type(s)	25% (WSP)	PV (D)	Evaluated By: CT
Site LTAR	.45	.8	Others Present: _____