

# CERTIFICATE OF COMPLETION / OPERATIONAL PERMIT


Name: (owner) Calvin Johnson  New Installation  Septic Tank  
Property Location: SR# 1100  Repairs  Nitrification Line  
Subdivision \_\_\_\_\_ Lot # \_\_\_\_\_  
TAX ID# \_\_\_\_\_ Quadrant # \_\_\_\_\_  
Contractor: LARRY STAPE Registration # 29  
Basement with Plumbing:  Garage:   
Water Supply:  Well  Public  Community  
Distance From Well: 50+ ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system:  Conventional  Other \_\_\_\_\_  
Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons  
Subsurface Drainage Field No. of ditches 2 exact length of each ditch 70 ft. width of ditches 3 ft. depth of ditches 36 in.  
French Drain: - Linear feet \*well

PERMIT NO. 08834

Date: 5-9-94  
Inspected by: James C. Montague  
Environmental Health Specialist




# CERTIFICATE OF COMPLETION / OPERATIONAL PERMIT

Name: (owner) Calvin Sabnson / Gary Smith  New Installation  Septic Tank  
Property Location: SR# 1100  Repairs  Nitrification Line  
Subdivision \_\_\_\_\_ Lot # \_\_\_\_\_  
TAX ID# \_\_\_\_\_ Quadrant # \_\_\_\_\_  
Contractor: Larry Sharpe Registration # \_\_\_\_\_  
Basement with Plumbing:  Garage:   
Water Supply:  Well  Public  Community  
Distance From Well: 100' ft.

Following are the specifications for the sewage disposal system on above captioned property.

Type of system:  Conventional  Other \_\_\_\_\_  
Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons  
Subsurface No. of 3 exact length 70 width of 3 depth of 24  
Drainage Field ditches of each ditch ft. ditches ft. ditches in.  
French Drain: \_\_\_\_\_ Linear feet

PERMIT NO. 10776 Date: 9-5-95  
Inspected by: Thomas J. Boyce R.S.  
Environmental Health Specialist



# IMPROVEMENT PERMIT

Be it ordained by the Harnett County Board of Health as follows: Section III, Item B. "No person shall begin construction of any building at which a septic tank system is to be used for disposal of sewage without first obtaining a written permit from the Harnett County Health Department".

Name: (owner) Calvin Salmon  New Installation  Septic Tank  
Property Location: SR# SR1100  Repairs  Nitrification Line

Subdivision \_\_\_\_\_ Lot # 5  
Tax ID# \_\_\_\_\_ Quadrant # \_\_\_\_\_  
Number of Bedrooms Proposed: 3 Lot Size: 1 acre  
Basement with Plumbing:  Garage:   
Water Supply:  Well  Public  Community  
Distance From Well: 100' ft.

Following is the minimum specifications for sewage disposal system on above captioned property. Subject to final approval.

Type of system:  Conventional  Other \_\_\_\_\_  
Size of tank: Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons  
Subsurface No. of 3 exact length 70 width of \_\_\_\_\_ depth of \_\_\_\_\_  
Drainage Field ditches \_\_\_\_\_ of each ditch \_\_\_\_\_ ft. ditches 3 ft. ditches 18 in. in.  
French Drain required: \_\_\_\_\_ Linear feet

This permit is subject to revocation if site plans or intended use change. Date: 6-13-95  
Signed: Joe W. R.

Environmental Health Specialist

VOID AFTER 5 YEARS

