

HTE# SD 1905-0019

# Harnett County Department of Public Health

25491

PERMIT # NA

## Operation Permit

521412

New Installation  Septic Tank  Nitrification Line  Repair  Expansion

PROPERTY LOCATION: 60 Rolling Field Dr. (Christie Ct. Rd)

Name: (owner) KB Homes Carolina SUBDIVISION Mason Pointe LOT # 21

System Installer: Thorburns Plumbing Registration # \_\_\_\_\_


Basement with plumbing:  Garage  Number of Bedrooms 3

Type of Water Supply:  Community  Public  Well Distance from well NA feet

System Type: 25% Reduction SPTG Types V and VI Systems expire in 5 years.

(In accordance with Table V a) Owner must contact Health Department 6 months prior to expiration for permit renewal.

This system has been installed in compliance with applicable North Carolina General Statutes, Rules for Sewage Treatment and Disposal, and all conditions of the Improvement Permit and Construction Authorization.



\* SOIL & PROPOSAL BY CENTRAL CAROLINA SOIL CONSULTING  
 \* PER REGIONAL SOIL SCIENTIST AND HARNETT COUNTY ENVIRO. HEALTH SUPERVISION TREAT DRY RETENTION POND AS A DRAINAGE ESMT [DOES NOT RETAIN WATER AS TYPICAL RETENTION POND]  
 \* STEPDOWN PRESENT AT LAST TURN BY SFD CORNER  
 \* 50% REDUCTION PPBRS REPAIR AREA

### PERMIT CONDITIONS:

- I. Performance: System shall perform in accordance with Rule .1961.
- II. Monitoring: As required by Rule .1961.
- III. Maintenance: As required by Rule .1961. Other: \_\_\_\_\_  
 Subsurface system operator required? Yes  No   
 If yes, see attached sheet for additional operation conditions, maintenance and reporting.
- IV. Operation: \_\_\_\_\_
- V. Other: \_\_\_\_\_

D-Box  Pump  Alarm  H20Line  PWR Line

Following are the specifications for the sewage disposal system on the above captioned property.

Type of system:  Conventional  Other EZ FLOW SPTG Septic Tank: 1000 gallons Pump Tank: \_\_\_\_\_ gallons  
 Subsurface No. of exact length width of depth of  
 Drainage Field ditches 1 of each ditch 225 feet ditches 3 feet ditches 24 inches  
 French Drain Required: \_\_\_\_\_ Linear feet

Authorized State Agent [Signature] Date 10/03/2019