

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: Applicant:
 Address: Date Evaluated:
 Proposed Facility: 3 BDRN Design Flow (.1949): 360 gpd Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	LS 0-2	0-15	G LS	VF2 NS/MP					
		15-30	SBK C	F2 3/SP	10YR2/2 @ 27"				PS .3
2		0-18	G LS	VF2 NS/MP					
		18-36	SBK SCL	F1 3/SP	10YR7/2 @ 35"				PS .2
3		0-15	G LS	VF1 NS/MP					
		15-30	SBK C	F1 3/SP	CR2C 28"				PS .3
4		0-18	G LS	VF1 NS/MP					
		18-28	SBK C	F2 3/SP	CR2C 27"				PS .3
5		0-17	G LS	VF2 NS/MP					
		17-29	SBK C	F2 3/SP	CR2C 27"				PS .3

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <u>PS</u> Evaluated By: <u>OT</u> Others Present: <u>—</u>
Available Space (.1945)	<u>✓</u>	<u>✓</u>	
System Type(s)	<u>25% A</u>	<u>REF. SYS</u>	
Site LTAR	<u>.3</u>	<u>.3</u>	

