

**SOIL/SITE EVALUATION  
 for ON-SITE WASTEWATER SYSTEM**

Owner:                      Applicant:  
 Address:                      Date Evaluated:  
 Proposed Facility: *14 850255*                      Design Flow (.1949): *150 gpd*                      Property Size:  
 Location of Site:                      Property Recorded:  
 Water Supply:                       Public  Individual  Well  Spring  Other  
 Evaluation Method:  Auger Boring  Pit  Cut  
 Type of Wastewater:  Sewage  Industrial Process  Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	<i>F3 2-5</i>	<i>0-12</i>	<i>G SL</i>	<i>VF2 NS/HP</i>					
		<i>12-24</i>	<i>SBK CL</i>	<i>F1 SS/NP</i>					<i>P5 .5</i>
		<i>24-48</i>	<i>G S</i>	<i>VF2 NS/HP</i>					
2		<i>0-10</i>	<i>G SL</i>	<i>VF1 NS/HP</i>					
		<i>10-28</i>	<i>SBK CL</i>	<i>F1 SS/NP</i>					<i>P5 .5</i>
		<i>28-48</i>	<i>G S</i>	<i>VF1 NS/HP</i>					

Description	Initial System	Repair System	Other Factors (.1946): Site Classification (.1948): <i>P5</i> Evaluated By: <i>CT</i> Others Present: <i>—</i>
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	
System Type(s)	<i>250/100</i>	<i>500/100</i>	
Site LTAR	<i>.5</i>	<i>.5</i>	