

July 1st, 2019

True Homes LLC/ Ashley Jones
2649 Brekonridge Centre Dr
Monroe, NC 28110

Re: Status of Permit Applications– SFD1906-0022

To whom it may concern,

An attempt was made to evaluate your property for the purpose of issuing an Improvement Permit. The evaluation could not be completed for one or more of the following reasons.

- 1. Use pink flags to mark property lines and irons that are set by surveyor need to be visible. (\$25.00 Fee incurred)
- 2. Use orange flags to mark house box.
- 3. Directions not clear to property (\$25.00 fee incurred)
- 4. Property needs cleared prior to permitting
- 5. Driveway not shown on site plan (Revision Required)
- 6. Backhoe pits maybe required
- 7. Other- Temporary retention pond shall be removed prior to environmental approval. 50ft setback requirement of any retention pond.**

Your application will be put on hold until the selected items above have been addressed.

When completed **please call 910-893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



Andrew Currin, R.E.H.S
Environmental Health Specialist
Harnett County Department of Public Health

AC/kh
Copy: Central Permitting