

**Howerton Services, PLLC**  
**License # P-1716**  
3513 Cathedral Bell Road  
Raleigh, NC 27614  
(919) 270-3460

September 8, 2019

Subject: Aviles Residence  
5675 Christian Light Road  
Fuquay Varina, NC 27526  
Harnett County Permit #: SFD1906-0026  
Foundation/Footing Inspection

Based on the request of the inspector, I inspected the location of the foundation piers on the footings. The piers of off center of the footings in a few of the piers. Some of the piers are properly centered. The piers located off center of the footings are acceptable. The footing projections (2"-3") on the off center piers are acceptable. No repairs or additional footings are needed.

The piers and footings are acceptable and meet the requirements of the 2018 North Carolina Building Code for Residences.



*Joel S. Howerton*

09 08 2019