

Mark E. Jones, PE
Structural Engineering and Design

August 29, 2019

Gregory, Inc.
62 E. McIver St.
Angier, NC 27501

Ref: Site Observations and Analysis
3584 NC 27 E
Coats, NC
Project No. 19-186

To Whom it may concern;

The above referenced site was observed on August 29, 2019 for the following items:

1. Engineer to evaluate soils in the footing excavation.

Based on analysis, the conclusions regarding the condition(s) are:

1. The referenced project is for new construction of a single family dwelling with a crawl space foundation. At the time of the inspection all footings for walls and interior piers had been excavated. Firm soils were encountered in all locations. The footings were ready for concrete placement.

Thank you for this opportunity to assist you. If you have any questions or need any further assistance, please do not hesitate to call.

Respectfully,



Mark E. Jones, PE

