

## Harnett County Department of Public Health Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Triangle Home Pros. PROPERTY LOCATION: 765 Rollins Mill Road (S21401)  
 SUBDIVISION: Eral Varina LOT # 2B

NEW  REPAIR  EXPANSION  Site Improvements required prior to Construction Authorization Issuance: \_\_\_\_\_

Type of Structure: 4-Bedroom 60'x60' SFD

Proposed Wastewater System Type: 25% Reduction Sys.

Projected Daily Flow: 4800 GPD

Number of bedrooms: 4 Number of Occupants: 8 max

Basement  Yes  No

Pump Required:  Yes  No  May be required based on final location and elevations of facilities

Type of Water Supply:  Community  Public  Well Distance from well NA feet

Permit conditions: \_\_\_\_\_ Permit valid for:  Five years  No expiration

Authorized State Agent: [Signature] Date: 09/11/2019 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

## Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Triangle Home Pros. PROPERTY LOCATION: 765 Rollins Mill Rd. (S21401)  
 SUBDIVISION: Eral Varina LOT # 2B

Facility Type: 482 60'x60' SFD  New  Expansion  Repair

Basement?  Yes  No Basement Fixtures?  Yes  No

Type of Wastewater System\*\* 25% Reduction System (Initial) Wastewater Flow: 4800 GPD  
 (See note below, if applicable ) Pump to At-Grade 25% Reduction Sys (Repair)

**Installation Requirements/Conditions**

Septic Tank Size <u>1250</u> gallons	Number of trenches <u>5</u>	Trench Spacing: <u>9</u> Feet on Center
Pump Tank Size _____ gallons	Exact length of each trench <u>80</u> feet	Soil Cover: <u>6</u> inches
	Trenches shall be installed on contour at a Maximum Trench Depth of: <u>18</u> inches (Trench bottoms shall be level to +/-1/4" in all directions)	(Maximum soil cover shall not exceed 36" above the trench bottom)

Pump Requirements: \_\_\_\_\_ ft. TDH vs. \_\_\_\_\_ GPM

Aggregate Depth: NA inches below pipe NA inches above pipe NA inches total

Conditions: Gravity to D-Box Distribution Required

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.  
 NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

**\*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.**

Owner/Legal Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] Date: 09/11/2019  
ANDREW CURRIN Construction Authorization Expiration Date: 09/11/2024


HTE# SFD1908-0021

Permit # NA

# Harnett County Department of Public Health Site Sketch

ISSUED TO: Triangle Home Pros. PROPERTY LOCATOR: 765 Rollins Mill Rd. (SL1401)  
SUBDIVISION Ecol Varinca LOT # 2B

Authorized State Agent: Andrew Morris Date: 09/11/2019  
ANDREW MORRIS



- \* SEPTIC PROPOSAL BY ADAMS SOIL CONSULTING
- \* GRAVITY TO D-BOX DISTRIBUTION REQUIRED
- \* ~~18\"/>~~
- \* 25% REDUCTION SIS.

\* THIS DRAWING IS FOR ILLUSTRATIVE PURPOSE ONLY. SYSTEM INSTALL MUST MEET ALL PERTINENT LAWS, RULES, AND REGULATIONS