

Joe E Godwin Sr. , P.E., P.L.S.

Fleet Temple , P.E.

Jason E Godwin , P.L.S.



1403 NC Highway 50 South  
Benson, North Carolina 27504  
919.894.7765

Email: [general@enochengineers.com](mailto:general@enochengineers.com)

[www.enochengineers.com](http://www.enochengineers.com)

## MATERIALS & TEST DIVISION

### FIELD REPORT

#### PROJECT

CLIENT:

DATE:

PROJECT:

CONTRACTOR:

ADDRESS:

TECHNICIAN:

LOT #:

#### TEST SUMMARY

#### TESTING RESULTS

SERVICE PERFORMED	TEST NO.	COMP %	WD PCF	DD PCF	MOISTURE %

#### RETURN VISIT REQUIRED?

YES

NO

TECHNICIAN:

Disclaimer:

Soils & Material inspections, testing results and on-site determinations contained in this report become void after 60 days of non-use of this report and/or following any inclement weather which causes structural soil or material deterioration. Additional testing will be required following a voided report determined by a North Carolina Building Code enforcement official or Enoch Engineers P.A. The client/contractor is responsible for notifying Enoch Engineers P.A. of any soil & material condition changes which could void this report.