

Harnett County Department of Public Health Improvement Permit

A building permit cannot be issued with only an Improvement Permit

SL 1440

ISSUED TO: True Homes LLC PROPERTY LOCATION: 26 Norris Farm Dr. (James Norris Rd.)
 SUBDIVISION: Norris Farm LOT # 23

NEW REPAIR EXPANSION Site Improvements required prior to Construction Authorization Issuance: _____

Type of Structure: 3-Bedroom 49'x40' SFD

Proposed Wastewater System Type: 25% Reduction Sys.

Projected Daily Flow: 360 GPD

Number of bedrooms: 3 Number of Occupants: 6 max

Basement Yes No

Pump Required: Yes No May be required based on final location and elevations of facilities

Type of Water Supply: Community Public Well Distance from well NA feet

Permit valid for: Five years
 No expiration

Permit conditions: _____

Authorized State Agent: [Signature] Date: 10/01/2019 SEE ATTACHED SITE SKETCH

The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

Construction Authorization

(Required for Building Permit)

The construction and installation requirements of Rules 1950, 1952, 1954, 1955, 1956, 1957, 1958, and 1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: True Homes LLC PROPERTY LOCATION: 26 Norris Farm Dr. (James Norris Rd.)
 SUBDIVISION: Norris Farm LOT # 23

Facility Type: 3BR 49'x40' SFD New Expansion Repair

Basement? Yes No Basement Fixtures? Yes No

Type of Wastewater System** 25% Reduction Sys. (Initial) Wastewater Flow: 360 GPD

(See note below, if applicable) Pump to 25% red. Sys. (Repair)

Installation Requirements/Conditions

Septic Tank Size <u>1000</u> gallons	Number of trenches <u>3</u>	Trench Spacing: <u>9</u> Feet on Center
Pump Tank Size _____ gallons	Exact length of each trench <u>75</u> feet	Soil Cover: <u>6-12</u> inches
	Trenches shall be installed on contour at a Maximum Trench Depth of: <u>18-24</u> inches	(Maximum soil cover shall not exceed 36" above the trench bottom)
	(Trench bottoms shall be level to +/- 1/4" in all directions)	

Pump Requirements: _____ ft. TDH vs. _____ GPM

Aggregate Depth: NA inches below pipe
NA inches above pipe
NA inches total

Conditions: Gravity to D-Box; Proposal by Adams Soil Consulting

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.
 NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.

Owner/Legal Representative Signature: _____ Date: _____

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit. SEE ATTACHED SITE SKETCH

Authorized State Agent: [Signature] Date: 10/01/2019
ANDREW CURRIN Construction Authorization Expiration Date: 10/01/2024

HTE# SFD1909-0018

Permit # NA

Harnett County Department of Public Health Site Sketch

SR 1440

ISSUED TO: True Homes LLC PROPERTY LOCATION: 26 Norris Farm Dr. (James Norris Rd.)
SUBDIVISION: Norris Farm LOT # 23

Authorized State Agent: *[Signature]* Date: 10/01/2019
ANDREW CURRIN

- * SHALLOW (18IN) TO DEEP (24IN) INSTALL REQUIRED
[CALL PRIOR TO INSTALL IF ADDITIONAL DEPTH REQUIRED]
- * INSTALL CLOSE TO SFD TO MAXIMIZE REPAIR
- * D-BOX DISTRIBUTION REQUIRED

