



Harnett County
108 EAST FRONT STREET
LILLINGTON, NC 27546
Phone:
Fax:

4/7/2021

SUBJECT: SFD1909-0030
SINGLE FAMILY DWELLING

To: Parker Athan

Here are the results of all Inspections located at **12836 NC 27 W:**

Inspection Type: SEWER CONNECTION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Scott Guy
Result:
Remarks:
Notes:

Inspection Type: ENVIR OPERATIONS PERMIT
Scheduled Date/Time:
Completed Date/Time:
Inspector: EH Bucket
Result:
Remarks:
Notes:

Inspection Type: FINAL SFD CRAWL**
Scheduled Date/Time:
Completed Date/Time:
Inspector: Scott Guy
Result:
Remarks:
Notes:

Inspection Type: TAX INSPECTION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Tax Inspection
Result:
Remarks:
Notes:





Harnett County
108 EAST FRONT STREET
LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: TEMP POWER CERTIFICATION
Scheduled Date/Time:
Completed Date/Time:
Inspector: Scott Guy
Result:
Remarks: eTRAKiT Inspection Request
Notes:

Inspection Type: ADDRESS
Scheduled Date/Time:
Completed Date/Time:
Inspector: GIS Bucket
Result:
Remarks:
Notes:

Inspection Type: TEMP POWER CERTIFICATION
Scheduled Date/Time: 11/9/2020
Completed Date/Time: 11/9/2020
Inspector: Steven Gazlay
Result: CANCELLED
Remarks: eTRAKiT Inspection Request
Notes: 11/5/2020 7:46 PM Ricky Congleton

Contact Name: Ricky Congleton
Site Address: 12836 NC 27 W
Phone: 9193232676
e-Mail: ttre24@hotmail.com

Inspection Type: T-POLE
Scheduled Date/Time: 11/9/2020
Completed Date/Time: 11/9/2020
Inspector: Steven Gazlay
Result: APPROVED
Remarks:
Notes:



Harnett County
108 EAST FRONT STREET
LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: FOOTING
Scheduled Date/Time: 12/31/2020 09:00 AM
Completed Date/Time: 12/31/2020
Inspector: Steven Gazlay
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 12/27/2020 8:39 PM Ricky Congleton

Contact Name: Ricky Congleton
Site Address: 12836 NC 27 W
Phone: 9193232676
e-Mail: ttre24@hotmail.com

spg changed Inspection Date/Time from 12/30/2020 Any to 12/31/2020 09:00 AM

Inspection Type: WATER CONNECTION
Scheduled Date/Time: 1/8/2021
Completed Date/Time: 1/8/2021
Inspector: Scott Guy
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 1/7/2021 10:55 AM Ricky Congleton

Contact Name: Ricky Congleton
Site Address: 12836 NC 27 W
Phone: 9193232676
e-Mail: ttre24@hotmail.com

Inspection Type: FOUNDATION
Scheduled Date/Time: 1/20/2021
Completed Date/Time: 1/20/2021
Inspector: Steven Gazlay
Result: CANCELLED
Remarks:
Notes:



Harnett County
108 EAST FRONT STREET
LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: FOUNDATION
Scheduled Date/Time: 1/21/2021
Completed Date/Time: 1/21/2021
Inspector: Scott Guy
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 1/20/2021 1:57 PM Ricky Congleton

Contact Name: Ricky Congleton
Site Address: 12836 NC 27 W
Phone: 9193232676
e-Mail: ttre24@hotmail.com

Inspection Type: OPEN FLOOR
Scheduled Date/Time: 1/26/2021
Completed Date/Time: 1/26/2021
Inspector: Steven Gazlay
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 1/23/2021 4:32 PM Ricky Congleton

Contact Name: Ricky Congleton
Site Address: 12836 NC 27 W
Phone: 9193232676
e-Mail: ttre24@hotmail.com

Inspection Type: FOUNDATION SURVEY
Scheduled Date/Time: 2/23/2021
Completed Date/Time: 2/23/2021
Inspector: Jeanann Dawson
Result: APPROVED
Remarks: NOT REQUIRED
Notes:



Harnett County
108 EAST FRONT STREET
LILLINGTON, NC 27546
Phone:
Fax:

Inspection Type: ROUGH IN
Scheduled Date/Time: 3/15/2021
Completed Date/Time: 3/15/2021
Inspector: Steven Gazlay
Result: DISAPPROVED
Remarks: eTRAKiT Inspection Request
Notes: 3/11/2021 11:36 AM Ricky Congleton

Contact Name: Ricky Congleton
Site Address: 12836 NC 27 W
Phone: 9193232676
e-Mail: ttre24@hotmail.com

Window in bath must be tempered or raised. Seal around tub drain. Missing insulation stops. Strap top plate splices within 24". Bolt drop header on deck. Header cut floor joist. Ok to side and insulate.

Inspection Type: ROUGH IN
Scheduled Date/Time: 3/24/2021
Completed Date/Time: 3/24/2021
Inspector: Steven Gazlay
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 3/23/2021 1:18 PM Ricky Congleton

Contact Name: Ricky Congleton
Site Address: 12836 NC 27 W
Phone: 9193232676
e-Mail: ttre24@hotmail.com

Inspection Type: INSULATION
Scheduled Date/Time: 3/24/2021
Completed Date/Time: 3/24/2021
Inspector: Steven Gazlay
Result: APPROVED
Remarks: eTRAKiT Inspection Request
Notes: 3/23/2021 12:50 PM Ricky Congleton

Contact Name: Ricky Congleton
Site Address: 12836 NC 27 W
Phone: 9193232676
e-Mail: ttre24@hotmail.com