



Date: December 13, 2019

Owner Gerardo Rivera
Address 1429 Red Hill Church Road, Dunn, NC 28334

Re: Distribution Encroachment request for Proposed Septic System
Location: 1429 Red Hill Church Road, NC, 28334

Dear : Mr. Rivera

This letter is in reference to the subject request to install a septic system within the thirty (30) foot wide Easement Area of a Duke Energy Progress, LLC (DEP) overhead electrical service line. An evaluation was made by a Duke Energy engineering technologist and determined that the encroachment can be permitted within our distribution easement area as shown on the attached site plan. DEP acknowledges the utilization of this Easement Area and agrees to said use under the following terms and conditions:

- That DEP shall not be liable for any damage to the septic system resulting from the use of mechanical equipment by DEP or its contractors in the maintenance, construction, reconstruction, and removal of DEP's facilities within the Easement Area.
- No additional Encroachments or modifications to the Encroachment, as shown on Site Plan, may be installed or maintained within the Easement Area without prior review and written approval, at DEP's sole discretion, by DEP.
- That if liquids should escape from said septic system in a sufficient quantity to make the ground soft and impassable to vehicles or endangers the integrity of a pole for said line, you shall correct the condition immediately at your own expense.
- That no equipment or material shall be utilized within the Easement Area in such a manner that it would come closer than 15 feet to any DEP overhead electric conductor(s).

I hope that this satisfactorily responds to your request to construct the septic system on DEP right of way. Please call me at 910-429-3101 if you need further assistance.

Denard R. Haney
Duke Energy Land Representative
Date: December 13, 2019

Owner
Date: December 13, 2019