

Mark E. Jones, PE
Structural Engineering and Design

December 30, 2019

Matthews Backhoe Service
P.O. Box 231
Kipling, NC 27543

Ref: Site Observations and Analysis
107 Bakertown Rd.
Fuquay-Varina, NC
Project No. 19-296

To Whom it may concern;

The above referenced site was visited on December 19, 2019 for the following items:

1. Engineer to perform third party footing inspection.

Based on analysis, the conclusions regarding the condition(s) are:

1. The referenced project is for new construction of a single family dwelling on a crawl space foundation. At the time of the inspection all footings for walls and interior piers had been excavated. The footings were excavated to consistent firm residual soils adequate to support all required design loads. The footings were ready for concrete placement.

Thank you for this opportunity to assist you. If you have any questions or need any further assistance, please do not hesitate to call.

Respectfully,



Mark E. Jones, PE

