



Peak Truss Builders, LLC

PO Box 340, New Hill, NC 27562

Comments and Clarifications

Job #:	Description:	Notes:
Q-1902259	107 Bakertown Rd	Roof Trusses 2' OC, 1' OH 2' OH Over Front Porch
Customer:	Contact:	
Guy C Lee - Clayton		
Address:	Site Address:	
151 Hwy 42 E PO Box 540 Clayton NC 27520	Fuquay-Varina NC	
O: (919) 553-6699 Chris George (919) 427-2997		

Truss Design Date:

1. Rear Porch Rafters and Cricket by Others
2. All exterior/bearing walls are 2x4 (3-1/2" wide) unless otherwise noted.
3. All trusses and engineered wood require proper bracing and blocking. Some bracing guidance is provided in our Field Installation Package. However, "systematic" or "whole house" bracing is the responsibility of the Engineer of Record.
4. Overhang - - horizontal truss dimension is 12". Sub-fascia and fascia are beyond. Front Porch at 24".
5. All perimeter dimensions on layout reflect outside to outside of the sheathing. Studs are held in 1/2" to allow sheathing to line up with edge of slab.

I have Reviewed and Approved above Clarifications:

Signed: _____

Date: _____