Harnett County Department of Public Health

Improvement Permit

A building permit cannot be issued with only an Improvement Permit	
ISSUED TO: Signature Home Blds PROPERTY LOCATION: 936 Middle Road (5/1778)	100
NEW REPAIR EXPANSION Site Improvements required prior to Construction Authorization Issuance:	_
Type of Structure: 14 - Bedram a 24 x 67' SEC	
Proposed Wastewater System Type: 25-90 reduction 53.	
Projected Daily Flow: 485 GPD	
Number of bedrooms:	41
Basement Tres No	
Pump Required: Yes No May be required based on final location and elevations of facilities	
Type of Water Supply: Community Public Well Distance from well NR feet Permit valid for: Eive years	
Permit conditions: No expiration	
01/10/2020	-
Authorized State Agent: SEE ATTACHED SITE SKETCH	
The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.	
Construction Authorization	
(Required for Building Permit)	
The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.	
ISSUED TO: Signature Home Blds PROPERTY LOCATION: 936 Middle Mood (Sr 1778) SUBDIVISION LOT # 1	
Facility Type:	
(See note below, if applicable)	
Installation Requirements/Conditions Number of trenches 3 (Repair)	
Septic Tank Size 1250 gallons Exact length of each trench 135 feet Trench Spacing: 91 Feet on Center	
Pump Tank Sizegallons	
Maximum Trench Depth of: 18 inches (Maximum soil cover shall not exceed	
(Trench bottoms shall be level to +/-1/4" 36" above the trench bottom)	
in all directions)	
Pump Requirements:ft. TDH vsGPMinches below pipe	
Aggregate Depth: inches above pipe	
Conditions: Gravity to D-Box Equal Distribution 35. NA inches total	
WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA. NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.	
**If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.	I
Owner/Legal Representative Signature: Date:	
This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This	
Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.	-
Authorized State Agent: Called Committee Date: CB1/02/2026 01/10/2026	
ANDREW WRITE Construction Authorization Expiration Date 1/02/2025 01/10/2025	

Harnett County Department of Public Health Site Sketch

