



**FIELD REPORT**  
FOUNDATION DEPARTMENT

PROJECT NAME: Academy at Anderson	PROJECT #: 6033.50
PROJECT LOCATION: Spring Lake, NC	SUMMIT REPRESENTATIVE: A. Per
DATE: 2/14/20	PRESENT AT SITE:
CLIENT/CONTRACTOR: Capital City	MILEAGE:
WORK PERFORMED: HA. Drilling & Test	TOTAL TIME:

AS REQUESTED, **SUMMIT** REPRESENTATIVE REPORTED TO THE ABOVE REFERENCED SITE TO EVALUATE NEAR SURFACE FOUNDATION BEARING MATERIALS FOR THE PROPOSED.

LOT/BUILDING NUMBER: 1100

ADDRESS: 101 Education Dr

PERMIT NUMBER: 1412-0040

OUR TESTING AND OBSERVATIONS INDICATE THAT THE SOILS TESTED BY **SUMMIT** (ARE / ARE NOT) SUITABLE FOR THE MINIMUM ALLOWED BEARING CAPACITY OF 2000 PSF AT THIS TIME.

**ACTION REQUIRED:**

Logs and footings are in conformance with project plans

Summit recommends discontinuing test log of footing before pouring

10-14-19

RETURN VISIT REQUIRED: YES/NO

SIGNED (SUMMIT)

SIGNED (CLIENT/CONTRACTOR IF REQUIRED)

**ENGINEERING • LABORATORY • TESTING**

3070 HAMMOND BUSINESS PLACE • SUITE 171 • RALEIGH, NC 27603 • (919) 380-9991 • (919) 380-9993 (FAX)

WWW.SUMMIT-COMPANIES.COM