


Norris Farm 3-Bedroom Septic Proposal Lot #1

1

0.575 AC.
25066 SF

NCSR 1440 (JAMES NORRIS RD.) 60'R/W



NORRIS FARM DR. 50' PUBLIC AND UTILITY EASEMENT

System: Gravity to D-Box
 Lines: 1-3 (225')
 0.4 LTAR
 18-24" Trench Bottom
 Accepted Status System
 Repair: Gravity to D-Box
 Lines: 4-6 (225')
 0.4 LTAR
 18-24" Trench Bottom
 Accepted Status System

GRAPHIC SCALE
1" = 50'



Adams
Soil Consulting
919-414-6761
Job #574