

North Carolina State Laboratory of Public Health

Environmental Sciences

Microbiology

Certificate of Analysis

4312 District Drive MSC 1918

Raleigh, NC 27699-1918

http://slph.ncpublichealth.com Phone: 919-733-7308 Fax: 919-715-8611

FINAL REPORT

Report to: Brittany Adams

Name of System:

HARNETT CO ENVIRONMENTAL HEALTH

Signature Home Builders

307 CORNELIUS HARNETT BLVD

1691 Main St

Lillington, NC 27546

Buies Creek, NC 27506

EIN: 566000306EH

Delivery:

Courier

10:30

Harnett County

StarLiMS ID: ES200618-0135

Date Collected: Date Received: 06/17/2020 06/18/2020 Time Collected:

08:45

Brittany Adams By:

Sample Source:

New Well

Time Received:

By:

Angela Heybroek

Sample Type:

Raw

Sampling Point:

well head spigot

GPS No.

Treatment:

Well Permit No.

Comment:

Analyte

no permit # provided

Colisure Profile

Test Result

Unit

Method: SM 9223B

Total Coliform

Present

Conclusion

Date Tested 06/18/2020

E. coli

Absent

06/18/2020

Report Date:

06/19/2020

Reported By:

KPLEMMONS

Explanations of Coliform Analysis:

If coliform bacteria are Absent, the water is considered safe for drinking purpose. If coliform bacteria are Present, the water is considered unsafe for drinking purpose. Presence of E. coli (bacteria) generally indicates that the water has been contaminated with fecal material. It must be remembered that a water analysis refers only to the sample received and should not be regarded as a complete report on the water supply.

North Carolina Division of Public Health Occupational and Environmental Epidemiology Branch, Epidemiology Section BIOLOGICAL ANALYSIS REPORT

Private well water information and recommendations

County: Harnett Name: Signature Home Sample ID Number: Location: 1691 Main St Buies Creek Reviewer B Adams
Initial Sample Confirmation Sample
BIOLOGICAL ANALYSIS RESULTS AND RECOMMENDATIONS FOR USES OF YOUR PRIVATE WELL WATER (These recommendations are based on biological analysis only.)
No coliform bacteria were found in your well water. Your water can be used for all purposes including drinking, cooking, washing dishes, bathing and showering.
Total coliform bacteria were detected in your water sample. Total Coliform are a group of related bacteria that are (with few exceptions) not harmful to humans. A variety of bacteria, parasites, and viruses, known as pathogens, can potentially cause health problems if humans ingest them. EPA considerated coliforms a useful indicator of other pathogens for drinking water. Total coliforms are used to determine the adequacy of water treatment and the integrity of the distribution system
X It is recommended that your well water be re-tested to verify that the result is accurate.
Fecal coliform bacteria were detected in the sample. Do not use the water for drinking, cooking, vashing dishes, bathing or showering.
f the re-test shows contamination by bacteria contact your local health department for assistance. There

may be a problem with the construction of the well, the groundwater source, or operation of the well. The well needs to be inspected by the local health department or a local well contractor to determine the problem with the well and to give guidance on how to correct the problem.

Your well water was tested for biological contaminants (total coliform and fecal coliform bacteria). The results were evaluated using the federal drinking water standards.

Drinking water may contain substances that can occur naturally in water or can be introduced into water from man-made sources. Total coliform bacteria are found in soil and fecal coliform bacteria are found in animal and human waste. Total coliform or fecal coliform bacteria in well water indicate that the well may have structural problems or that the well was not properly disinfected.

If you have been drinking the well water and are pregnant, nursing, have a child in the household under 5 years of age, or immunocompromised (such as an individual with AIDS, cancer, hepatitis, dialysis or surgical procedures) inform your physician of these results at your next visit.

If the contamination continues, you should investigate the possibility of drilling a new well or installing a point-of-entry disinfection unit which can use chlorine, ultraviolet light, or ozone.

For further information please contact your county health department or the Occupational and Environmental Epidemiology Branch at 919-707-5900.



www.harnett.org

Harnett County Government Complex 307 W. Cornelius Harnett Boulevard Lillington, NC 27546

> ph: 910-893-7547 fax: 910-893-9371

June 24th, 2020

Signature Home Builders 1209 N Main Street Lillington, NC 27546

RE: Bacteriological water sample collected at: 1691 Main Street, Buies Creek

To whom it may concern,

The report of your water sample taken for bacteria, revealed the presence of Total Coli form. A copy of the water sample report is enclosed.

The enclosed pamphlet provides specific directions about how to disinfect the well. If you have any questions, contact the Aquifer Protection Section at the Fayetteville Regional Office at (910) 433-3300 or contact me at (910) 893-7547.

As soon as the well has been treated, contact the Harnett County Division of Environmental Health so another sample can be taken. No fee will be charged for a second sample if the request is made within thirty (30) days of this letter. After thirty (30) days, the fee for a second sample is \$25.00.

If you have any questions, please call me Monday through Friday between 8:00 and 9:00 a.m. at (910) 893-7547.

Sincerely,

Brittany Adams, R.E.H.S.I

Environmental Health

Harnett County Department of Public Health

BA/kh

Enclosures: Water Sample Report

Biological Analysis Report

How to Disinfect Your Water Well