



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

7/9/2025

SUBJECT: **SFD2001-0029**  
**SINGLE FAMILY DWELLING**

To: QUINN JOSHUA M

Here are the results of all Inspections located at **1109 JOE COLLINS RD:**

Inspection Type: FOUNDATION SURVEY  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: CP Bucket  
Result:  
Remarks: not needed  
Notes:

Inspection Type: OPEN FLOOR SFD CRAWL  
Scheduled Date/Time:  
Completed Date/Time:  
Inspector: Scott Guy  
Result:  
Remarks:  
Notes:

Inspection Type: FOOTING  
Scheduled Date/Time: 4/17/2020  
Completed Date/Time: 4/17/2020  
Inspector: Scott Guy  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: FOUNDATION  
Scheduled Date/Time: 4/27/2020  
Completed Date/Time: 4/27/2020  
Inspector: Scott Guy  
Result: APPROVED  
Remarks:  
Notes: Temp -owner pole not installed



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: T-POLE  
Scheduled Date/Time: 5/28/2020  
Completed Date/Time: 5/28/2020  
Inspector: Scott Guy  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: ROUGH IN SFD CRAWL  
Scheduled Date/Time: 6/17/2020  
Completed Date/Time: 6/17/2020  
Inspector: Scott Guy  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: INSULATION  
Scheduled Date/Time: 6/19/2020  
Completed Date/Time: 6/19/2020  
Inspector: Scott Guy  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: ADDRESS  
Scheduled Date/Time: 6/23/2020  
Completed Date/Time: 6/23/2020  
Inspector: GIS Bucket  
Result: APPROVED  
Remarks:  
Notes: 1109 JOE COLLINS RD LILLINGTON 27546.

Inspection Type: TAX INSPECTION  
Scheduled Date/Time: 6/30/2020  
Completed Date/Time:  
Inspector: Tax Inspection  
Result:  
Remarks:  
Notes:



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: ENVIR OPERATIONS PERMIT  
Scheduled Date/Time: 8/14/2020  
Completed Date/Time: 8/14/2020  
Inspector: James Manhart  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: WATER CONNECTION  
Scheduled Date/Time: 8/26/2020  
Completed Date/Time: 8/26/2020  
Inspector: Steven Gazlay  
Result: DISAPPROVED  
Remarks:  
Notes: Work not completed.

Inspection Type: SEWER CONNECTION  
Scheduled Date/Time: 8/26/2020  
Completed Date/Time: 8/26/2020  
Inspector: Steven Gazlay  
Result: FAIL W/ PENALTY  
Remarks:  
Notes: Work not completed.

Inspection Type: WATER CONNECTION  
Scheduled Date/Time: 8/28/2020  
Completed Date/Time: 8/28/2020  
Inspector: Unassigned  
Result: APPROVED  
Remarks:  
Notes: Inspector SPG changed the inspection assignment from SPG to SBL  
Inspector SBL changed the inspection assignment from SBL to RLH

Inspection Type: SEWER CONNECTION  
Scheduled Date/Time: 8/28/2020  
Completed Date/Time: 8/28/2020  
Inspector: Unassigned  
Result: APPROVED  
Remarks:  
Notes: Inspector SPG changed the inspection assignment from SPG to SBL  
Inspector SBL changed the inspection assignment from SBL to RLH



**Harnett County**  
420 McKinney Pkwy  
LILLINGTON, NC 27546  
Phone:  
Fax:

Inspection Type: TEMP POWER CERTIFICATION  
Scheduled Date/Time: 8/31/2020  
Completed Date/Time: 8/31/2020  
Inspector: Steven Gazlay  
Result: DISAPPROVED  
Remarks:  
Notes: Provide and label ac condensate unit. Install switch plates in kitchen.

Inspection Type: TEMP POWER CERTIFICATION  
Scheduled Date/Time: 9/2/2020  
Completed Date/Time: 9/2/2020  
Inspector: Steven Gazlay  
Result: DISAPPROVED  
Remarks:  
Notes: Inspector TSG changed the inspection assignment from TSG to SPG  
Address items from previous inspection

Inspection Type: TEMP POWER CERTIFICATION  
Scheduled Date/Time: 9/3/2020  
Completed Date/Time: 9/3/2020  
Inspector: Steven Gazlay  
Result: APPROVED  
Remarks:  
Notes:

Inspection Type: FINAL SFD CRAWL\*\*  
Scheduled Date/Time: 9/4/2020  
Completed Date/Time: 9/4/2020  
Inspector: Steven Gazlay  
Result: DISAPPROVED  
Remarks:  
Notes: Grade must slope 6" away in 10'. Backfill ditches around home. Missing house numbers. Install handrail. Missing energy certificate. Grout and finish master shower.

Inspection Type: FINAL SFD CRAWL\*\*  
Scheduled Date/Time: 9/8/2020  
Completed Date/Time: 9/8/2020  
Inspector: Steven Gazlay  
Result: FAIL W/ PENALTY  
Remarks:  
Notes: Work to completed.



**Harnett County**  
420 McKinney Pkwy

LILLINGTON, NC 27546

Phone:

Fax:

Inspection Type: FINAL SFD CRAWL\*\*

Scheduled Date/Time: 9/9/2020

Completed Date/Time: 9/9/2020

Inspector: Steven Gazlay

Result: APPROVED

Remarks:

Notes: