Department of Environment, Health and Natural Resources Division of Environmental Health On-Site Wastewater Section

Available Space (.1945) System Type(s) Site LTAR

Sheet: Property ID: Lot #: 5 File #: Code:

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

HiddenLakes

Evalua Evalua	r: ss: sed Facility: on of Site: Supply: ation Method of Wastewate	l: 🔀 Auge	X Public I	☐ Pit	TOV Spi	20 5 -	er		
P R O F I L E	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	.1941 Structure/	ORPHOLOGY 1941 .1941 Consistence	.1942 Soil Wetness/	OTHER PROFILE FACTOR .1943 Soil	.1956 Sapro	.1944 Restr	Profile Class
l	L <51.		GR C		PASAP	Depth (IN.)	Class	Horiz	& LTAR
		34-44	GR SCL BK SCL		2 sssp	44"			PS 0.45
a	LLS,	0-30 30-46	AF SL BK SCL	VFR SEX	p sssp	46	12		P5 0.45
					,				
Descript Available System T	Space (.1945 ype(s)	Sy:	stem	air System	Other Factors (.1946) Site Classification (.1946) Evaluated B Others Present	s: Provision	ally su Adam	itald is	L

COMMENTS: ____

LANDSCAPE POSITIONS	<u>GROUP</u>	<u>TEXTURES</u>	. <u>1955 LTAR</u>	CONSISTENCE MOIST	WET	
R-RIDGE S-SHOULDER SLOPE L-LINEAR SLOPE FS-FOOT SLOPE	I	S-SAND LS-LOAMY SAND SL-SANDY LOAM L-LOAM SI-SILT SIL-SILT LOAM CL-CLAY LOAM SCL-SANDY CLAY LOAM	1.2 - 0.8 0.8 - 0.6	VFR-VERY FRIABLE FR-FRIABLE FI-FIRM	NS-NON-STICKY SS-SLIGHTY STICKY S-STICKY	
N-NOSE SLOPE H-HEAD SLOPE CC-CONCLAVE SLOPE CV-CONVEX SLOPE T-TERRACE FP-FLOOD PLAN	Ш		0.6 - 0.3	VFI-VERY FIRM EFI-EXTREMELY FIRM	VS-VERY STICKY NP-NON-PLASTIC SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC	

0.4 - 0.1

STRUCTURE
SG-SINGLE GRAIN
M- MASSIVE
CR-CRUMB
GR-GRANULAR
SBK-SUBANGULAR BLOCKY
ABK-ANGULAR BLOCKY
PL-PLATY
PR-PRISMATIC

MINERALOGY SLIGHTLY EXPANSIVE

SIC-SILTY CLAY C-CLAY SC-SANDY CLAY

EXPANSIVE

IV

