Department of Environment, Health and Natural Resources Division of Environmental Health On-Site Wastewater Section

Sheet:
Property ID:
Lot #:
File #:
Code:

SOIL/SITE EVALUATION for ON-SITE WASTEWATER SYSTEM

5TD2002-0007

Owner: - Applicant: LGI Homo LCC	AUBRIT	POND
Address: 62 Waterville way Proposed Facility: 382 5=5 Date Evaluated: 02/22/2020 Design Flow (.1949): 360(05) Property Recorded:	607	148
		»·
Water Supply: Public Individual Well Spring Other Evaluation Method: Auger Boring Pit Cut		
Type of Wastewater: Sewage Industrial Process Mixed		

P R O F I L	.1940 Landscape	Horizon	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS .1942				
E #	Position/ Slope %	Depth (In.)	.1941 Structure/ Texture	.1941 Consistence Mineralogy	Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	Profile Class & LTAR
1	L 3%	0-12	chis	WA NEND					
		12-38	BN SIL	Fr se					P3
		384	Povert	-		36			6.35
a	L 3%	0-12	61 L5	ven ist					PS
9	3/0		3N SIL		75714, C 36"	36			0.35

Description	Initial	Repair System	Other Factors (.1946):
	System		Site Classification (.1948): Provisionally sortable
Available Space (.1945)			Evaluated by.
System Type(s)	25% mc	25% Mc	Others Present: Finder Cossia neto
Site LTAR	0.35	0.35	


COMMENTS: ____

LANDSCAPE POSITIONS	GROUP	TEXTURES	. <u>1955 LTAR</u>	CONSISTENCE MOIST	WET
R-RIDGE S-SHOULDER SLOPE L-LINEAR SLOPE	I	S-SAND LS-LOAMY SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE	NS-NON-STICKY SS-SLIGHTY STICKY
FS-FOOT SLOPE N-NOSE SLOPE H-HEAD SLOPE	II	SL-SANDY LOAM L-LOAM	0.8 - 0.6	FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	S-STICKY VS-VERY STICKY NP-NON-PLASTIC SP-SLIGHTLY STICKY P-PLASTIC VP-VERY PLASTIC
CC-CONCLAVE SLOPE CV-CONVEX SLOPE T-TERRACE FP-FLOOD PLAN	III	SI-SILT SIL-SILT LOAM CL-CLAY LOAM SCL-SANDY CLAY LOAM	0.6 - 0.3		
	IV	SIC-SILTY CLAY C-CLAY SC-SANDY CLAY	0.4 - 0.1		

STRUCTURE
SG-SINGLE GRAIN
M- MASSIVE
CR-CRUMB
GR-GRANULAR
SBK-SUBANGULAR BLOCKY
ABK-ANGULAR BLOCKY
PL-PLATY
PR-PRISMATIC

MINERALOGY SLIGHTLY EXPANSIVE

EXPANSIVE



WATERWILLE WAY

9