


## Harnett County Department of Public Health Improvement Permit

A building permit cannot be issued with only an Improvement Permit

ISSUED TO: Ben Stout Real Estate      PROPERTY LOCATION: 259 Hamilton Rd, Bunnlevel      SR# 2037  
 SUBDIVISION \_\_\_\_\_ LOT # \_\_\_\_\_  
 NEW       REPAIR       EXPANSION       Site Improvements required prior to Construction Authorization Issuance: \_\_\_\_\_  
 Type of Structure: SFD 64'x32'  
 Proposed Wastewater System Type: 25% Reduction  
 Projected Daily Flow: 360 GPD  
 Number of bedrooms: 3      Number of Occupants: 6 max  
 Basement  Yes       No  
 Pump Required:  Yes       No       May be required based on final location and elevations of facilities  
 Type of Water Supply:  Community       Public       Well      Distance from well \_\_\_\_\_ feet      Permit valid for:  Five years  
 Permit conditions: \_\_\_\_\_       No expiration

Authorized State Agent:       Date: 3/1/2020      SEE ATTACHED SITE SKETCH  
 The issuance of this permit by the Health Department in no way guarantees the issuance of other permits. The permit holder is responsible for checking with appropriate governing bodies in meeting their requirements. This site is subject to revocation if the site plan, plat, or the intended use changes. The Improvement Permit shall not be affected by a change in ownership of the site. This permit is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.

### Construction Authorization (Required for Building Permit)

The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1958, and .1959 are incorporated by references into this permit and shall be met. Systems shall be installed in accordance with the attached system layout.

ISSUED TO: Ben Stout Real Estate      PROPERTY LOCATION: 259 Hamilton Rd, Bunnlevel  
 SUBDIVISION \_\_\_\_\_ LOT # \_\_\_\_\_  
 Facility Type: SFD 64'x32'       New       Expansion       Repair  
 Basement?  Yes       No      Basement Fixtures?  Yes       No  
 Type of Wastewater System\*\* 25% Reduction      (Initial) Wastewater Flow: 360 GPD  
 (See note below, if applicable )      Pump to 25% Reduction (Repair)  


Installation Requirements/Conditions	Number of trenches <u>1</u>	
Septic Tank Size <u>1000</u> gallons	Exact length of each trench <u>260</u> feet	Trench Spacing: <u>9</u> Feet on Center
Pump Tank Size _____ gallons	Trenches shall be installed on contour at a Maximum Trench Depth of: <u>18-20</u> inches (Trench bottoms shall be level to +/-1/4" in all directions)	Soil Cover: <u>6</u> inches (Maximum soil cover shall not exceed 36" above the trench bottom)
Pump Requirements: _____ ft. TDH vs. _____ GPM		Aggregate Depth: _____ inches below pipe _____ inches above pipe _____ inches total

 Conditions: \_\_\_\_\_

**WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM ANY PART OF SEPTIC SYSTEM OR REPAIR AREA.  
 NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.**

\*\*If applicable: I understand the system type specified is different from the type specified on the application. I accept the specifications of this permit.  
 Owner/Legal Representative Signature: \_\_\_\_\_ Date: \_\_\_\_\_

This Construction Authorization is subject to revocation if the site plan, plat, or the intended use changes. The Construction Authorization shall not be transferred when there is a change in ownership of the site. This Construction Authorization is subject to compliance with the provisions of the Laws and Rules for Sewage Treatment and Disposal and to the conditions of this permit.      SEE ATTACHED SITE SKETCH

Authorized State Agent:       Date: 3/1/2020  
 Construction Authorization Expiration Date: 3/1/2025


Application # SFD2002-0036

### Harnett County Department of Public Health Site Sketch

Property Location: 259 Hamilton Rd, Bunnlevel

Issued To: Benjamin Stout Leaf Estate Subdivision \_\_\_\_\_ Lot # \_\_\_\_\_

Authorized State Agent: B. Alch REHS-I Date: 3/2/2020



This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.