## Wayne R. Dashield, PE

421-B South Bright Leaf Blvd. Smithfield, NC 27577

(919) 934-0961

April 14, 2020

Re. Permit # SFD-2002-0016 90 Kotata Ave Bunn Level, NC


To: Harnett County Inspections

On April 14, 2020 I made an onsite visit to 90 Kotata Ave located in Bunn Level, North Carolina. The purpose of this visit was to inspect the existing footing for the proposed house. The Footing was excavated approximately 12" below the plan excavation and had a soil bearing capacity over 3000 PSF. (See attached sheet) I will recommend the area below the footings be backfilled with # 57 stone.

If I can be of any more assistance, please feel free to contact me.

Yours truly,

Wayne R. Dashield, PE



## Wayne R. Dashield, PE 421-B BRIGHT LEAF BLVD. Smithfield, NC 27577

3/27/2020

## CONE PENETROMETER TEST RESULTS 90 KOTATA AVE BUNN LEVEL, NC

## SOIL BEARING TESTS

			DEPTH IN FT.	CALCULATE		C Pass	Soil
TEST		LOCATION	DIST BELOW	DIAL	BEARING	1	Туре
NO.	DATE	WALL#	FOUNDATION	READING	LBS. / S.F.	Fail	
1	4/14/2020	NE CORNER	1.0	320	3026	Pass	SM
2	4/14/2020	OFF NW CORN	1.0	370	3489	Pass	SM

\*\* ADD 12" #57 STONE BELOW FOOTING

All cone penetrometer test were preformed in the center of the feeting.

COMMENTS:

in the center of the footing MINIMUM BEARING 2500 PSF

