

SOUTHEASTERN SOIL & ENVIRONMENTAL ASSOC., INC.

PROPOSED SUBSURFACE WASTE DISPOSAL SYSTEM DETAIL SHEET

SUBDIVISION: OAKMONT
INITIAL SYSTEM: APPROVED 25% REDUCTION ^{pump to}
DISTRIBUTION: SEMIAL
BENCHMARK: 100.0
NO. BEDROOMS: 4

LOT 297
REPAIR APPROVED 25% REDUCTION ^{pump to}
DISTRIBUTION SEMIAL
LOCATION PC 297/298
LTAR 0.6 GPD/FTL

LINE	FLAG COLOR	ELEVATION	LENGTH
1 2 3 4A	P	106.25	40'
	W	105.50	65'
	P	104.58	80'
	W	103.84	15'
			<u>200'</u>
4B	W	103.84	60'
5	P	102.75	75'
6	W	101.75	75'
			<u>210'</u>

Initial system

BY M EAKER

DATE 03/2015

TYPICAL PROFILE

0-30 U/L (VF, wsc)
30-48 SCL (Fr, sbk)
cr 2/pm > 36"
INSTALL AT 18"-20"

THERE SHALL BE NO GRADING,
CUTTING, LOGGING OR OTHER SOIL
DISTURBANCE IN SEPTIC AREA