Norris Farm Lot #9

4-Bedroom Home (480 gal./day)

			1101110 (40)	•				
LINE #	<u>COLOR</u>	<u>BS</u>	<u>HI</u>	<u>FS</u>	ELEVATION	LINE LENGTH	Design Length	
TBM		2.0		100.0		<u>in field</u>	<u>installation</u>	
INST. 1			102.0					
1	Red			1.7	100.3	103	100	
2	Yellow			2.1	99.9	120	100	
3	Pink			2.4	99.6	128	100	
4	Blue			2.7	99.3	132	75	
5	Orange			3	99	75	75	
6	White			3.2	98.8	75	75	
7	Red			3.4	98.6	75	75	
			_					
			_	System		<u>Repair</u>		
				Lines 1-3		Lines 4-7		
System Type			Accep	ted Status S	ystem A	Accepted Status Syst	em	
Suggested Soil LTAR			0.40			0.40		
33								
Total Line Length			300			300		
	•	•						
Square Footage			900			900		
Duan and Transk Battons			2.411			24"		
Proposed Trench Bottom		24"			24"			
			G	Gravity to D-				
Distribution Method			В	Box		Gravity to D-Box		