

Date: 08/28/2020

To: Donald Mangum
lisatrygod@aol.com
919-915-2528

Re: Inspection Item
Location: 79 JT McNeill Lane, Lillington, NC
JDSfaulkner Project No.: RDU2008326
Date of Inspection: 08/28/2020

A representative of JDSfaulkner arrived on site to observe the issues reported to us by the client which are presented, along with our recommendations, in this report.

Observations:

Contractor has requested evaluation of the (3) 2x10 header installed over the double garage doors with a max clear span of 9'-3" where the approved plans call for a (2) 2x10 header over the openings.

Recommendations:

Based on our on-site observations and review, the (3) 2x10 header is adequate to support the anticipated loading conditions and no further action is required.

If you have any questions or if I can be of further assistance to you on this project, please contact me at 984-365-4043.

Respectfully Submitted,
Nick Galban
JDSfaulkner

