Harnett County Department of Public Health Improvement Permit

A building permit cannot be issued with only an Improvement Permit


	PROPERTY LOCATION: 1351 Line Rd		
	SUBDIVISION		LOT #
NEW X REPAIR EXPANSION Type of Structure: SFD (56'x60')	Site Improvements re-	quired prior to Construction Authoriz	ration Issuance:
Proposed Wastewater System Type: 25% Reduction System			
Projected Daily Flow: 360 GPD			
Number of bedrooms: 3 Number of Occupants: 6n	nax		
Basement Yes No			
Pump Required: Yes No May be required based on final loc			
Type of Water Supply: 🗌 Community 🔲 Public 🗵 Well Distance	from wellfeet	Permit valid for:	Five years
Permit conditions:			No expiration
4 1/1			
Authorized State Agent::	Date: 4/17/2020	CEE ATTA	CHED GITE CRETCH
Authorized State Agent:: The issuance of this permit by the Health Department in no way guaranteed the issuance of other	STATE OF THE STATE	50,000,000,000	CHED SITE SKETCH
site is subject to revocation if the site plan, plat, or the intended use changes, the Improvement Potthe Laws and Rules for Sewage Treatment and Disposal and to conditions of this permit.	ermit shall not be affected by a change in own	ership of the site. This permit is subject to c	ompliance with the provisions of
Constru	ction Authorization		
	ired for Building Permit)		
The construction and installation requirements of Rules .1950, .1952, .1954, .1955, .1956, .1957, .1		into this permit and shall be met. Systems	shall be installed in accordance
with the attached system layout.			
ISSUED TO: Paul Lyon	PROPERTY LOCATION: 1351 Li	ne Rd	
2000 200 000 000 000 000 000 000 000 00	SUBDIVISION		LOT #
Facility Type: SFD (56'x60') New	☐ Expansion ☐ Repair		
Basement? 🗌 Yes 🗵 No Basement Fixtures? 🗌 Yes	■ No		
Type of Wastewater System** 25% Reduction System		(Initial) Wastewater Flow:	360 GPD
(See note below, if applicable 🔲)			
25% Reduction System	(Repair)		
Installation Requirements/Conditions Number of trenche	25 3		
Septic Tank Size 1000 gallons Exact length of ea	ch trench 75 feet	Trench Spacing: 9	Feet on Center
	installed on contour at a	Soil Cover: 6i	nches
Maximum Trench I	Depth of: 18 inches	(Maximum soil cover shall n	ot exceed
	hall be level to +/-1/4"	36" above the trench botto	
in all directions)			1
Pump Requirements:ft. TDH vsGPM			inches below pipe
rump requirements.		Aggregate Depth:	inches above pipe
Conditions:		766. cgate peptiii	inches total
conditions.			menes total
WATER LINES (INCLUDING IRRIGATION) MUST BE 10FT. FROM AN NO UTILITIES ALLOWED IN INITIAL OR REPAIR DRAIN FIELD AREA.		REPAIR AREA.	
**If applicable: 1 understand the system type specified is different from th	e type specified on the application	. I accept the specifications of th	his permit.
Owner/Legal Representative Signature:		Date:	
This Construction Authorization is subject to revocation if the site plan, plat, or the intended use ch	anges. The Construction Authorization shall not	be transferred when there is a change in ow	enership of the site. This
Construction Authorization is subjected compliance with the provisions of the Laws and Rules for Se			ATTACHED SITE SKETCH
the late			
Authorized State Agent: REAS	Date:	4/17/2020	
Additionated State Agents	ection Authorization Expiration [
Constru	iction Authorization Expiration L	Jaic. Tilleozo	

Harnett County Department of Public Health Site Sketch

Property Location: 1351 Line Rd		
Issued To: Paul Lyon	Subdivision	Lot #
Authorized State Agent:	PENS (OLIVEZ TOLKSOOF)	Date: 4/17/2020

A BYSTEM FLAGGED

* CALL WHY ANY
QUESTIONS PRIOR
To INSTALLATION



This drawing is for illustrative purposes only. System installation must meet all pertinent laws, rules, and regulations.