

Mark E. Jones, PE
Structural Engineering and Design

June 4, 2020

Gregory, Inc.
62 E. McIver St.
Angier, NC 27501

Ref: Site Observations and Analysis
752 Butts Rd.
Angier, NC
Project No. 20-129

To Whom it may concern;

The above referenced site was visited on June 1, 2020 for the following items:

1. Engineer to perform third party footing inspection.

Based on analysis, the conclusions regarding the condition(s) are:

1. The referenced project is for new construction of a single-family dwelling with a crawl space foundation. At the time of the inspection all footings for walls and interior piers had been excavated. Firm soils were encountered in all locations. All footings met the requirements of the 2018 NC Residential Building Code Section R403. The footings were ready for concrete placement.

Thank you for this opportunity to assist you. If you have any questions or need any further assistance, please do not hesitate to call.

Respectfully,



Mark E. Jones, PE