SOUTHEASTERN SOIL & ENVIRONMENTAL ASSOC., INC.

PROPOSED SUBSURFACE WASTE DISPOSAL SYSTEM DETAIL SHEET

SUBDIVISION: Summerlin

LOT 55

INITIAL SYSTEM: Gravity APPROVED 25% REDUCTION

REPAIR Gravity APPROVED 25% Reduction

DISTRIBUTION: D-Box

DISTRIBUTION D-Box

BENCHMARK: 100.0

LOCATION BC Lot 55/RD IRON

NO. BEDROOMS: 4

LTAR 0.8 gpd/Ft^2

	LINE	FLAG COLOR	ELEVATION	LENGTH
I	1	W	101.00	50
	2	B	100.67	50
	3	W	100.25	50
				150
R	4	B	99.75	50
	5	W	99.08	50
	6	B	98.25	50
				150

BY B.C. Raynor

DATE 07/15/2018

TYPICAL PROFILE

0-36 LS vfri gran

CR 2 > 36"

THERE SHALL BE NO GRADING, CUTTING, LOGGING OR OTHER SOIL DISTURBANCE IN SEPTIC AREA

50'
50'
50'
50'
55
55