

ROOF TRUSS REQUIREMENTS

TRUSS DESIGN. Trusses to be designed and engineered in accordance with good design practice. Any addition with these drawings must be brought to Haynes Home Plan, Inc. attention before construction begins.

KNEE WALL AND CEILING HEIGHTS. All finished knee wall heights and ceiling heights are shown finished down 1/2" from roof decking for insulation. If for any reason the truss manufacturer fails to meet or exceed design load then height, finished knee wall height, or finished ceiling height shown on these drawings the finished ceiling height may vary. Any discrepancy must be brought to Haynes Home Plan, Inc. attention, so a suitable solution can be reached before construction begins. Any variation due to these conditions not being met is the responsibility of the truss manufacturer.

ANCHORAGE. All required anchors for trusses due to uplift or bearing shall meet the requirements as specified on the truss schedule.

BEARING. All trusses shall be designed for bearing on girt 2.2 plates or larger unless noted otherwise.

Peak Heights & Head Systems. See elevation page(s) for peak heights and flow system indications.

STRUCTURAL NOTES

All construction shall conform to the latest requirements of the 2018 North Carolina Building Code, plus all local codes and regulations. This document is to be used in conjunction with the code.

JOIST PRACTICES AND SAFETY: Haynes Home Plan, Inc. assumes no liability for construction practices and procedures or safety program. Haynes Home Plan, Inc. shall not be responsible for the contractor's failure to carry out the construction work in accordance with the contract documents. All members shall be framed, anchored, and braced in accordance with good construction practice and the building code.

USE	LINE LOAD (PSF)	EQUID LOAD (PSF)	DEFLECTION (IN)
Roof without storage	20	20	L/240
Attics with limited storage	40	20	L/240
Attics with full storage	40	40	L/240
Attics with full storage and deck	40	80	L/240
Fire escapes	40	80	L/240
Garage and landings	200	200	---
General in-fill components	50	50	L/360
Passenger vehicle garages	50	50	L/360
Rooms other than living	40	20	L/240
Shedding rooms	20	20	L/240
Stairs	40	40	L/240
Slopes	20	---	---

FRAMING LUMBER: All non-bearing framing lumber shall be SYP #2 (1b) or SYP #1 (1b) or SYP #2 (1b) = 750 PSI and all bearing lumber shall be SYP #2 (1b) = 750 PSI unless noted otherwise.

ENGINEERED WOOD BEAMS:

Laminated veneer lumber (LVL) = 1b-2000 PSI, 1b-2005 PSI, E-1.5x10x10 PSI
Parallel strand lumber (PSL) = 1b-2000 PSI, 1b-2005 PSI, E-2.0x10x10 PSI
Laminated strand lumber (LSL) = 1b-2100 PSI, 1b-4000 PSI, E-1.5x10x10 PSI
I-joist = all members per manufacturer's instructions.

TRUSS AND JOIST MEMBERS: All roof truss and joist truss shall be designed in accordance with this document. Trusses and joists shall be designed according to the manufacturer's specifications. Any change in truss or joist design shall be coordinated with Haynes Home Plan, Inc. before all members are manufactured.

TRUSS AND JOIST MEMBERS: All roof truss and joist truss shall be designed in accordance with this document. Trusses and joists shall be designed according to the manufacturer's specifications. Any change in truss or joist design shall be coordinated with Haynes Home Plan, Inc. before all members are manufactured.

MEMBERS: All roof truss and joist truss shall be designed in accordance with this document. Trusses and joists shall be designed according to the manufacturer's specifications. Any change in truss or joist design shall be coordinated with Haynes Home Plan, Inc. before all members are manufactured.

MEMBERS: All roof truss and joist truss shall be designed in accordance with this document. Trusses and joists shall be designed according to the manufacturer's specifications. Any change in truss or joist design shall be coordinated with Haynes Home Plan, Inc. before all members are manufactured.

ATTIC ACCESS

SECTION 8007.1 ATTIC ACCESS: An attic access opening shall be provided to the attic that exceeds 400 square feet (37.25 sq) and have a vertical height of 60 inches (5'0" min) or greater. The net clear opening shall not be less than 20 inches by 20 inches (50 sq ft) and shall be located in a hallway or other readily accessible location. A 30-inch (762 mm) minimum unobstructed headroom in the attic space shall be provided at some point above the access opening. See Section 8005.1.3 for access requirements where mechanical equipment is located in attics.

Exceptions:

1. Concentrated areas not located over the main structure including porches, areas below stair wells, dormers, bay windows, etc.
2. Full door size stairs, gangways, landings, and hallways may protrude into the net clear opening.

EXTERIOR HEADERS

(2) 2 X 6 WITH 1 JACK STUD EACH END
UNLESS NOTED OTHERWISE
KING STUDS EACH END PER TABLE BELOW

HEADERS	1	2	3	4	5	6
1 KING STUDS	1	2	3	4	5	6

INTERIOR HEADERS

LOAD BEARING HEADERS (2) 2 X 6 WITH 1 JACK STUD AND 1 KING STUD EACH END
UNLESS NOTED OTHERWISE
NON LOAD BEARING HEADERS TO BE LADDER FRAMED

