

Norris Farm

Lot #16

4-Bedroom Home (480 gal./day)

<u>LINE #</u>	<u>COLOR</u>	<u>BS</u>	<u>HI</u>	<u>FS</u>	<u>ELEVATION</u>	<u>LINE LENGTH</u>	<u>Design Length</u>
TBM		2.0		100.0		<u>in field</u>	<u>installation</u>
INST. 1			102.0				
1	Pink			2.5	99.5	83	60
2	White			2.8	99.2	90	60
3	Blue			3.1	98.9	75	60
4	Yellow			3.3	98.7	70	60
5	Orange			3.6	98.4	68	60
6	Red			1.7	100.3	65	50
7	Pink			1.9	100.1	65	50
8	White			2	100	60	50
9	Blue			2.1	99.9	60	50
10	Yellow			2.2	99.8	58	50
11	Orange				102	55	50

System

Repair

Lines 1-5

Lines 6-10

System Type

Accepted Status System

Accepted Status System

Suggested Soil LTAR

0.40

0.40

Total Line Length

300

300

Square Footage

900

900

Proposed Trench Bottom

18"

18"

Distribution Method

Gravity to D-Box

Gravity to D-Box