

HTE# SFD 2005-0078

HARNETT COUNTY HEALTH DEPARTMENT
ENVIRONMENTAL HEALTH
307 CORNELIUS HARNETT BOULEVARD
LILLINGTON, NC 27546

EXISTING SEPTIC SYSTEM INSPECTION

NAME Serenity Built Homes Inc PHONE # 910-984-7042

ADDRESS P.O. Box 1417 Lillington N.C. 27546

NAME OF MOBILE HOME PARK OR S/D 6+9

NAME OF OWNER (IF DIFFERENT) Marilyn Moore

ADDRESS OF OWNER (IF DIFFERENT) 51 ALEPLN Angier N.C. 27501

PROPERTY LOCATION: STATE ROAD NAME AND # 512 1552 Abattoir RD

The aforementioned site has been evaluated by the Harnett County Health Department Environmental Health Section. At the time of inspection, there appeared to be a septic system serving this site. If this system should malfunction, the owner is responsible for any necessary repairs.

THIS INSPECTION IS VOID IF:

Rebuild Run Down

- (1) the intended use of the septic system should change, and/or
- (2) the system should fail or malfunction, and/or
- (3) the owner or tenant of the property changes, and/or
- (4) after six months

**BUILDING MUST BE 5' FROM ANY PART OF SEPTIC SYSTEM
DO NOT DRIVE OR PARK ON SEPTIC SYSTEM**

AUTHORIZATION OF EXISTING SYSTEM

James E. Marshall IR TSOAS
Signature of Inspector

6-23-20
Date