

June 9th, 2020

ph: 910-893-7547

fax: 910-893-9371

Serenity Built Homes
Po Box 1417
Lillington, NC 27546

RE: Existing Tank Application # SFD 2005-0078

To whom it may concern,

An attempt was made to evaluate your property for the purpose of issuing an existing tank permit. The evaluation could not be completed for one or more of the following reasons.

1. Uncover outlet lid on septic tank and break seal. (\$25.00 fee incurred).

2. Have system pumped out

3. Replace Sanitary T

4. Other –

Your application will be put on hold until the selected items above have been addressed. When completed **call 893-7547 to confirm** that the items mentioned have been corrected, we will then reschedule your property for evaluation.

Sincerely,



James E. Manhart III, R.E.H.S.
Environmental Health Program Specialist
Harnett County Department of Public Health

JEM/kh
Copy - Central Permitting