





Truss Placement Plan SCALE: NTS

= Indicates Left End of Truss
(Reference Engineered Truss Drawing)
Do NOT Erect Truss Backwards

			_		_		
LOAD CHART FOR JACK STUDS  (BASED ON TABLES P502.5(1) & (b))  NUMBER OF JACK STUDS REQUIRED @ EA END OF			BUILDER	H&H Homes	COUNTY	County	THIS IS A These trus the building sheets for
END REACTION (UP TO) REQ'D STUDS FOR (2) PLY HEADER	HEADER/GIRDER	END REACTION (JP TO) REQ'D STUDS FOR (4) PLY HEADER	JOB NAME	Engage A	ADDRESS	Site Address	is responsi the overall walls, and or regarding b or online @ Bearing re prescriptiv
	END REACTION (UP TO) REQ'D STUDS FOR (3) PLY HEADER		PLAN	Engage A	MODEL	Roof	
1700 1 3400 2 5100 3	2550 1 5100 2 7650 3	3400 1 6800 2 10200 3	SEAL DATE	12/22/17	DATE REV.	03/05/18	( derived foundation than 3000 be retained
6800 4 8500 5 10200 6	10200 4 12750 5 15300 6	13600 4 17000 5	QUOTE#	B0318-0845	DRAWN BY	Marshall Naylor	specified retained to
11900 7 13600 8 15300 9			JOB#	Order#	SALESMAN	Marshall Naylor	1

THIS IS A TRUSS PLACEMENT DIAGRAM ONLY.

These trusses are designed as individual building components to be incorporated into the building design at the specification of the building designer. See individual design sheets for each truss design identified on the placement drawing. The building designer is responsible for temporary and permanent bracing of the roof and floor system and for the overall structure. The design of the truss support structure including headers, beams, walls, and columns is the responsibility of the building designer. For general guidance regarding bracing, consult BCSI-B1 and BCSI-B3 provided with the truss delivery package or online @ sbcindustry.com

Bearing reactions less than or equal to 3000# are deemed to comply with the prescriptive Code requirements. The contractor shall refer to the attached Tables derived from the prescriptive Code requirements) to determine the minimum oundation size and number of wood studs required to support reactions greater than 3000# but not greater than 15000#. A registered design professional shall be retained to design the support system for any reaction that exceeds those specified in the attached Tables. A registered design professional shall be retained to design the support system for all reactions that exceed 15000#.

Marshall Naylor



Reilly Road Industrial Park Fayetteville, N.C. 28309 Phone: (910) 864-8787 Fax: (910) 864-4444