

Mark E. Jones, PE
Structural Engineering and Design

June 15, 2020

Raynor Builders
725 N. Raleigh St.
Angier, NC 27501

Ref: Site Observations and Analysis
156 East Main St.
Coats, NC
Project No. 20-136

To Whom it may concern;

The above referenced site was observed on June 10, 2020 for the following items:

1. Engineer to evaluate footing excavation.

Based on analysis, the conclusions regarding the condition(s) are:

1. The referenced site was inspected per plans and all foundation walls and interior piers had been excavated. Firm soils were encountered in all locations. The footings were ready for concrete placement.

Thank you for this opportunity to assist you. If you have any questions or need any further assistance, please do not hesitate to call.

Respectfully,



Mark E. Jones, PE

