

**SOIL/SITE EVALUATION
 for ON-SITE WASTEWATER SYSTEM**

Owner: - Applicant: TREVOR & AMANDA JOHNSON
 Address: 323 SMITH PRINCE Date Evaluated: 06/25/2026
 Proposed Facility: 3rd ST Design Flow (.1949): 36000 Property Size:
 Location of Site: Property Recorded:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1,2	L 3-4%	0-8	CL SL	VR NSMP					
		8-38	CL C	FI SP					PS
		38+	Parent Mat.	-		38			0.3
3,4,5	L 3-4%	0-8	CL SL	VR NSMP					
		8-42	CL C	FI SP					PS
		42+	Parent Mat.	-		42			0.3
* LITOCROMATIC FEATURES 24IN+ BUT NOT 50% PARENT MATERIAL									
NON SOIL WETNESS, LARGE PARENT MATERIAL TRANSITION.									
A,C,D	L 3-4%	0-16	CL SL	VR NSMP					PS
		10-40	CL C	FI SP	7.5F171 @ 38"	40			0.3
B	L 3-4%	0-16	CL SL	VR NSMP					0/PS
		10-36	CL C	FI ST	7.5F171 @ 34"	36			0.3

Description	Initial System	Repair System	Other Factors (.1946):
Available Space (.1945)	<input checked="" type="checkbox"/>	<input checked="" type="checkbox"/>	Site Classification (.1948): <u>PROVISIONALLY SUITABLE</u>
System Type(s)	<u>25% RED</u>	<u>25% RED</u>	Evaluated By: <u>ANDREW CORWIN, MCH</u>
Site LTAR	<u>0.3</u>	<u>0.3</u>	Others Present:

COMMENTS: _____

LANDSCAPE POSITIONS	GROUP	TEXTURES	.1955 LTAR	CONSISTENCE MOIST	WET
R-RIDGE S-SHOULDER SLOPE L-LINEAR SLOPE FS-FOOT SLOPE N-NOSE SLOPE H-HEAD SLOPE CC-CONCLAVE SLOPE CV-CONVEX SLOPE T-TERRACE FP-FLOOD PLAN	I	S-SAND LS-LOAMY SAND	1.2 - 0.8	VFR-VERY FRIABLE FR-FRIABLE	NS-NON-STICKY SS-SLIGHTY STICKY
	II	SL-SANDY LOAM L-LOAM	0.8 - 0.6	FI-FIRM VFI-VERY FIRM EFI-EXTREMELY FIRM	S-STICKY VS-VERY STICKY NP-NON-PLASTIC SP-SLIGHTLY STICKY
	III	SI-SILT SIL-SILT LOAM CL-CLAY LOAM SCL-SANDY CLAY LOAM	0.6 - 0.3		P-PLASTIC VP-VERY PLASTIC
	IV	SIC-SILTY CLAY C-CLAY SC-SANDY CLAY	0.4 - 0.1		

STRUCTURE
 SG-SINGLE GRAIN
 M-MASSIVE
 CR-CRUMB
 GR-GRANULAR
 SBK-SUBANGULAR BLOCKY
 ABK-ANGULAR BLOCKY
 PL-PLATY
 PR-PRISMATIC

MINERALOGY
 SLIGHTLY EXPANSIVE
 EXPANSIVE

(4)

Show profile locations and other site features (dimensions, references or benchmark, and North)

