

Truss Placement Plan SCALE: NTS

= Indicates Left End of Truss
(Reference Engineered Truss Drawing)
Do NOT Erect Truss Backwards

LOAD CHART FOR JACK STUDS									
(BASED ON TABLES R502.5(1) & (b))									
NUMBER OF JACK STUDS REQUIRED @ EA END OF HEADER/GIRDER									
END REACTION (UP TO)	REQ'D STUDS FOR (2) PLY HEADER		END REACTION (UP TO)	REQ'D STUDS FOR (3) PLY HEADER		END REACTION (UP TO)	REQ'D STUDS FOR (4) PLY HEADER		
1700	1		2550	1		3400	1		
3400	2		5100	2		6800	2		
5100	3		7650	3		10200	3		
6800	4		10200	4		13600	4		
8500	5		12750	5		17000	5		
10200	6		15300	6					
11900	7								
13600	8								
15300	9								

			_
H&H Homes	CITY / CO.		THIS IS A TR These trusses a the building desi sheets for each t is responsible fo the overall struct walls, and colum regarding bracin
	ADDRESS		
Vision A	MODEL		or online @ sbci Bearing reaction prescriptive Co
7/22/19	DATE REV.	/ /	(derived from foundation size than 3000# but be retained to
	DRAWN BY		specified in the retained to des
	SALES REP.		Signature_
	Vision A	ADDRESS Vision A MODEL 7/22/19 DATE REV. DRAWN BY	ADDRESS Vision A MODEL 7/22/19 DATE REV. / / DRAWN BY

THIS IS A TRUSS PLACEMENT DIAGRAM ONLY.
These trusses are designed as individual building components to be incorporated into
the building design at the specification of the building designer. See individual design
sheets for each truss design identified on the placement drawing. The building designe
is responsible for temporary and permanent bracing of the roof and floor system and fo
the overall structure. The design of the truss support structure including headers, bean
walls, and columns is the responsibility of the building designer. For general guidance
regarding bracing, consult BCSI-B1 and BCSI-B3 provided with the truss delivery packa
or online @ sbcindustry.com
Descring reactions loss than ar equal to 2000# are deemed to comply with the

Bearing reactions less than or equal to 3000# are deemed to comply with the prescriptive Code requirements. The contractor shall refer to the attached Tables (derived from the prescriptive Code requirements) to determine the minimum foundation size and number of wood studs required to support reactions greater than 3000# but not greater than 1500#. A registered design professional shall be retained to design the support system for any reaction that exceeds those specified in the attached Tables. A registered design professional shall be retained to design the support system for all reactions that exceed 15000#.

Sügnature

Sales Area

соттесн
ROOF & FLOOR
TRUSSES & BEAMS

Reilly Road Industrial Park Fayetteville, N.C. 28309 Phone: (910) 864-8787 Fax: (910) 864-4444