

## Truss Placement Plan SCALE: 1/4"=1'

= Indicates Left End of Truss
(Reference Engineered Truss Drawing)
Do NOT Erect Truss Backwards

LOAD CHART FOR JACK STUDS									
(BASED ON TABLES R502.5(1) & (b)) NUMBER OF JACK STUDS REQUIRED @ EA END OF HEADER/GIRDER									
END REACTION (UP TO)	REQ D STUDS FOR (2) PLY HEADER		END REACTION (UP TO)	REQ'D STUDS FOR (3) PLY HEADER		END REACTION (UP TO)	REQ'D STUDS FOR (4) PLY HEADER		
1700	1		2550	1		3400	1		
3400	2		5100	2		6800	2		
5100	3		7650	3		10200	3		
6800	4		10200	4		13600	4		
8500	5		12750	5		17000	5		
10200	6		15300	6					
11900	7								
13600	8								
15300	_								

			OUALE: I/T I	
BUILDER	H&H Homes	CITY / CO.		THIS IS A TR These trusses a the building des sheets for each
JOB NAME		ADDRESS		is responsible fo the overall struct walls, and colum regarding bracin
PLAN	Vantage B	MODEL	Roof	or online @ sbci  Bearing reactio prescriptive Co ( derived from foundation size than 300# but be retained to despecified in the retained to des
SEAL DATE	4/8/20	DATE REV.	/ /	
QUOTE#		DRAWN BY Marshall Naylor	Marshall Naylor	
JOB#		SALES REP.	Marshall Naylor	

THIS IS A TRUSS PLACEMENT DIAGRAM ONLY.

These trusses are designed as individual building components to be incorporated into the building design at the specification of the building designer. See individual design sheets for each truss design identified on the placement drawing. The building designer is responsible for temporary and permanent bracing of the roos of and floor system and for the overall structure. The design of the truss support structure including headers, beams, walls, and columns is the responsibility of the building designer. For general guidance regarding bracing, consult BCSI-B1 and BCSI-B3 provided with the truss delivery package or online @ sbcindustry.com

Bearing reactions less than or equal to 3000# are deemed to comply with the

dearing reactions less than or equal to 3000# are deemed to comply with the rescriptive Code requirements. The contractor shall refer to the attached Tables derived from the prescriptive Code requirements ) to determine the minimum bundation size and number of wood studs required to support reactions greater and 3000# but not greater than 15000#. A registered design professional shall be retained to design the support system for any reaction that exceeds those pecified in the attached Tables. A registered design professional shall be stained to design the support system for all reactions that exceed 15000#.

Marshall Naylor

Marshall Naylor



Reilly Road Industrial Park Fayetteville, N.C. 28309 Phone: (910) 864-8787 Fax: (910) 864-4444