


# Olde Mill Village 4-Bedroom Septic Proposal Lot #50



System: Gravity to D-Box  
 Lines: 6-8 (405')  
 0.3 LTAR  
 18" Trench Bottom  
 Accepted Status System  
 Repair: Pressure Manifold  
 Lines: 2-5 (400')  
 0.3 LTAR  
 18" Trench Bottom  
 Accepted Status System

GRAPHIC SCALE  
 1" = 50'



Adams  
 Soil Consulting  
 919-414-6761  
 Job #699