

**Date:** 12/07/2020

**To:** John Dove  
Dove Homes, LLC  
7720 Penny Road  
Raleigh, NC 27606  
jdove@dove-homes.com  
919-427-6991

**Re: Inspection Item**  
Location: 197 Farrah-Shea Way, Angier, NC  
JDSfaulkner Project No.: RDU2011754  
Date of Inspection: 12/07/2020

A representative of JDSfaulkner arrived on site to observe the issues reported to us by the client which are presented, along with our recommendations, in this report.

**Observations:**

3" nails have been installed in the HTU26 hangers into the girder trusses in lieu of the 3-1/2" nails required based on the manufacturer's specifications.

**Recommendations:**

Based on our on-site observations and review, the hangers are adequate to support the anticipated loads as installed; no further action required.

If you have any questions or if I can be of further assistance to you on this project, please contact me at 919-818-8717.

Respectfully Submitted,  
James Chang  
JDSfaulkner

