


- --- 1 RELIABLE Model RFC49 Concealed Pendant Spr FP
 K=4.9, 155F°, 7/16" Orifice, Maximum Spacing 20'x20'
 Sprinkler head demand: 20 gpm @ 16.7
 RFC49-20
- --- 19 RELIABLE Model RFC49 Concealed Pendant Spr FP
 K=4.9, 155F°, 7/16" Orifice, Maximum Spacing 16'x16'
 Sprinkler head demand: 13 gpm @ 7.04
 RFC49-16
- --- 3 RELIABLE Model RFC49 Concealed Pendant Spr FP
 K=4.9, 155F°, 7/16" Orifice, Maximum Spacing 18'x18'
 Sprinkler head demand: 17 gpm @ 12.03
 RFC49-18


SPRINKLER DESCRIPTIONS



Most Demanding Single Head Information	
Information	Results
Flow Required at Head (GPM):	20
Source Pressure at Head (PSI):	16.7
Maximum Spacing (length):	20
Maximum Spacing (Width):	20
Domestic Flow Added (GPM):	0
Sprinkler Model:	RFC49
Elevation of Highest Head:	109
K-Factor	4.9
Temperature Rating:	155
Flow Required at Source (GPM)	20
Pressure Required at Source (psi)	40.79
Source Reference Point:	At Ref Pt STR
C-Factor of Sprinkler Pipe	150
C-Factor of Service Line	150
Head Reference Point:	H.1

Most Demanding Two Head Information	
Information	Results
Flow Required at Head (GPM):	13
Source Pressure at Head (PSI):	7.04
Maximum Spacing (length):	16
Maximum Spacing (Width):	16
Domestic Flow Added (GPM):	0
Sprinkler Model:	RFC49
Elevation of Highest Head:	118
K-Factor	4.9
Temperature Rating:	155
Flow Required at Source (GPM)	26.0075
Pressure Required at Source (psi)	49.37
Source Reference Point:	At Ref Pt STR
C-Factor of Sprinkler Pipe	150
C-Factor of Service Line	150
Head Reference Point:	H.23 & H.22

LEGEND	
-----	Manifold
○ A	Inter Level Connection
● irAB1+	Hot Water Fixture
● irAB1+	Cold Water Fixture
—	Type K Copper w/ ProPress Fittings
—	Type L Copper w/ ProPress Fittings
—	Type M Copper w/ ProPress Fittings
—	ViegaPEX Ultra Black
—	ViegaPEX Ultra Blue - Cold Plumbing
—	ViegaPEX Ultra Red - Hot Plumbing



WATER SERVICE DETAIL



VIEGA LLC'S DESIGN SERVICES DEPARTMENT HAS PREPARED THIS SERIES OF DRAWINGS AS THE FIRST DESIGN FOR PLUMBING, RADIANT, SNOW MELTING OR FIRE SUPPRESSION SYSTEMS FOR THE USE OF YOU, OUR CUSTOMER, IN PREPARING OR OBTAINING SPECIFICATIONS, BIDS AND PROPOSALS IN CONNECTION WITH THE SALE OF THESE SYSTEMS. THESE DRAWINGS ARE BASED UPON INFORMATION PROVIDED BY YOU AND HAVE BEEN PREPARED TO APPROPRIATE PROFESSIONAL STANDARDS OF DESIGN BASED UPON THAT INFORMATION. THESE DRAWINGS ARE NOT TO BE CONSIDERED FINAL AND, PRIOR TO PERFORMING ANY WORK ASSOCIATED WITH THESE DESIGNS OR DRAWINGS, YOU MUST:

- 1) CHECK AND CONFIRM ALL PIPE SIZES, CALCULATIONS, MATERIALS, PLUMBING AND/OR FIRE CODES USED OR APPLICABLE; AND
- 2) PRESENT THE DRAWINGS TO YOUR PROFESSIONAL ENGINEER FOR REVIEW AND APPROVAL AND HAVE THE DRAWINGS MARKED "FINAL" BY YOUR PROFESSIONAL ENGINEER.

IF YOUR PROFESSIONAL ENGINEER REPORTS ANY ERRORS IN THE DRAWINGS OR MAKES ANY CHANGES IN THE DRAWINGS, THESE ERRORS OR CHANGES MUST BE COMMUNICATED TO VIEGA LLC'S DESIGN SERVICES DEPARTMENT FOR A DETERMINATION IF A REVISION TO THE DESIGN IS NECESSARY.

VIEGA LLC DISCLAIMS ANY WARRANTIES, EXPRESS OR IMPLIED, ASSOCIATED WITH THE DESIGN OF THE SYSTEM OR ITS USE. ALL DESIGNS ARE PROVIDED "AS IS" AND IT IS YOUR SOLE RESPONSIBILITY TO CONFIRM AND ENSURE THAT THE SYSTEM TO BE INSTALLED WILL OPERATE AND FUNCTION IN COMPLIANCE WITH ALL APPLICABLE CODES AND IN ACCORDANCE WITH ALL APPLICABLE SPECIFICATIONS.

Design Services Department
 1900 Southwood Drive - Nashua, NH 03063
 Tel: 877-843-4262 x 351 Fax: 316-425-8466

Project:
182 OAKHAVEN DRIVE
HOLLY SPRINGS, NC 27540

Dwg no.:
FP 1 OF 3

Title:
MAIN FLOOR PLAN

Quotation no.: FPNM2102-006 NC


Drawn by: N.M.

Approved by:

Date Submitted: 02/10/2021

Scale: 1/4" = 1'

Revision No: Revision Date:



VIEGA LLC'S DESIGN SERVICES DEPARTMENT HAS PREPARED THIS SERIES OF DRAWINGS AS THE FIRST DESIGN FOR PLUMBING, RADIANT, SNOW MELTING OR FIRE SUPPRESSION SYSTEMS FOR THE USE OF YOU, OUR CUSTOMER, IN PREPARING / OBTAINING SPECIFICATIONS, BIDS AND PROPOSALS IN RELATION TO THE SALE OF THESE SYSTEMS. THESE DRAWINGS ARE BASED UPON INFORMATION PROVIDED BY YOU AND HAVE BEEN PREPARED TO APPROPRIATE PROFESSIONAL STANDARDS OF DESIGN BASED UPON THAT INFORMATION. THESE DRAWINGS ARE NOT TO BE CONSIDERED FINAL AND, PRIOR TO PERFORMING ANY WORK ASSOCIATED WITH THESE DESIGNS OR DRAWINGS, YOU MUST:

- 1) CHECK AND CONFIRM ALL PIPE SIZES, CALCULATIONS, MATERIALS, PLUMBING AND / OR FIRE CODES USED OR APPLICABLE; AND
- 2) PRESENT THE DRAWINGS TO YOUR PROFESSIONAL ENGINEER FOR REVIEW AND APPROVAL AND HAVE THE DRAWINGS MARKED "FINAL" BY YOUR PROFESSIONAL ENGINEER.

IF YOUR PROFESSIONAL ENGINEER REPORTS ANY ERRORS IN THE DRAWINGS OR MAKES ANY CHANGES IN THE DRAWINGS, THESE ERRORS OR CHANGES MUST BE COMMUNICATED TO VIEGA LLC'S DESIGN SERVICES DEPARTMENT FOR A DETERMINATION IF A REVISION TO THE DESIGN IS NECESSARY.

VIEGA LLC DISCLAIMS ANY WARRANTIES, EXPRESS OR IMPLIED, ASSOCIATED WITH THE DESIGN OF THE SYSTEM OR ITS USE. ALL DESIGNS ARE PROVIDED "AS IS" AND IT IS YOUR SOLE RESPONSIBILITY TO CONFIRM AND ENSURE THAT THE SYSTEM TO BE INSTALLED WILL OPERATE AND FUNCTION IN COMPLIANCE WITH ALL APPLICABLE CODES AND IN ACCORDANCE WITH ALL APPLICABLE SPECIFICATIONS.

Design Services Department
 1900 Southwood Drive - Nashua, NH 03063
 Tel: 877-843-4262 x 351 Fax: 316-425-8466

Project:

182 OAKHAVEN DRIVE
HOLLY SPRINGS, NC 27540

Dwg no.:
FP 2 OF 3

Title:
BONUS ROOM PLAN

Quotation no.: FPNM2102-006 NC	
Drawn by:	N.M.
Approved by:	
Date Submitted:	02/10/2021
Scale:	1/2" = 1'
Revision No:	Revision Date:

FIRE PROTECTION INSTALLATION NOTES:

- INSTALLATION OF THE FIRE PROTECTION SYSTEM SHALL BE INSTALLED IN ACCORDANCE WITH THE 2016 EDITION OF NFPA 13D OR SECTION P2904 OF THE 2018 INTERNATIONAL RESIDENTIAL CODE (IRC). NFPA 13D IS THE STANDARD FOR THE INSTALLATION OF SPRINKLER SYSTEMS IN ONE- AND TWO-FAMILY DWELLINGS AND MANUFACTURED HOMES.
- INSTALLATION OF THE FIRE PROTECTION SYSTEM SHALL COMPLY WITH ALL LOCAL RESIDENTIAL FIRE PROTECTION CODES AND ALL APPLICABLE STATE REGULATIONS.
- SPRINKLER HEADS SHALL MEET ALL GENERAL CARE AND INSTALLATION REQUIREMENTS OF THE SPRINKLER MANUFACTURER. SUBSTITUTION OF SPRINKLER HEADS IS NOT PERMITTED.
- AFTER INSTALLATION OF THE SPRINKLERS, THE ENTIRE SYSTEM SHALL BE PRESSURE TESTED IN ACCORDANCE WITH STATE AND LOCAL CODE REQUIREMENTS. SPRINKLERS SHALL BE LOCATED PER THE LAYOUT. DO NOT INSTALL SPRINKLERS IN AREAS EXPOSED TO TEMPERATURES THAT EXCEED THE MAXIMUM RECOMMENDED AMBIENT TEMPERATURE FOR THE TEMPERATURE RATING USED. MINIMUM DISTANCE OF SPRINKLER HEADS FROM HEAT SOURCES SHALL COMPLY WITH TABLE 7.5.6.3 IN THE 2016 EDITION OF NFPA 13D, INSTALLATION OF SPRINKLER SYSTEMS IN ONE - AND TWO - FAMILY DWELLINGS AND MANUFACTURED HOMES.
- NO DEVIATIONS FROM THE PLAN SHALL BE ALLOWED WITHOUT APPROVAL FROM THE AUTHORITY HAVING JURISDICTION AND DESIGNER.
- PIPING AND SPRINKLER FITTINGS SHALL BE SUPPORTED IN COMPLIANCE WITH LOCAL PLUMBING CODE AND THE 2016 EDITION OF NFPA 13D, INSTALLATION OF SPRINKLER SYSTEMS IN ONE - AND TWO - FAMILY DWELLINGS AND MANUFACTURED HOMES.
- SMOKE DETECTORS SHALL BE INSTALLED IN ACCORDANCE WITH NFPA 72, NATIONAL FIRE ALARM CODE. WHEN NOT EQUIPPED WITH SMOKE DETECTORS, LOCAL WATERFLOW ALARMS SHALL BE REQUIRED.
- WATER SOFTENERS AND WATER FILTRATION DEVICES SHALL NOT BE INSTALLED IN THE SYSTEM WITHOUT A REVIEW OF THE HYDRAULIC CALCULATIONS OF THE SYSTEM.
- A SIGN SHALL BE AFFIXED ADJACENT TO THE MAIN SHUTOFF VALVE THAT STATES IN MINIMUM 1/4" LETTERS, "WARNING: THE WATER SYSTEM FOR THIS HOME SUPPLIES FIRE SPRINKLERS THAT REQUIRE CERTAIN FLOWS AND PRESSURES TO FIGHT A FIRE. DEVICES THAT RESTRICT THE FLOW OR DECREASE THE PRESSURE OR AUTOMATICALLY SHUT OFF THE WATER TO THE FIRE SPRINKLER SYSTEM, SUCH AS WATER SOFTENERS, FILTRATION SYSTEMS, AND AUTOMATIC SHUT-OFF VALVES, SHALL NOT BE ADDED TO THIS SYSTEM WITHOUT A REVIEW OF THE FIRE SPRINKLER SYSTEM BY A FIRE PROTECTION SPECIALIST. DO NOT REMOVE THIS SIGN."
- ALL PIPING AND FITTINGS SHALL BE PROPERLY INSULATED AND PROTECTED SO THAT THEY ARE NOT EXPOSED TO TEMPERATURES BELOW 40° F.
- WHEN THE MAXIMUM STATIC PRESSURE EXCEEDS 80 PSI, A PRESSURE-REDUCING VALVE SHALL BE INSTALLED. NFPA 13D RESTRICTS THE OPERATING PRESSURE OF PEX SYSTEMS TO 80 PSI. PRESSURE DROP THROUGH THE PRESSURE-REDUCING DEVICE SHALL BE INCLUDED IN THE HYDRAULIC CALCULATIONS.
- WHEN A FIRE DEPARTMENT CONNECTION IS REQUIRED, PEX TUBING SHALL NOT BE PERMITTED. CONSULT WITH THE AUTHORITY HAVING JURISDICTION (AHJ) ABOUT THIS REQUIREMENT PRIOR TO INSTALLATION.

PLUMBING INSTALLATION NOTES:

- INSTALLATION OF HOT AND COLD WATER DISTRIBUTION SYSTEMS SHALL BE IN ACCORDANCE WITH THE LOCAL PLUMBING CODE.
- WATER SOFTENERS AND WATER FILTRATION DEVICES SHALL NOT BE INSTALLED WITHOUT A REVIEW OF THE HYDRAULIC CALCULATIONS OF THE SYSTEM.
- FINAL APPROVAL OF MULTIPURPOSE AND PASSIVE PURGE FIRE SPRINKLER INSTALLATIONS SHALL BE FROM THE AUTHORITY HAVING JURISDICTION.

TESTING:

- EVERY VIEGA NFPA 13D FIRE PROTECTION INSTALLATION SHALL BE PRESSURE TESTED IN ACCORDANCE WITH NFPA 13D, WHICH STATES THAT SYSTEMS WITHOUT FIRE DEPARTMENT CONNECTIONS SHALL BE TESTED FOR LEAKAGE AT THE NORMAL SYSTEM OPERATING WATER PRESSURE.
- THE AUTHORITY HAVING JURISDICTION (AHJ) MAY REQUIRE A FLOW VERIFICATION TEST OF THE MOST HYDRAULICALLY REMOTE SPRINKLER HEAD(S). THIS FLOW VERIFICATION TEST IS AVAILABLE TO ENSURE THE INSTALLED FIRE PROTECTION SYSTEM OPERATES AS DESIGNED. DOCUMENTATION ON HOW TO PERFORM A FLOW VERIFICATION TEST IS AVAILABLE THROUGH VIEGA TECHNICAL SERVICES.
- THE FLOW VERIFICATION TEST SHALL BE PERFORMED AFTER ALL PIPING, FITTINGS, SPRINKLER HEADS AND PLUMBING CONNECTIONS HAVE BEEN INSTALLED AND PRESSURE TESTING OF THE SYSTEM HAS BEEN COMPLETED. THE FLOW TEST SHOULD OCCUR WHILE IN THE "ROUGH" STAGE OF CONSTRUCTION. FLOW TEST RESULTS SHOULD BE COMPARED TO THE SYSTEM DESIGN VALUES. RESIDUAL PRESSURE (PSI) AND FLOW (GPM) MUST BE EQUAL TO OR GREATER THEN THE DESIGN VALUES TO ENSURE A PROPERLY FUNCTIONING SYSTEM.

DRAWING AND DESIGN NOTES:

- DESIGN SHALL ENSURE WATER SUPPLY TO THE MOST HYDRAULICALLY DEMANDING SINGLE AND DUAL SPRINKLER HEADS.
- TUBING AND FITTINGS SHALL BE U.L. LISTED FOR RESIDENTIAL FIRE PROTECTION SYSTEMS IN ACCORDANCE WITH NFPA 13D.
- VIEGAFEX ULTRA (BLACK IN COLOR) LISTED TO U.L. 1821 FOR RESIDENTIAL WET-PIPE FIRE PROTECTION SYSTEMS IN ACCORDANCE WITH NFPA 13D.
- VIEGA PEX PRESS FITTINGS (POLYMER AND BRONZE) LISTED TO U.L. 1821 FOR RESIDENTIAL WET-PIPE FIRE PROTECTION SYSTEMS IN ACCORDANCE WITH NFPA 13D.
- APPROVED SMOKE DETECTION SYSTEMS AND/OR WATER FLOW ALARMS SHALL BE INSTALLED WHERE REQUIRED BY THE AUTHORITY HAVING JURISDICTION (AHJ).

MATERIALS LIST NOTES:

- SERVICE ENTRANCE MATERIALS FROM WATER MAIN CONNECTION TO DISTRIBUTION MANIFOLD ARE EXCLUDED.
- SPRINKLERS AND ASSOCIATED ESCUTCHEONS OR COVER PLATES ARE NOT SUPPLIED BY VIEGA.
- MATERIAL LIST IS SUGGESTED ONLY. CONTRACTOR SHALL CONFIRM REQUIRED MATERIALS PRIOR TO PLACEMENT OF ORDER.




FIGURE A.9.1.1(a) Insulation Recommendations — Arrangement 1.




FIGURE A.9.1.1(b) Insulation Recommendations — Arrangement 2.




FIGURE A.9.1.1(c) Insulation Recommendations — Arrangement 3.




FIGURE A.9.1.1(d) Insulation Recommendations — Arrangement 4.




FIGURE A.9.1.1(e) Insulation Recommendations — Arrangement 5.

INSULATION DETAILS - ANNEX A.9.1.1 (NFPA 13D 2016)





WATER METER PRESSURE LOSSES (PSI) - TABLE 10.4.4(A) NFPA 13D (2016)						
Meter Size (in.)	Flow (gpm)					
	18 or less	23	26	31	39	52
5/8"	9	14	18	26	38	*
3/4"	7	11	14	22	35	*
1"	2	3	3	4	6	10
1-1/2"	1	1	2	2	4	7
2"	1	1	1	1	2	3

TABLE 10.4.4(a) (NFPA 13D 2016)

DISTANCES FROM HEAT SOURCES - TABLE 7.5.6.3 NFPA 13D (2016)		
Heat Source	Ordinary Temp. 135° - 170°	Intermediate Temp. 175° - 220°
Side of Fireplace	36"	12"
Front of Fireplace	60"	36"
Coal or Wood Burning Stove	42"	12"
Kitchen Range	18"	9"
Wall Oven	18"	9"
Hot Air Flues	18"	9"
Uninsulated Heat Ducts	18"	9"
Uninsulated Hot Water Pipes	12"	6"
Side of Hot Air Diffusers	24"	12"
Front of Hot Air Diffusers	36"	18"
Hot Water Heater or Furnace	6"	3"
Light Fixture 0 W - 250 W	6"	3"
Light Fixture 250 W - 499 W	12"	6"

TABLE 7.5.6.3 (NFPA 13D 2016)

INSTALLATION NOTES



INSTALLATION DETAIL - SPRINKLER BRACKETS

Project:

182 OAKHAVEN DRIVE
HOLLY SPRINGS, NC 27540

Dwg no.:

FP 3 OF 3

Title:

NOTES & DETAILS

Quotation no.: FPNM2102-006 NC

Drawn by:

N.M.

Approved by:

Date Submitted: 02/10/2021

Scale:

N/A

Revision No.:

Revision Date:

VIEGA LLC'S DESIGN SERVICES DEPARTMENT HAS PREPARED THIS SERIES OF DRAWINGS AS THE FIRST DESIGN FOR PLUMBING, RADIANT, SNOW MELTING OR FIRE SUPPRESSION SYSTEMS FOR THE USE OF YOU, OUR CUSTOMER, IN PREPARING OR OBTAINING SPECIFICATIONS, BIDS AND PROPOSALS IN RELATION TO THE SALE OF THESE SYSTEMS. THESE DRAWINGS ARE BASED UPON INFORMATION PROVIDED BY YOU AND HAVE BEEN PREPARED TO APPROPRIATE PROFESSIONAL STANDARDS OF DESIGN BASED UPON THAT INFORMATION. THESE DRAWINGS ARE NOT TO BE CONSIDERED FINAL AND, PRIOR TO PERFORMING ANY WORK ASSOCIATED WITH THESE DESIGNS OR DRAWINGS, YOU MUST:

- CHECK AND CONFIRM ALL PIPE SIZES, CALCULATIONS, MATERIALS, PLUMBING AND / OR FIRE CODES USED OR APPLICABLE; AND
- PRESENT THE DRAWINGS TO YOUR PROFESSIONAL ENGINEER FOR REVIEW AND APPROVAL AND HAVE THE DRAWINGS MARKED "FINAL" BY YOUR PROFESSIONAL ENGINEER.

IF YOUR PROFESSIONAL ENGINEER REPORTS ANY ERRORS IN THE DRAWINGS OR MAKES ANY CHANGES IN THE DRAWINGS, THESE ERRORS OR CHANGES MUST BE COMMUNICATED TO VIEGA LLC'S DESIGN SERVICES DEPARTMENT FOR A DETERMINATION IF A REVISION TO THE DESIGN IS NECESSARY.

VIEGA LLC DISCLAIMS ANY WARRANTIES, EXPRESS OR IMPLIED, ASSOCIATED WITH THE DESIGN OF THE SYSTEM OR ITS USE. ALL DESIGNS ARE PROVIDED "AS IS" AND IT IS YOUR SOLE RESPONSIBILITY TO CONFIRM AND ENSURE THAT THE SYSTEM TO BE INSTALLED WILL OPERATE AND FUNCTION IN COMPLIANCE WITH ALL APPLICABLE CODES AND IN ACCORDANCE WITH ALL APPLICABLE SPECIFICATIONS.

Design Services Department
1900 Southwood Drive - Nashua, NH 03063
Tel: 877-843-4262 x 351 Fax: 316-425-8466

viega

Viega LLC
Technical Services Department
1900 Southwood Drive
Nashua, NH 03063
603-882-7171

Job Name : 182 OAKHAVEN DRIVE - One Head Calculation (H.1)
Building : SINGLE FAMILY RESIDENCE
Location : HOLLY SPRINGS NC 27540
System : NFPA 13D
Contract : FPNM2102-006 NC
Data File : FPNM2102-006 NC (182 Oakhaven Drive).wx1

HYDRAULIC DESIGN INFORMATION SHEET

Name - 182 OAKHAVEN DRIVE Date - 02/10/2021
 Location -
 Building - SINGLE FAMILY RESIDENCE System No. - NFPA 13D
 Contractor - CUMBERLAND HOMES INC. Contract No. - FPNM2102-006 NC
 Calculated By - VIEGA LLC Drawing No. - FPNM2102-006 NC
 Construction: (X) Combustible () Non-Combustible Ceiling Height 9
 OCCUPANCY - RESIDENTIAL

S Type of Calculation: ()NFPA 13 Residential ()NFPA 13R (X)NFPA 13D
 Y Number of Sprinklers Flowing: (X)1 ()2 ()4 ()
 S ()Other
 T ()Specific Ruling Made by Date

E
 M Listed Flow at Start Point - 20 Gpm System Type
 Listed Pres. at Start Point - 16.7 Psi (X) Wet () Dry
 D MAXIMUM LISTED SPACING 20 x 20 () Deluge () PreAction
 E Domestic Flow Added - 0 Gpm Sprinkler or Nozzle
 S Additional Flow Added - Gpm Make RELIABLE Model RFC49
 I Elevation at Highest Outlet - 109 Feet Size 7/16 K-Factor 4.9
 G Note: Temperature Rating 155
 N

Calculation Gpm Required 20 Psi Required 40.79 At Ref Pt STR
 Summary C-Factor Used: Overhead 150 Underground 150

W Water Flow Test: Pump Data: Tank or Reservoir:
 A Date of Test - x Rated Cap. Cap.
 T Time of Test - x @ Psi Elev.
 E Static (Psi) - 71 Elev.
 R Residual (Psi) - 20 Other Well
 Flow (Gpm) - 168 Proof Flow Gpm
 S Elevation - 100

P Location: x
 P
 L Source of Information: x
 Y


Water Supply Curve

Viega LLC
182 OAKHAVEN DRIVE - One Head Calculation (H.1)

Page 2
Date 2/22/2021

City Water Supply:
C1 - Static Pressure : 71
C2 - Residual Pressure: 20
C2 - Residual Flow : 168

Demand:
D1 - Elevation : 3.898
D2 - System Flow : 20.024
D2 - System Pressure : 40.786
Hose (Demand) :
D3 - System Demand : 20.024
Safety Margin : 29.217



Fittings Used Summary

Viega LLC
182 OAKHAVEN DRIVE - One Head Calculation (H.1)

Page 3
Date 2/22/2021

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	Generic Gate Valve	1	1	1	1	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Vpel *	PEX Press 90 Elbow - Poly	12.6	18.9	17.7	18.6	29.4	36.4	0	0	0											
Vprt *	PEX Press Tee - Run-Poly	3.9	3.6	3.8	6.4	7.9	10.2	0	0	0											
Vptb *	PEX Press Tee - Branch-Poly	14	19.1	18.4	18.7	28.3	37.5	0	0	0											

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Flow Summary - NFPA

Viega LLC
182 OAKHAVEN DRIVE - One Head Calculation (H.1)

Page 4
Date 2/22/2021

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
STR	71.0	20	168.0	70.003	20.02	40.786

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
H.1	109.0	4.9	16.7	20.02	400
H.8	109.0		19.32		
T.27	109.0		21.42		
H.13	109.0		22.72		
S.1	98.0		31.44		
MTR	100.0		38.02		
STR	100.0		40.79		
H.4	109.0		17.41		
H.3	109.0		17.81		
H.2	109.0		18.31		
H.5	109.0		19.06		
H.9	109.0		19.37		
T.24	109.0		19.58		
H.10	109.0		19.83		
H.11	109.0		19.92		
H.12	109.0		20.04		
T.25	109.0		20.29		
H.6	109.0		20.58		
H.7	109.0		20.75		
T.26	109.0		21.22		
H.15	109.0		19.67		
H.17	109.0		19.95		
H.18	109.0		20.04		
T.29	109.0		20.23		
H.16	109.0		20.26		
H.14	109.0		20.28		
T.30	109.0		20.25		
T.33	118.0		16.6		
H.20	118.0		16.64		
H.23	118.0		16.78		
H.22	118.0		16.83		
H.21	118.0		16.89		
H.19	118.0		16.95		
T.32	118.0		16.97		
T.31	109.0		21.12		
T.28	109.0		21.15		

Final Calculations : Hazen-Williams

Viega LLC
182 OAKHAVEN DRIVE - One Head Calculation (H.1)

Page 5
Date 2/22/2021

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
H.1 to H.8	109 109	4.90	12.55	1	Vprt	3.8	24.000 3.800	150	16.700 0.0			
			12.55	0.863			27.800	0.0941	2.617	Vel =	6.88	
H.8 to T.27	109 109		0.0	1	Vptb	18.4	4.000 18.400	150	19.317 0.0			
			12.55	0.863			22.400	0.0941	2.108	Vel =	6.88	
T.27 to H.13	109 109		7.47	1	Vprt	3.8	2.000 3.800	150	21.425 0.0			
			20.02	0.863			5.800	0.2233	1.295	Vel =	10.98	
H.13 to S.1	109 98		0.0	1	Vprt T	3.8 2.92	11.000 6.720	150	22.720 4.764			
			20.02	0.863			17.720	0.2233	3.957	Vel =	10.98	
S.1 to MTR	98 100		0.0	1.25	2E	2.429	50.000 2.429	150	31.441 2.134		** Fixed Loss = 3	
			20.02	1.053			52.429	0.0847	4.442	Vel =	7.38	
MTR to STR	100 100		0.0	1	E T	3.022 7.555	20.000 12.089	150	38.017 0.0			
			20.02	1.049	G	1.511	32.089	0.0863	2.769	Vel =	7.43	
STR			0.0 20.02						40.786	K Factor =	3.13	
H.1 to H.4	109 109		7.47	1	Vprt	3.8	16.000 3.800	150	16.700 0.0			
			7.47	0.863			19.800	0.0361	0.714	Vel =	4.10	
H.4 to H.3	109 109		0.0	1			11.000	150	17.414 0.0			
			7.47	0.863			11.000	0.0360	0.396	Vel =	4.10	
H.3 to H.2	109 109		0.0	1	Vprt	3.8	10.000 3.800	150	17.810 0.0			
			7.47	0.863			13.800	0.0360	0.497	Vel =	4.10	
H.2 to H.5	109 109		0.0	1	Vprt	3.8	17.000 3.800	150	18.307 0.0			
			7.47	0.863			20.800	0.0361	0.750	Vel =	4.10	
H.5 to H.9	109 109		0.0	1	Vprt	3.8	5.000 3.800	150	19.057 0.0			
			7.47	0.863			8.800	0.0360	0.317	Vel =	4.10	
H.9 to T.24	109 109		0.0	1	Vprt	3.8	2.000 3.800	150	19.374 0.0			
			7.47	0.863			5.800	0.0360	0.209	Vel =	4.10	
T.24 to H.10	109 109		-4.03	1	Vptb Vprt	18.4 3.8	7.000 22.200	150	19.583 0.0			
			3.44	0.863			29.200	0.0086	0.250	Vel =	1.89	
H.10 to H.11	109 109		0.0	1	Vprt	3.8	6.000 3.800	150	19.833 0.0			
			3.44	0.863			9.800	0.0086	0.084	Vel =	1.89	
H.11 to H.12	109 109		0.0	1	Vprt	3.8	10.000 3.800	150	19.917 0.0			
			3.44	0.863			13.800	0.0086	0.119	Vel =	1.89	
H.12 to T.25	109 109		0.0	1	Vptb	18.4	11.000 18.400	150	20.036 0.0			
			3.44	0.863			29.400	0.0086	0.252	Vel =	1.89	

Final Calculations : Hazen-Williams

Viega LLC
182 OAKHAVEN DRIVE - One Head Calculation (H.1)

Page 6
Date 2/22/2021

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
T.25 to H.6	109 109		1.33 4.77	1 0.863	Vprt	3.8	15.000 3.800 18.800	150 0.0157	20.288 0.0 0.295		Vel = 2.62	
H.6 to H.7	109 109		0.0 4.77	1 0.863	Vprt	3.8	7.000 3.800 10.800	150 0.0157	20.583 0.0 0.170		Vel = 2.62	
H.7 to T.26	109 109		0.0 4.77	1 0.863	Vptb	18.4	11.000 18.400 29.400	150 0.0157	20.753 0.0 0.463		Vel = 2.62	
T.26 to T.27	109 109		2.70 7.47	1 0.863	Vprt	3.8	2.000 3.800 5.800	150 0.0360	21.216 0.0 0.209		Vel = 4.10	
T.27			0.0 7.47						21.425		K Factor = 1.61	
T.24 to H.15	109 109		4.03 4.03	1 0.863	Vprt	3.8	4.000 3.800 7.800	150 0.0115	19.583 0.0 0.090		Vel = 2.21	
H.15 to H.17	109 109		0.0 4.03	1 0.863	Vprt	3.8	20.000 3.800 23.800	150 0.0115	19.673 0.0 0.274		Vel = 2.21	
H.17 to H.18	109 109		0.0 4.03	1 0.863			8.000 8.000	150 0.0115	19.947 0.0 0.092		Vel = 2.21	
H.18 to T.29	109 109		0.0 4.03	1 0.863	Vprt	3.8	13.000 3.800 16.800	150 0.0115	20.039 0.0 0.193		Vel = 2.21	
T.29 to H.16	109 109		-2.69 1.34	1 0.863	Vptb	18.4	3.000 18.400 21.400	150 0.0015	20.232 0.0 0.032		Vel = 0.73	
H.16 to H.14	109 109		0.0 1.34	1 0.863	Vprt	3.8	6.000 3.800 9.800	150 0.0015	20.264 0.0 0.015		Vel = 0.73	
H.14 to T.25	109 109		0.0 1.34	1 0.863	Vprt	3.8	2.000 3.800 5.800	150 0.0016	20.279 0.0 0.009		Vel = 0.73	
T.25			0.0 1.34						20.288		K Factor = 0.30	
T.29 to T.30	109 109		2.70 2.7	1 0.863			3.000 3.000	150 0.0057	20.232 0.0 0.017		Vel = 1.48	
T.30 to T.33	109 118		0.0 2.7	1 0.863	2Vpel	35.4	11.000 35.400 46.400	150 0.0055	20.249 -3.898 0.254		Vel = 1.48	
T.33 to H.20	118 118		0.0 2.7	1 0.863	Vprt	3.8	2.000 3.800 5.800	150 0.0055	16.605 0.0 0.032		Vel = 1.48	
H.20 to H.23	118 118		0.0 2.7	1 0.863	Vprt	3.8	23.000 3.800 26.800	150 0.0055	16.637 0.0 0.147		Vel = 1.48	

Final Calculations : Hazen-Williams

Viega LLC
182 OAKHAVEN DRIVE - One Head Calculation (H.1)

Page 7
Date 2/22/2021

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
H.23 to H.22	118 118		0.0 2.7	1 0.863			9.000 9.000	150 0.0054	16.784 0.0 0.049		Vel = 1.48	
H.22 to H.21	118 118		0.0 2.7	1 0.863	Vprt	3.8	7.000 3.800 10.800	150 0.0055	16.833 0.0 0.059		Vel = 1.48	
H.21 to H.19	118 118		0.0 2.7	1 0.863	Vprt	3.8	6.000 3.800 9.800	150 0.0055	16.892 0.0 0.054		Vel = 1.48	
H.19 to T.32	118 118		0.0 2.7	1 0.863	Vprt	3.8	1.000 3.800 4.800	150 0.0054	16.946 0.0 0.026		Vel = 1.48	
T.32 to T.31	118 109		0.0 2.7	1 0.863	2Vpel	35.4	11.000 35.400 46.400	150 0.0055	16.972 3.898 0.254		Vel = 1.48	
T.31 to T.28	109 109		0.0 2.7	1 0.863			5.000 5.000	150 0.0054	21.124 0.0 0.027		Vel = 1.48	
T.28 to T.26	109 109		0.0 2.7	1 0.863	Vprt	3.8	8.000 3.800 11.800	150 0.0055	21.151 0.0 0.065		Vel = 1.48	
T.26			0.0 2.70						21.216		K Factor = 0.59	

viega

Viega LLC
Technical Services Department
1900 Southwood Drive
Nashua, NH 03063
603-882-7171

Job Name : 182 OAKHAVEN DRIVE - Two Head Calculation (H.23 & H.22)
Building : SINGLE FAMILY RESIDENCE
Location : HOLLY SPRINGS NC 27540
System : NFPA 13D
Contract : FPNM2102-006 NC
Data File : FPNM2102-006 NC (182 Oakhaven Drive).wx2

HYDRAULIC DESIGN INFORMATION SHEET

Name - 182 OAKHAVEN DRIVE Date - 02/10/2021
 Location -
 Building - SINGLE FAMILY RESIDENCE System No. - NFPA 13D
 Contractor - CUMBERLAND HOMES INC. Contract No. - FPNM2102-006 NC
 Calculated By - VIEGA LLC Drawing No. - FPNM2102-006 NC
 Construction: (X) Combustible () Non-Combustible Ceiling Height 9
 OCCUPANCY - RESIDENTIAL

S Type of Calculation: ()NFPA 13 Residential ()NFPA 13R (X)NFPA 13D
 Y Number of Sprinklers Flowing: ()1 (X)2 ()4 ()
 S ()Other
 T ()Specific Ruling Made by Date

E
 M Listed Flow at Start Point - 13 Gpm System Type
 Listed Pres. at Start Point - 7.04 Psi (X) Wet () Dry
 D MAXIMUM LISTED SPACING 16 x 16 () Deluge () PreAction
 E Domestic Flow Added - 0 Gpm Sprinkler or Nozzle
 S Additional Flow Added - Gpm Make RELIABLE Model RFC49
 I Elevation at Highest Outlet - 118 Feet Size 7/16 K-Factor 4.9
 G Note: Temperature Rating 155
 N

Calculation Gpm Required 26.0075 Psi Required 49.37 At Ref Pt STR
 Summary C-Factor Used: Overhead 150 Underground 150

W Water Flow Test: Pump Data: Tank or Reservoir:
 A Date of Test - x Rated Cap. Cap.
 T Time of Test - x @ Psi Elev.
 E Static (Psi) - 71 Elev.
 R Residual (Psi) - 20 Other Well
 Flow (Gpm) - 168 Proof Flow Gpm
 S Elevation - 100

P Location: x
 P
 L Source of Information: x
 Y

Water Supply Curve

Viega LLC
182 OAKHAVEN DRIVE - Two Head Calculation (H.23 & H.22)


Page 2
Date 2/22/2021

City Water Supply:

C1 - Static Pressure : 71
C2 - Residual Pressure: 20
C2 - Residual Flow : 168

Demand:

D1 - Elevation : 7.796
D2 - System Flow : 26.008
D2 - System Pressure : 49.365
Hose (Demand) : _____
D3 - System Demand : 26.008
Safety Margin : 20.018



Fittings Used Summary

Viega LLC
182 OAKHAVEN DRIVE - Two Head Calculation (H.23 & H.22)

Page 3
Date 2/22/2021

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	Generic Gate Valve	1	1	1	1	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Vpel *	PEX Press 90 Elbow - Poly	12.6	18.9	17.7	18.6	29.4	36.4	0	0	0											
Vprt *	PEX Press Tee - Run-Poly	3.9	3.6	3.8	6.4	7.9	10.2	0	0	0											
Vptb *	PEX Press Tee - Branch-Poly	14	19.1	18.4	18.7	28.3	37.5	0	0	0											

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Flow Summary - NFPA

Viega LLC
 182 OAKHAVEN DRIVE - Two Head Calculation (H.23 & H.22)

Page 4
 Date 2/22/2021

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
STR	71.0	20	168.0	69.383	26.01	49.365

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>		<i>Notes</i>
H.23	118.0	4.9	7.04	13.0	0.05	256
H.20	118.0		9.42			
T.33	118.0		9.94			
T.30	109.0		17.96			
T.29	109.0		18.23			
H.16	109.0		18.87			
H.14	109.0		19.16			
T.25	109.0		19.33			
H.6	109.0		19.84			
H.7	109.0		20.13			
T.26	109.0		20.93			
T.27	109.0		22.25			
H.13	109.0		24.35			
S.1	98.0		35.53			
MTR	100.0		44.87			
STR	100.0		49.36			
H.22	118.0	4.9	7.05	13.01	0.05	256
H.21	118.0		8.26			
H.19	118.0		9.37			
T.32	118.0		9.91			
T.31	109.0		19.04			
T.28	109.0		19.6			
H.18	109.0		18.56			
H.17	109.0		18.72			
H.15	109.0		19.19			
T.24	109.0		19.34			
H.9	109.0		19.47			
H.5	109.0		19.67			
H.2	109.0		20.13			
H.3	109.0		20.44			
H.4	109.0		20.69			
H.1	109.0		21.13			
H.8	109.0		21.75			
H.12	109.0		19.34			
H.11	109.0		19.34			
H.10	109.0		19.34			

Final Calculations : Hazen-Williams

Viega LLC
182 OAKHAVEN DRIVE - Two Head Calculation (H.23 & H.22)

Page 5
Date 2/22/2021

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
H.23 to H.20	118 118	4.90	12.17	1	Vprt	3.8	23.000 3.800	150	7.040 0.0			
			12.17	0.863			26.800	0.0889	2.382	Vel =	6.68	
H.20 to T.33	118 118		0.0	1	Vprt	3.8	2.000 3.800	150	9.422 0.0			
			12.17	0.863			5.800	0.0888	0.515	Vel =	6.68	
T.33 to T.30	118 109		0.0	1	2Vpel	35.4	11.000 35.400	150	9.937 3.898			
			12.17	0.863			46.400	0.0889	4.123	Vel =	6.68	
T.30 to T.29	109 109		0.0	1			3.000	150	17.958 0.0			
			12.17	0.863			3.000	0.0890	0.267	Vel =	6.68	
T.29 to H.16	109 109		-5.41	1	Vptb	18.4	3.000 18.400	150	18.225 0.0			
			6.76	0.863			21.400	0.0300	0.641	Vel =	3.71	
H.16 to H.14	109 109		0.0	1	Vprt	3.8	6.000 3.800	150	18.866 0.0			
			6.76	0.863			9.800	0.0299	0.293	Vel =	3.71	
H.14 to T.25	109 109		0.0	1	Vprt	3.8	2.000 3.800	150	19.159 0.0			
			6.76	0.863			5.800	0.0300	0.174	Vel =	3.71	
T.25 to H.6	109 109		-0.36	1	Vprt	3.8	15.000 3.800	150	19.333 0.0			
			6.4	0.863			18.800	0.0271	0.509	Vel =	3.51	
H.6 to H.7	109 109		0.0	1	Vprt	3.8	7.000 3.800	150	19.842 0.0			
			6.4	0.863			10.800	0.0270	0.292	Vel =	3.51	
H.7 to T.26	109 109		0.0	1	Vptb	18.4	11.000 18.400	150	20.134 0.0			
			6.4	0.863			29.400	0.0271	0.796	Vel =	3.51	
T.26 to T.27	109 109		13.84	1	Vprt	3.8	2.000 3.800	150	20.930 0.0			
			20.24	0.863			5.800	0.2278	1.321	Vel =	11.10	
T.27 to H.13	109 109		5.77	1	Vprt	3.8	2.000 3.800	150	22.251 0.0			
			26.01	0.863			5.800	0.3622	2.101	Vel =	14.27	
H.13 to S.1	109 98		0.0	1	Vprt T	3.8 2.92	11.000 6.720	150	24.352 4.764			
			26.01	0.863			17.720	0.3622	6.418	Vel =	14.27	
S.1 to MTR	98 100		0.0	1.25	2E	2.429	50.000 2.429	150	35.534 2.134		** Fixed Loss = 3	
			26.01	1.053			52.429	0.1374	7.205	Vel =	9.58	
MTR to STR	100 100		0.0	1	E T	3.022 7.555	20.000 12.089	150	44.873 0.0			
			26.01	1.049	G	1.511	32.089	0.1400	4.492	Vel =	9.66	
STR			0.0 26.01						49.365	K Factor =	3.70	
H.23 to H.22	118 118		0.83	1			9.000	150	7.040 0.0			
			0.83	0.863			9.000	0.0007	0.006	Vel =	0.46	

Final Calculations : Hazen-Williams

Viega LLC
182 OAKHAVEN DRIVE - Two Head Calculation (H.23 & H.22)

Page 6
Date 2/22/2021

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
H.22 to H.21	118 118	4.90	13.01 13.84	1 0.863	Vprt	3.8	7.000 3.800 10.800	150 0.1127	7.046 0.0 1.217		Vel = 7.59	
H.21 to H.19	118 118		0.0 13.84	1 0.863	Vprt	3.8	6.000 3.800 9.800	150 0.1128	8.263 0.0 1.105		Vel = 7.59	
H.19 to T.32	118 118		0.0 13.84	1 0.863	Vprt	3.8	1.000 3.800 4.800	150 0.1127	9.368 0.0 0.541		Vel = 7.59	
T.32 to T.31	118 109		0.0 13.84	1 0.863	2Vpel	35.4	11.000 35.400 46.400	150 0.1127	9.909 3.898 5.230		Vel = 7.59	
T.31 to T.28	109 109		0.0 13.84	1 0.863			5.000 5.000	150 0.1126	19.037 0.0 0.563		Vel = 7.59	
T.28 to T.26	109 109		0.0 13.84	1 0.863	Vprt	3.8	8.000 3.800 11.800	150 0.1127	19.600 0.0 1.330		Vel = 7.59	
T.26			0.0 13.84						20.930		K Factor = 3.03	
T.29 to H.18	109 109		5.41 5.41	1 0.863	Vprt	3.8	13.000 3.800 16.800	150 0.0198	18.225 0.0 0.333		Vel = 2.97	
H.18 to H.17	109 109		0.0 5.41	1 0.863			8.000 8.000	150 0.0199	18.558 0.0 0.159		Vel = 2.97	
H.17 to H.15	109 109		0.0 5.41	1 0.863	Vprt	3.8	20.000 3.800 23.800	150 0.0198	18.717 0.0 0.472		Vel = 2.97	
H.15 to T.24	109 109		0.0 5.41	1 0.863	Vprt	3.8	4.000 3.800 7.800	150 0.0199	19.189 0.0 0.155		Vel = 2.97	
T.24 to H.9	109 109		0.36 5.77	1 0.863	Vprt	3.8	2.000 3.800 5.800	150 0.0222	19.344 0.0 0.129		Vel = 3.16	
H.9 to H.5	109 109		0.0 5.77	1 0.863	Vprt	3.8	5.000 3.800 8.800	150 0.0224	19.473 0.0 0.197		Vel = 3.16	
H.5 to H.2	109 109		0.0 5.77	1 0.863	Vprt	3.8	17.000 3.800 20.800	150 0.0223	19.670 0.0 0.464		Vel = 3.16	
H.2 to H.3	109 109		0.0 5.77	1 0.863	Vprt	3.8	10.000 3.800 13.800	150 0.0223	20.134 0.0 0.308		Vel = 3.16	
H.3 to H.4	109 109		0.0 5.77	1 0.863			11.000 11.000	150 0.0224	20.442 0.0 0.246		Vel = 3.16	
H.4 to H.1	109 109		0.0 5.77	1 0.863	Vprt	3.8	16.000 3.800 19.800	150 0.0223	20.688 0.0 0.442		Vel = 3.16	

Final Calculations : Hazen-Williams

Viega LLC
 182 OAKHAVEN DRIVE - Two Head Calculation (H.23 & H.22)

Page 7
 Date 2/22/2021

Node1 to Node2	Elev1 Elev2	K Fact	Qa Qt	Nom Act	Fitting or Eqiv	Len	Pipe Ftngs Total	CFact Pf/Ft	Pt Pe Pf	*****	Notes	*****
H.1 to H.8	109 109		0.0 5.77	1 0.863	Vprt	3.8	24.000 3.800 27.800	150 0.0223	21.130 0.0 0.621		Vel = 3.16	
H.8 to T.27	109 109		0.0 5.77	1 0.863	Vptb	18.4	4.000 18.400 22.400	150 0.0223	21.751 0.0 0.500		Vel = 3.16	
T.27			0.0 5.77						22.251		K Factor = 1.22	
T.25 to H.12	109 109		0.36 0.36	1 0.863	Vptb	18.4	11.000 18.400 29.400	150 0.0001	19.333 0.0 0.004		Vel = 0.20	
H.12 to H.11	109 109		0.0 0.36	1 0.863	Vprt	3.8	10.000 3.800 13.800	150 0.0001	19.337 0.0 0.001		Vel = 0.20	
H.11 to H.10	109 109		0.0 0.36	1 0.863	Vprt	3.8	6.000 3.800 9.800	150 0.0002	19.338 0.0 0.002		Vel = 0.20	
H.10 to T.24	109 109		0.0 0.36	1 0.863	Vptb Vprt	18.4 3.8	7.000 22.200 29.200	150 0.0001	19.340 0.0 0.004		Vel = 0.20	
T.24			0.0 0.36						19.344		K Factor = 0.08	