



VIEGA LLC'S DESIGN SERVICES DEPARTMENT HAS PREPARED THIS SERIES OF DRAWINGS AS THE FIRST DESIGN FOR PLUMBING, RADIANT, SNOW MELTING OR FIRE SUPPRESSION SYSTEMS FOR THE USE OF YOU, OUR CUSTOMER, IN PREPARING / OBTAINING SPECIFICATIONS, BIDS AND PROPOSALS IN RELATION TO THE SALE OF THESE SYSTEMS. THESE DRAWINGS ARE BASED UPON INFORMATION PROVIDED BY YOU AND HAVE BEEN PREPARED TO APPROPRIATE PROFESSIONAL STANDARDS OF DESIGN BASED UPON THAT INFORMATION. THESE DRAWINGS ARE NOT TO BE CONSIDERED FINAL AND, PRIOR TO PERFORMING ANY WORK ASSOCIATED WITH THESE DESIGNS OR DRAWINGS, YOU MUST:

- 1) CHECK AND CONFIRM ALL PIPE SIZES, CALCULATIONS, MATERIALS, PLUMBING AND / OR FIRE CODES USED OR APPLICABLE; AND
- 2) PRESENT THE DRAWINGS TO YOUR PROFESSIONAL ENGINEER FOR REVIEW AND APPROVAL AND HAVE THE DRAWINGS MARKED "FINAL" BY YOUR PROFESSIONAL ENGINEER.

IF YOUR PROFESSIONAL ENGINEER REPORTS ANY ERRORS IN THE DRAWINGS OR MAKES ANY CHANGES IN THE DRAWINGS, THESE ERRORS OR CHANGES MUST BE COMMUNICATED TO VIEGA LLC'S DESIGN SERVICES DEPARTMENT FOR A DETERMINATION IF A REVISION TO THE DESIGN IS NECESSARY.

VIEGA LLC DISCLAIMS ANY WARRANTIES, EXPRESS OR IMPLIED, ASSOCIATED WITH THE DESIGN OF THE SYSTEM OR ITS USE. ALL DESIGNS ARE PROVIDED "AS IS" AND IT IS YOUR SOLE RESPONSIBILITY TO CONFIRM AND ENSURE THAT THE SYSTEM TO BE INSTALLED WILL OPERATE AND FUNCTION IN COMPLIANCE WITH ALL APPLICABLE CODES AND IN ACCORDANCE WITH ALL APPLICABLE SPECIFICATIONS.

Design Services Department
1900 Southwood Drive - Nashua, NH 03063
Tel: 877-843-4262 x 351 Fax: 316-425-8466

Project: **LOT#10**
332 OAKHAVEN DRIVE
HOLLY SPRINGS, NC 27540

Dwg no.: **FP 1 OF 3**

Title: **1ST FLOOR PLAN**

Quotation no.: **FPMS2102-001 NC**

Drawn by: **M.S.**

Approved by:

Date Submitted: **02/26/2021**

Scale: **1/4" = 1'**

Revision No: **Revision Date:**


Most Demanding Single Head Information	Results
Flow Required at Head (GPM):	20
Source Pressure at Head (PSI):	16.7
Maximum Spacing (length):	20
Maximum Spacing (Width):	20
Domestic Flow Added (GPM):	0
Sprinkler Model:	RFC49
Elevation of Highest Head:	120
K-Factor	4.9
Temperature Rating:	155
Flow Required at Source (GPM)	20
Pressure Required at Source (psi)	47.66
Source Reference Point:	At Ref Pt STR
C-Factor of Sprinkler Pipe	150
C-Factor of Service Line	150
Head Reference Point:	H.8

Most Demanding Two Head Information	Results
Flow Required at Head (GPM):	13
Source Pressure at Head (PSI):	7.04
Maximum Spacing (length):	16
Maximum Spacing (Width):	16
Domestic Flow Added (GPM):	0
Sprinkler Model:	RFC49
Elevation of Highest Head:	120
K-Factor	4.9
Temperature Rating:	155
Flow Required at Source (GPM)	26.0331
Pressure Required at Source (psi)	51.5
Source Reference Point:	At Ref Pt STR
C-Factor of Sprinkler Pipe	150
C-Factor of Service Line	150
Head Reference Point:	H.10 & H.4


SPRINKLER DESCRIPTIONS

- 18
RFC49-16 RELIABLE Model RFC49 Concealed Pendent Spr FP
 K=4.9, 155F°, 7/16" Orifice, Maximum Spacing 16"x16"
 Sprinkler head demand: 13 gpm @ 7.04
- 2
RFC49-18 RELIABLE Model RFC49 Concealed Pendent Spr FP
 K=4.9, 155F°, 7/16" Orifice, Maximum Spacing 18"x18"
 Sprinkler head demand: 17 gpm @ 12.03
- 1
RFC49-20 RELIABLE Model RFC49 Concealed Pendent Spr FP
 K=4.9, 155F°, 7/16" Orifice, Maximum Spacing 20"x20"
 Sprinkler head demand: 20 gpm @ 16.7

LEGEND	
	Manifold
	Inter Level Connection
	Hot Water Fixture
	Cold Water Fixture
	Type K Copper w/ ProPress Fittings
	Type L Copper w/ ProPress Fittings
	Type M Copper w/ ProPress Fittings
	ViegaPEX Ultra Black
	ViegaPEX Ultra Blue - Cold Plumbing
	ViegaPEX Ultra Red - Hot Plumbing



1st Floor 8 Sprinklers



FLOW AT SOURCE: 1 GPM
 SUPPLY STATIC PRESSURE: 60 PSI
 RESIDUAL PRESSURE: 20 PSI
 SUPPLY ELEVATION: 0'

WATER SERVICE DETAIL




VEIGA LLC'S DESIGN SERVICES DEPARTMENT HAS PREPARED THIS SERIES OF DRAWINGS AS THE FIRST DESIGN FOR PLUMBING, RADIANT, SNOW MELTING OR FIRE SUPPRESSION SYSTEMS FOR THE USE OF YOU, OUR CUSTOMER, IN PREPARING / OBTAINING SPECIFICATIONS, BIDS AND PROPOSALS IN RELATION TO THE SALE OF THESE SYSTEMS. THESE DRAWINGS ARE BASED UPON INFORMATION PROVIDED BY YOU AND HAVE BEEN PREPARED TO APPROPRIATE PROFESSIONAL STANDARDS OF DESIGN BASED UP THAT INFORMATION. THESE DRAWINGS ARE NOT TO BE CONSIDERED FINAL AND, PRIOR TO PERFORMING ANY WORK ASSOCIATED WITH THESE DESIGNS OR DRAWINGS, YOU MUST:

- 1) CHECK AND CONFIRM ALL PIPE SIZES, CALCULATIONS, MATERIALS, PLUMBING AND / OR FIRE CODES USED OR APPLICABLE; AND
- 2) PRESENT THE DRAWINGS TO YOUR PROFESSIONAL ENGINEER FOR REVIEW AND APPROVAL AND HAVE THE DRAWINGS MARKED "FINAL" BY YOUR PROFESSIONAL ENGINEER.

IF YOUR PROFESSIONAL ENGINEER REPORTS ANY ERRORS IN THE DRAWINGS OR MAKES ANY CHANGES IN THE DRAWINGS, THESE ERRORS OR CHANGES MUST BE COMMUNICATED TO VEIGA LLC'S DESIGN SERVICES DEPARTMENT FOR A DETERMINATION IF A REVISION TO THE DESIGN IS NECESSARY.

VEIGA LLC DISCLAIMS ANY WARRANTIES, EXPRESS OR IMPLIED, ASSOCIATED WITH THE DESIGN OF THE SYSTEM OR ITS USE. ALL DESIGNS ARE PROVIDED "AS IS" AND IT IS YOUR SOLE RESPONSIBILITY TO CONFIRM AND ENSURE THAT THE SYSTEM TO BE INSTALLED WILL OPERATE AND FUNCTION IN COMPLIANCE WITH ALL APPLICABLE CODES AND IN ACCORDANCE WITH ALL APPLICABLE SPECIFICATIONS.

Design Services Department
1900 Southwood Drive - Nashua, NH 03063
Tel: 877-843-4262 x 351 Fax: 316-425-8466



Project:

LOT#10
332 OAKHAVEN DRIVE
HOLLY SPRINGS, NC 27540

Dwg no.:

FP 1 OF 3

Title:

1ST FLOOR PLAN

Quotation no.: FPMS2102-001 NC

Drawn by: M.S.

Apprv. by:

Date Submitted: 02/26/2021

Scale: 1/4" = 1'

Revision No: Revision Date:

FIRE PROTECTION INSTALLATION NOTES:

1. INSTALLATION OF THE FIRE PROTECTION SYSTEM SHALL BE INSTALLED IN ACCORDANCE WITH THE 2016 EDITION OF NFPA 13D OR SECTION P2904 OF THE 2018 INTERNATIONAL RESIDENTIAL CODE (IRC). NFPA 13D IS THE STANDARD FOR THE INSTALLATION OF SPRINKLER SYSTEMS IN ONE- AND TWO-FAMILY DWELLINGS AND MANUFACTURED HOMES.
2. INSTALLATION OF THE FIRE PROTECTION SYSTEM SHALL COMPLY WITH ALL LOCAL RESIDENTIAL FIRE PROTECTION CODES AND ALL APPLICABLE STATE REGULATIONS.
3. SPRINKLER HEADS SHALL MEET ALL GENERAL CARE AND INSTALLATION REQUIREMENTS OF THE SPRINKLER MANUFACTURER. SUBSTITUTION OF SPRINKLER HEADS IS NOT PERMITTED.
4. AFTER INSTALLATION OF THE SPRINKLERS, THE ENTIRE SYSTEM SHALL BE PRESSURE TESTED IN ACCORDANCE WITH STATE AND LOCAL CODE REQUIREMENTS. SPRINKLERS SHALL BE LOCATED PER THE LAYOUT. DO NOT INSTALL SPRINKLERS IN AREAS EXPOSED TO TEMPERATURES THAT EXCEED THE MAXIMUM RECOMMENDED AMBIENT TEMPERATURE FOR THE TEMPERATURE RATING USED. MINIMUM DISTANCE OF SPRINKLER HEADS FROM HEAT SOURCES SHALL COMPLY WITH TABLE 7.5.6.3 IN THE 2016 EDITION OF NFPA 13D, INSTALLATION OF SPRINKLER SYSTEMS IN ONE - AND TWO - FAMILY DWELLINGS AND MANUFACTURED HOMES.
5. NO DEVIATIONS FROM THE PLAN SHALL BE ALLOWED WITHOUT APPROVAL FROM THE AUTHORITY HAVING JURISDICTION AND DESIGNER.
6. PIPING AND SPRINKLER FITTINGS SHALL BE SUPPORTED IN COMPLIANCE WITH LOCAL PLUMBING CODE AND THE 2016 EDITION OF NFPA 13D, INSTALLATION OF SPRINKLER SYSTEMS IN ONE - AND TWO - FAMILY DWELLINGS AND MANUFACTURED HOMES.
7. SMOKE DETECTORS SHALL BE INSTALLED IN ACCORDANCE WITH NFPA 72, NATIONAL FIRE ALARM CODE. WHEN NOT EQUIPPED WITH SMOKE DETECTORS, LOCAL WATERFLOW ALARMS SHALL BE REQUIRED.
8. WATER SOFTENERS AND WATER FILTRATION DEVICES SHALL NOT BE INSTALLED IN THE SYSTEM WITHOUT A REVIEW OF THE HYDRAULIC CALCULATIONS OF THE SYSTEM.
9. A SIGN SHALL BE AFFIXED ADJACENT TO THE MAIN SHUTOFF VALVE THAT STATES IN MINIMUM 1/4" LETTERS, "WARNING: THE WATER SYSTEM FOR THIS HOME SUPPLIES FIRE SPRINKLERS THAT REQUIRE CERTAIN FLOWS AND PRESSURES TO FIGHT A FIRE. DEVICES THAT RESTRICT THE FLOW OR DECREASE THE PRESSURE OR AUTOMATICALLY SHUT OFF THE WATER TO THE FIRE SPRINKLER SYSTEM, SUCH AS WATER SOFTENERS, FILTRATION SYSTEMS, AND AUTOMATIC SHUT-OFF VALVES, SHALL NOT BE ADDED TO THIS SYSTEM WITHOUT A REVIEW OF THE FIRE SPRINKLER SYSTEM BY A FIRE PROTECTION SPECIALIST. DO NOT REMOVE THIS SIGN."
10. ALL PIPING AND FITTINGS SHALL BE PROPERLY INSULATED AND PROTECTED SO THAT THEY ARE NOT EXPOSED TO TEMPERATURES BELOW 40° F.
11. WHEN THE MAXIMUM STATIC PRESSURE EXCEEDS 80 PSI, A PRESSURE-REDUCING VALVE SHALL BE INSTALLED. NFPA 13D RESTRICTS THE OPERATING PRESSURE OF PEX SYSTEMS TO 80 PSI. PRESSURE DROP THROUGH THE PRESSURE-REDUCING DEVICE SHALL BE INCLUDED IN THE HYDRAULIC CALCULATIONS.
12. WHEN A FIRE DEPARTMENT CONNECTION IS REQUIRED, PEX TUBING SHALL NOT BE PERMITTED. CONSULT WITH THE AUTHORITY HAVING JURISDICTION (AHJ) ABOUT THIS REQUIREMENT PRIOR TO INSTALLATION.

PLUMBING INSTALLATION NOTES:

1. INSTALLATION OF HOT AND COLD WATER DISTRIBUTION SYSTEMS SHALL BE IN ACCORDANCE WITH THE LOCAL PLUMBING CODE.
2. WATER SOFTENERS AND WATER FILTRATION DEVICES SHALL NOT BE INSTALLED WITHOUT A REVIEW OF THE HYDRAULIC CALCULATIONS OF THE SYSTEM.
3. FINAL APPROVAL OF MULTIPURPOSE AND PASSIVE PURGE FIRE SPRINKLER INSTALLATIONS SHALL BE FROM THE AUTHORITY HAVING JURISDICTION.

TESTING:

1. EVERY VIEGA NFPA 13D FIRE PROTECTION INSTALLATION SHALL BE PRESSURE TESTED IN ACCORDANCE WITH NFPA 13D, WHICH STATES THAT SYSTEMS WITHOUT FIRE DEPARTMENT CONNECTIONS SHALL BE TESTED FOR LEAKAGE AT THE NORMAL SYSTEM OPERATING WATER PRESSURE.
2. THE AUTHORITY HAVING JURISDICTION (AHJ) MAY REQUIRE A FLOW VERIFICATION TEST OF THE MOST HYDRAULICALLY REMOTE SPRINKLER HEAD(S). THIS FLOW VERIFICATION TEST IS AVAILABLE TO ENSURE THE INSTALLED FIRE PROTECTION SYSTEM OPERATES AS DESIGNED. DOCUMENTATION ON HOW TO PERFORM A FLOW VERIFICATION TEST IS AVAILABLE THROUGH VIEGA TECHNICAL SERVICES.
3. THE FLOW VERIFICATION TEST SHALL BE PERFORMED AFTER ALL PIPING, FITTINGS, SPRINKLER HEADS AND PLUMBING CONNECTIONS HAVE BEEN INSTALLED AND PRESSURE TESTING OF THE SYSTEM HAS BEEN COMPLETED. THE FLOW TEST SHOULD OCCUR WHILE IN THE "ROUGH" STAGE OF CONSTRUCTION. FLOW TEST RESULTS SHOULD BE COMPARED TO THE SYSTEM DESIGN VALUES. RESIDUAL PRESSURE (PSI) AND FLOW (GPM) MUST BE EQUAL TO OR GREATER THEN THE DESIGN VALUES TO ENSURE A PROPERLY FUNCTIONING SYSTEM.

DRAWING AND DESIGN NOTES:

1. DESIGN SHALL ENSURE WATER SUPPLY TO THE MOST HYDRAULICALLY DEMANDING SINGLE AND DUAL SPRINKLER HEADS.
2. TUBING AND FITTINGS SHALL BE U.L. LISTED FOR RESIDENTIAL FIRE PROTECTION SYSTEMS IN ACCORDANCE WITH NFPA 13D.
3. VIEGAFEX ULTRA (BLACK IN COLOR) LISTED TO U.L. 1821 FOR RESIDENTIAL WET-PIPE FIRE PROTECTION SYSTEMS IN ACCORDANCE WITH NFPA 13D.
4. VIEGA PEX PRESS FITTINGS (POLYMER AND BRONZE) LISTED TO U.L. 1821 FOR RESIDENTIAL WET-PIPE FIRE PROTECTION SYSTEMS IN ACCORDANCE WITH NFPA 13D.
5. APPROVED SMOKE DETECTION SYSTEMS AND/OR WATER FLOW ALARMS SHALL BE INSTALLED WHERE REQUIRED BY THE AUTHORITY HAVING JURISDICTION (AHJ).

MATERIALS LIST NOTES:

1. SERVICE ENTRANCE MATERIALS FROM WATER MAIN CONNECTION TO DISTRIBUTION MANIFOLD ARE EXCLUDED.
2. SPRINKLERS AND ASSOCIATED ESCUTCHEONS OR COVER PLATES ARE NOT SUPPLIED BY VIEGA.
3. MATERIAL LIST IS SUGGESTED ONLY. CONTRACTOR SHALL CONFIRM REQUIRED MATERIALS PRIOR TO PLACEMENT OF ORDER.




FIGURE A.9.1.1(a) Insulation Recommendations — Arrangement 1.




FIGURE A.9.1.1(b) Insulation Recommendations — Arrangement 2.




FIGURE A.9.1.1(c) Insulation Recommendations — Arrangement 3.




FIGURE A.9.1.1(d) Insulation Recommendations — Arrangement 4.




FIGURE A.9.1.1(e) Insulation Recommendations — Arrangement 5.

INSULATION DETAILS - ANNEX A.9.1.1 (NFPA 13D 2016)





WATER METER PRESSURE LOSSES (PSI) - TABLE 10.4.4(A) NFPA 13D (2016)						
Meter Size (in.)	Flow (gpm)					
	18 or less	23	26	31	39	52
5/8"	9	14	18	26	38	*
3/4"	7	11	14	22	35	*
1"	2	3	3	4	6	10
1-1/2"	1	1	2	2	4	7
2"	1	1	1	1	2	3

TABLE 10.4.4(a) (NFPA 13D 2016)

DISTANCES FROM HEAT SOURCES - TABLE 7.5.6.3 NFPA 13D (2016)		
Heat Source	Ordinary Temp. 135°-170°	Intermediate Temp. 175°-220°
Side of Fireplace	36"	12"
Front of Fireplace	60"	36"
Coal or Wood Burning Stove	42"	12"
Kitchen Range	18"	9"
Wall Oven	18"	9"
Hot Air Flues	18"	9"
Uninsulated Heat Ducts	18"	9"
Uninsulated Hot Water Pipes	12"	6"
Side of Hot Air Diffusers	24"	12"
Front of Hot Air Diffusers	36"	18"
Hot Water Heater or Furnace	6"	3"
Light Fixture 0 W - 250 W	6"	3"
Light Fixture 250 W - 499 W	12"	6"

TABLE 7.5.6.3 (NFPA 13D 2016)

INSTALLATION NOTES



INSTALLATION DETAIL - SPRINKLER BRACKETS

VIEGA LLC'S DESIGN SERVICES DEPARTMENT HAS PREPARED THIS SERIES OF DRAWINGS AS THE FIRST DESIGN FOR PLUMBING, RADIANT, SNOW MELTING OR FIRE SUPPRESSION SYSTEMS FOR THE USE OF YOU, OUR CUSTOMER, IN PREPARING / OBTAINING SPECIFICATIONS, BIDS AND PROPOSALS IN RELATION TO THE SALE OF THESE SYSTEMS. THESE DRAWINGS ARE BASED UPON INFORMATION PROVIDED BY YOU AND HAVE BEEN PREPARED TO APPROPRIATE PROFESSIONAL STANDARDS OF DESIGN BASED UPON THAT INFORMATION. THESE DRAWINGS ARE NOT TO BE CONSIDERED FINAL AND, PRIOR TO PERFORMING ANY WORK ASSOCIATED WITH THESE DESIGNS OR DRAWINGS, YOU MUST:

- 1.) CHECK AND CONFIRM ALL PIPE SIZES, CALCULATIONS, MATERIALS, PLUMBING AND / OR FIRE CODES USED OR APPLICABLE; AND
- 2.) PRESENT THE DRAWINGS TO YOUR PROFESSIONAL ENGINEER FOR REVIEW AND APPROVAL AND HAVE THE DRAWINGS MARKED "FINAL" BY YOUR PROFESSIONAL ENGINEER.

IF YOUR PROFESSIONAL ENGINEER REPORTS ANY ERRORS IN THE DRAWINGS OR MAKES ANY CHANGES IN THE DRAWINGS, THESE ERRORS OR CHANGES MUST BE COMMUNICATED TO VIEGA LLC'S DESIGN SERVICES DEPARTMENT FOR A DETERMINATION IF A REVISION TO THE DESIGN IS NECESSARY.

VIEGA LLC DISCLAIMS ANY WARRANTIES, EXPRESS OR IMPLIED, ASSOCIATED WITH THE DESIGN OF THE SYSTEM OR ITS USE. ALL DESIGNS ARE PROVIDED "AS IS" AND IT IS YOUR SOLE RESPONSIBILITY TO CONFIRM AND ENSURE THAT THE SYSTEM TO BE INSTALLED WILL OPERATE AND FUNCTION IN COMPLIANCE WITH ALL APPLICABLE CODES AND IN ACCORDANCE WITH ALL APPLICABLE SPECIFICATIONS.

Design Services Department
1900 Southwood Drive - Nashua, NH 03063
Tel: 877-843-4262 x 351 Fax: 316-425-8466

Project:

LOT#10

332 OAKHAVEN DRIVE
HOLLY SPRINGS, NC 27540

Dwg no.:

FP 3 OF 3

Title:

NOTES & DETAILS

Quotation no.: FPMS2102-001 NC

Drawn by: M.S.

Approved by:

Date Submitted: 02/26/2021

Scale: N/A

Revision No: Revision Date:

viega

Viega LLC
Technical Services Department
1900 Southwood Drive
Nashua, NH 03063
603-882-7171

Job Name : LOT#10 - One Head Calculation (H.8)
Building : SINGLE FAMILY RESIDENCE
Location : 332 OAKHAVEN DRIVE HOLLY SPRINGS NC 27540
System : NFPA 13D
Contract : FPMS2102-001 NC
Data File : 332 Oakhaven Drive Lot 10.wx1

HYDRAULIC DESIGN INFORMATION SHEET

Name - LOT#10 Date - 02/26/2021
Location - HOLLY SPRINGS NC 27540
Building - SINGLE FAMILY RESIDENCE System No. - NFPA 13D
Contractor - x Contract No. - FPMS2102-001 NC
Calculated By - VIEGA LLC Drawing No. - FPMS2102-001 NC
Construction: (X) Combustible () Non-Combustible Ceiling Height 10 FT
OCCUPANCY - RESIDENTIAL

S Type of Calculation: ()NFPA 13 Residential ()NFPA 13R (X)NFPA 13D
Y Number of Sprinklers Flowing: (X)1 ()2 ()4 ()
S ()Other
T ()Specific Ruling Made by Date
E
M Listed Flow at Start Point - 20 Gpm System Type
Listed Pres. at Start Point - 16.7 Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 20 x 20 () Deluge () PreAction
E Domestic Flow Added - 0 Gpm Sprinkler or Nozzle
S Additional Flow Added - Gpm Make RELIABLE Model RFC49
I Elevation at Highest Outlet - 120 Feet Size 7/16 K-Factor 4.9
G Note: Temperature Rating 155
N

Calculation Gpm Required 20 Psi Required 47.66 At Ref Pt STR
Summary C-Factor Used: Overhead 150 Underground 150

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - x Rated Cap. Cap.
T Time of Test - x @ Psi Elev.
E Static (Psi) - 60 Elev.
R Residual (Psi) - 20 Other Well
Flow (Gpm) - 168 Proof Flow Gpm
S Elevation - 100

P Location: x
P
L Source of Information: x
Y

Water Supply Curve C

Viega LLC
LOT#10 - One Head Calculation (H.8)


Page 2
Date 2/26/2021

City Water Supply:

C1 - Static Pressure : 60
C2 - Residual Pressure: 20
C2 - Residual Flow : 168

Demand:

D1 - Elevation : 8.662
D2 - System Flow : 20.024
D2 - System Pressure : 47.660
Hose (Demand) : _____
D3 - System Demand : 20.024
Safety Margin : 11.558



Fittings Used Summary

Viega LLC
 LOT#10 - One Head Calculation (H.8)

Page 3
 Date 2/26/2021

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	Generic Gate Valve	1	1	1	1	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Vpel *	PEX Press 90 Elbow - Poly	12.6	18.9	17.7	18.6	29.4	36.4	0	0	0											
Vprt *	PEX Press Tee - Run-Poly	3.9	3.6	3.8	6.4	7.9	10.2	0	0	0											
Vptb *	PEX Press Tee - Branch-Poly	14	19.1	18.4	18.7	28.3	37.5	0	0	0											

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Flow Summary - NFPA 2007

Viega LLC
 LOT#10 - One Head Calculation (H.8)

Page 4
 Date 2/26/2021

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
STR	60.0	20	168.0	59.218	20.02	47.66

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
H.8	120.0	4.9	16.7	20.02	
T.25	120.0		18.06		
T.23	120.0		20.41		
T.24	109.0		27.24		
T.22	109.0		28.59		
H.1	109.0		29.07		
T.27	109.0		31.67		
T.28	109.0		32.06		
S.1	104.0		35.72		
MTR	100.0		44.89		
STR	100.0		47.66		
T.31	120.0		17.9		
H.17	120.0		18.21		
H.19	120.0		18.55		
H.20	120.0		18.76		
T.36	120.0		19.1		
T.35	120.0		20.53		
T.34	109.0		27.15		
T.33	109.0		28.33		
T.29	109.0		28.66		
H.7	109.0		29.46		
H.6	109.0		30.31		
H.13	120.0		17.95		
H.14	120.0		18.02		
T.32	120.0		18.05		
H.9	120.0		18.1		
T.26	120.0		18.14		
H.3	120.0		18.22		
H.4	120.0		18.36		
H.10	120.0		18.49		
H.16	120.0		18.67		
H.15	120.0		18.78		
H.5	120.0		18.08		
H.21	109.0		28.39		
H.18	109.0		28.44		
T.30	109.0		28.58		
H.11	109.0		28.61		
H.12	109.0		28.58		
H.2	109.0		28.59		

Final Calculations - Hazen-Williams

Viega LLC
 LOT#10 - One Head Calculation (H.8)

Page 5
 Date 2/26/2021

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftg's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
H.8 to T.25	11.57	0.863 150.0 0.0810	Vprt	3.8 0.0	13.000 3.800	16.700 0.0			K Factor = 4.90	
T.25 to T.23	11.57	0.863 150.0 0.0632	Vptb Vpel	18.4 17.7 0.0	1.000 36.100 37.100	18.060 0.0 2.346			Vel = 6.35	
T.23 to T.24	0.0	0.863 150.0 0.0633	Vpel	17.7 0.0	15.000 17.700 32.700	20.406 4.764 2.069			Vel = 5.55	
T.24 to T.22	0.0	0.863 150.0 0.0632	Vptb	18.4 0.0	3.000 18.400 21.400	27.239 0.0 1.353			Vel = 5.55	
T.22 to H.1	0.63	0.863 150.0 0.0706	Vprt	3.8 0.0	3.000 3.800 6.800	28.592 0.0 0.480			Vel = 5.90	
H.1 to T.27	0.0	0.863 150.0 0.0706	Vprt	3.8 0.0	33.000 3.800 36.800	29.072 0.0 2.599			Vel = 5.90	
T.27 to T.28	9.27	1.025 150.0 0.0968		0.0 0.0	4.000 0.0 4.000	31.671 0.0 0.387			Vel = 7.78	
T.28 to S.1	0.0	1.025 150.0 0.0966	E T	2.7 6.75 0.0	6.000 9.450 15.450	32.058 2.166 1.492			Vel = 7.78	
S.1 to MTR	0.0	1.053 150.0 0.0847	2E	2.429 0.0	50.000 2.429 52.429	35.716 4.732 4.442			** Fixed Loss = 3 Vel = 7.38	
MTR to STR	0.0	1.049 150.0 0.0863	E T G	3.022 7.555 1.511	20.000 12.089 32.089	44.890 0.0 2.770			Vel = 7.43	
	0.0 20.02					47.660			K Factor = 2.90	
H.8 to T.31	8.45	0.863 150.0 0.0453	Vptb	18.4 0.0	8.000 18.400	16.700 0.0			Vel = 4.63	
T.31 to H.17	-2.40	0.863 150.0 0.0245	Vprt	3.8 0.0	9.000 3.800 12.800	17.895 0.0 0.313			Vel = 3.32	
H.17 to H.19	0.0	0.863 150.0 0.0244	Vprt	3.8 0.0	10.000 3.800 13.800	18.208 0.0 0.337			Vel = 3.32	
H.19 to H.20	0.0	0.863 150.0 0.0244		0.0 0.0	9.000 0.0 9.000	18.545 0.0 0.220			Vel = 3.32	
H.20 to T.36	0.0	0.863 150.0 0.0244	Vprt	3.8 0.0	10.000 3.800 13.800	18.765 0.0 0.337			Vel = 3.32	
T.36 to T.35	3.85	0.863 150.0 0.0606	Vprt Vpel	3.8 17.7 0.0	2.000 21.500 23.500	19.102 0.0 1.425			Vel = 5.43	

Final Calculations - Hazen-Williams

Viega LLC
 LOT#10 - One Head Calculation (H.8)

Page 6
 Date 2/26/2021

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftg's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
T.35 to T.34	0.0 9.9	0.863 150.0 0.0607	Vpel	17.7 0.0 0.0	13.000 17.700 30.700	20.527 4.764 1.862			Vel = 5.43	
T.34 to T.33	0.0 9.9	0.863 150.0 0.0607	Vptb	18.4 0.0 0.0	1.000 18.400 19.400	27.153 0.0 1.177			Vel = 5.43	
T.33 to T.29	-2.26 7.64	0.863 150.0 0.0375	Vprt	3.8 0.0 0.0	5.000 3.800 8.800	28.330 0.0 0.330			Vel = 4.19	
T.29 to H.7	1.64 9.28	0.863 150.0 0.0538	Vprt	3.8 0.0 0.0	11.000 3.800 14.800	28.660 0.0 0.796			Vel = 5.09	
H.7 to H.6	0.0 9.28	0.863 150.0 0.0538	Vprt	3.8 0.0 0.0	12.000 3.800 15.800	29.456 0.0 0.850			Vel = 5.09	
H.6 to T.27	0.0 9.28	0.863 150.0 0.0537	Vptb	18.4 0.0 0.0	7.000 18.400 25.400	30.306 0.0 1.365			Vel = 5.09	
	0.0 9.28					31.671			K Factor = 1.65	
T.31 to H.13	2.40 2.4	0.863 150.0 0.0044	Vprt	3.8 0.0 0.0	8.000 3.800 11.800	17.895 0.0 0.052			Vel = 1.32	
H.13 to H.14	0.0 2.4	0.863 150.0 0.0044	Vprt	3.8 0.0 0.0	12.000 3.800 15.800	17.947 0.0 0.070			Vel = 1.32	
H.14 to T.32	0.0 2.4	0.863 150.0 0.0044		0.0 0.0 0.0	8.000 0.0 8.000	18.017 0.0 0.035			Vel = 1.32	
T.32 to H.9	0.0 2.4	0.863 150.0 0.0044	Vprt	3.8 0.0 0.0	7.000 3.800 10.800	18.052 0.0 0.047			Vel = 1.32	
H.9 to T.26	0.0 2.4	0.863 150.0 0.0044	Vprt	3.8 0.0 0.0	5.000 3.800 8.800	18.099 0.0 0.039			Vel = 1.32	
T.26 to H.3	1.44 3.84	0.863 150.0 0.0105	Vprt	3.8 0.0 0.0	4.000 3.800 7.800	18.138 0.0 0.082			Vel = 2.11	
H.3 to H.4	0.0 3.84	0.863 150.0 0.0105	Vprt	3.8 0.0 0.0	9.000 3.800 12.800	18.220 0.0 0.135			Vel = 2.11	
H.4 to H.10	0.0 3.84	0.863 150.0 0.0105	Vprt	3.8 0.0 0.0	9.000 3.800 12.800	18.355 0.0 0.135			Vel = 2.11	
H.10 to H.16	0.0 3.84	0.863 150.0 0.0105	Vprt	3.8 0.0 0.0	13.000 3.800 16.800	18.490 0.0 0.177			Vel = 2.11	
H.16 to H.15	0.0 3.84	0.863 150.0 0.0105		0.0 0.0 0.0	11.000 0.0 11.000	18.667 0.0 0.116			Vel = 2.11	

Final Calculations - Hazen-Williams

Viega LLC
 LOT#10 - One Head Calculation (H.8)

Page 7
 Date 2/26/2021

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Fting's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
H.15 to T.36	0.0 3.84	0.863 150.0 0.0106	Vptb Vprt	18.4 3.8 0.0	8.000 22.200 30.200	18.783 0.0 0.319		Vel = 2.11		
	0.0 3.84					19.102		K Factor = 0.88		
T.25 to H.5	1.45 1.45	0.863 150.0 0.0018	Vprt	3.8 0.0 0.0	5.000 3.800 8.800	18.060 0.0 0.016		Vel = 0.80		
H.5 to T.26	0.0 1.45	0.863 150.0 0.0017	Vptb Vprt	18.4 3.8 0.0	14.000 22.200 36.200	18.076 0.0 0.062		Vel = 0.80		
	0.0 1.45					18.138		K Factor = 0.34		
T.33 to H.21	2.26 2.26	0.863 150.0 0.0039	Vprt	3.8 0.0 0.0	11.000 3.800 14.800	28.330 0.0 0.058		Vel = 1.24		
H.21 to H.18	0.0 2.26	0.863 150.0 0.0040		0.0 0.0 0.0	14.000 0.0 14.000	28.388 0.0 0.056		Vel = 1.24		
H.18 to T.30	0.0 2.26	0.863 150.0 0.0039	Vptb Vprt	18.4 3.8 0.0	12.000 22.200 34.200	28.444 0.0 0.135		Vel = 1.24		
T.30 to H.11	-0.62 1.64	0.863 150.0 0.0022	Vprt	3.8 0.0 0.0	11.000 3.800 14.800	28.579 0.0 0.032		Vel = 0.90		
H.11 to T.29	0.0 1.64	0.863 150.0 0.0022	Vptb	18.4 0.0 0.0	4.000 18.400 22.400	28.611 0.0 0.049		Vel = 0.90		
	0.0 1.64					28.660		K Factor = 0.31		
T.30 to H.12	0.62 0.62	0.863 150.0 0.0002		0.0 0.0 0.0	4.000 0.0 4.000	28.579 0.0 0.001		Vel = 0.34		
H.12 to H.2	0.0 0.62	0.863 150.0 0.0004	Vprt	3.8 0.0 0.0	11.000 3.800 14.800	28.580 0.0 0.006		Vel = 0.34		
H.2 to T.22	0.0 0.62	0.863 150.0 0.0004	Vprt	3.8 0.0 0.0	13.000 3.800 16.800	28.586 0.0 0.006		Vel = 0.34		
	0.0 0.62					28.592		K Factor = 0.12		

viega

Viega LLC
Technical Services Department
1900 Southwood Drive
Nashua, NH 03063
603-882-7171

Job Name : LOT#10 - Two Head Calculation (H.10 & H.4)
Building : SINGLE FAMILY RESIDENCE
Location : 332 OAKHAVEN DRIVE HOLLY SPRINGS NC 27540
System : NFPA 13D
Contract : FPMS2102-001 NC
Data File : 332 Oakhaven Drive Lot 10.wx2

HYDRAULIC DESIGN INFORMATION SHEET

Name - LOT#10 Date - 02/26/2021
 Location - HOLLY SPRINGS NC 27540
 Building - SINGLE FAMILY RESIDENCE System No. - NFPA 13D
 Contractor - x Contract No. - FPMS2102-001 NC
 Calculated By - VIEGA LLC Drawing No. - FPMS2102-001 NC
 Construction: (X) Combustible () Non-Combustible Ceiling Height 10 FT
 OCCUPANCY - RESIDENTIAL

S Type of Calculation: ()NFPA 13 Residential ()NFPA 13R (X)NFPA 13D
 Y Number of Sprinklers Flowing: ()1 (X)2 ()4 ()

S ()Other

T ()Specific Ruling Made by Date

E
 M Listed Flow at Start Point - 13 Gpm System Type
 Listed Pres. at Start Point - 7.04 Psi (X) Wet () Dry
 D MAXIMUM LISTED SPACING 16 x 16 () Deluge () PreAction
 E Domestic Flow Added - 0 Gpm Sprinkler or Nozzle
 S Additional Flow Added - Gpm Make RELIABLE Model RFC49
 I Elevation at Highest Outlet - 120 Feet Size 7/16 K-Factor 4.9
 G Note: Temperature Rating 155
 N

Calculation Gpm Required 26.0331 Psi Required 51.5 At Ref Pt STR
 Summary C-Factor Used: Overhead 150 Underground 150

W Water Flow Test: Pump Data: Tank or Reservoir:
 A Date of Test - x Rated Cap. Cap.
 T Time of Test - x @ Psi Elev.
 E Static (Psi) - 60 Elev.
 R Residual (Psi) - 20 Other Well
 Flow (Gpm) - 168 Proof Flow Gpm
 S Elevation - 100

P Location: x
 P
 L Source of Information: x
 Y

Water Supply Curve C

Viega LLC
LOT#10 - Two Head Calculation (H.10 & H.4)


Page 2
Date 2/26/2021

City Water Supply:

C1 - Static Pressure : 60
C2 - Residual Pressure: 20
C2 - Residual Flow : 168

Demand:

D1 - Elevation : 8.662
D2 - System Flow : 26.033
D2 - System Pressure : 51.497
Hose (Demand) : _____
D3 - System Demand : 26.033
Safety Margin : 7.233



Fittings Used Summary

Viega LLC
 LOT#10 - Two Head Calculation (H.10 & H.4)

Page 3
 Date 2/26/2021

Fitting Legend

Abbrev.	Name	1/2	3/4	1	1 1/4	1 1/2	2	2 1/2	3	3 1/2	4	5	6	8	10	12	14	16	18	20	24
E	90' Standard Elbow	2	2	2	3	4	5	6	7	8	10	12	14	18	22	27	35	40	45	50	61
G	Generic Gate Valve	1	1	1	1	1	1	1	1	1	2	2	3	4	5	6	7	8	10	11	13
T	90' Flow thru Tee	3	4	5	6	8	10	12	15	17	20	25	30	35	50	60	71	81	91	101	121
Vpel *	PEX Press 90 Elbow - Poly	12.6	18.9	17.7	18.6	29.4	36.4	0	0	0											
Vprt *	PEX Press Tee - Run-Poly	3.9	3.6	3.8	6.4	7.9	10.2	0	0	0											
Vptb *	PEX Press Tee - Branch-Poly	14	19.1	18.4	18.7	28.3	37.5	0	0	0											

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Flow Summary - NFPA 2007

Viega LLC
 LOT#10 - Two Head Calculation (H.10 & H.4)

Page 4
 Date 2/26/2021

SUPPLY ANALYSIS

<i>Node at Source</i>	<i>Static Pressure</i>	<i>Residual Pressure</i>	<i>Flow</i>	<i>Available Pressure</i>	<i>Total Demand</i>	<i>Required Pressure</i>
STR	60.0	20	168.0	58.73	26.03	51.497

NODE ANALYSIS

<i>Node Tag</i>	<i>Elevation</i>	<i>Node Type</i>	<i>Pressure at Node</i>	<i>Discharge at Node</i>	<i>Notes</i>
H.10	120.0	4.9	7.04	13.0	
H.16	120.0		8.32		
H.15	120.0		9.16		
T.36	120.0		11.46		
T.35	120.0		14.04		
T.34	109.0		22.17		
T.33	109.0		24.3		
T.29	109.0		24.89		
H.7	109.0		26.19		
H.6	109.0		27.59		
T.27	109.0		29.83		
T.28	109.0		30.46		
S.1	104.0		35.05		
MTR	100.0		47.0		
STR	100.0		51.5		
H.4	120.0	4.9	7.07	13.03	
H.3	120.0		8.72		
T.26	120.0		9.72		
H.5	120.0		11.33		
T.25	120.0		11.72		
T.23	120.0		15.13		
T.24	109.0		22.9		
T.22	109.0		24.86		
H.1	109.0		25.64		
H.9	120.0		9.96		
T.32	120.0		10.25		
H.14	120.0		10.47		
H.13	120.0		10.91		
T.31	120.0		11.23		
H.8	120.0		11.53		
H.17	120.0		11.29		
H.19	120.0		11.35		
H.20	120.0		11.39		
H.21	109.0		24.42		
H.18	109.0		24.53		
T.30	109.0		24.8		
H.11	109.0		24.83		
H.12	109.0		24.8		
H.2	109.0		24.83		

Final Calculations - Hazen-Williams

Viega LLC
 LOT#10 - Two Head Calculation (H.10 & H.4)

Page 5
 Date 2/26/2021

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv.	Ln.	Pipe Ftg's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
H.10 to H.16	11.20 11.2	0.863 150.0 0.0762	Vprt	3.8 0.0	13.000 3.800	7.040 0.0			K Factor = 4.90	
H.16 to H.15	0.0 11.2	0.863 150.0 0.0761		0.0 0.0	11.000 0.0	8.320 0.0			Vel = 6.14	
H.15 to T.36	0.0 11.2	0.863 150.0 0.0762	Vptb Vprt	18.4 3.8	8.000 22.200	9.157 0.0			Vel = 6.14	
T.36 to T.35	2.44 13.64	0.863 150.0 0.1098	Vprt Vpel	3.8 17.7	2.000 21.500	11.458 0.0			Vel = 7.48	
T.35 to T.34	0.0 13.64	0.863 150.0 0.1098	Vpel	17.7 0.0	13.000 17.700	14.038 4.764			Vel = 7.48	
T.34 to T.33	0.0 13.64	0.863 150.0 0.1098	Vptb	18.4 0.0	1.000 18.400	22.174 0.0			Vel = 7.48	
T.33 to T.29	-3.26 10.38	0.863 150.0 0.0662	Vprt	3.8 0.0	5.000 3.800	24.304 0.0			Vel = 5.69	
T.29 to H.7	1.74 12.12	0.863 150.0 0.0882	Vprt	3.8 0.0	11.000 3.800	24.887 0.0			Vel = 6.65	
H.7 to H.6	0.0 12.12	0.863 150.0 0.0882	Vprt	3.8 0.0	12.000 3.800	26.192 0.0			Vel = 6.65	
H.6 to T.27	0.0 12.12	0.863 150.0 0.0882	Vptb	18.4 0.0	7.000 18.400	27.586 0.0			Vel = 6.65	
T.27 to T.28	13.91 26.03	1.025 150.0 0.1570		0.0 0.0	4.000 0.0	29.827 0.0			Vel = 10.12	
T.28 to S.1	0.0 26.03	1.025 150.0 0.1570	E T	2.7 6.75	6.000 9.450	30.455 2.166			Vel = 10.12	
S.1 to MTR	0.0 26.03	1.053 150.0 0.1377	2E	2.429 0.0	50.000 2.429	35.046 4.732			** Fixed Loss = 3 Vel = 9.59	
MTR to STR	0.0 26.03	1.049 150.0 0.1403	E T G	3.022 7.555 1.511	20.000 12.089 32.089	46.996 0.0 4.501			Vel = 9.66	
	0.0 26.03					51.497			K Factor = 3.63	
H.10 to H.4	1.80 1.8	0.863 150.0 0.0026	Vprt	3.8 0.0	9.000 3.800	7.040 0.0			Vel = 0.99	
H.4 to H.3	13.04 14.84	0.863 150.0 0.1283	Vprt	3.8 0.0	9.000 3.800	7.073 0.0			K Factor = 4.90 Vel = 8.14	

Final Calculations - Hazen-Williams

Viega LLC
 LOT#10 - Two Head Calculation (H.10 & H.4)

Page 6
 Date 2/26/2021

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftng's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
H.3 to T.26	0.0 14.84	0.863 150.0 0.1282	Vprt 3.8 0.0 0.0	4.000 3.800 7.800	8.715 0.0 1.000		Vel = 8.14		
T.26 to H.5	-6.46 8.38	0.863 150.0 0.0446	Vptb 18.4 Vprt 3.8 0.0	14.000 22.200 36.200	9.715 0.0 1.615		Vel = 4.60		
H.5 to T.25	0.0 8.38	0.863 150.0 0.0445	Vprt 3.8 0.0 0.0	5.000 3.800 8.800	11.330 0.0 0.392		Vel = 4.60		
T.25 to T.23	4.01 12.39	0.863 150.0 0.0919	Vptb 18.4 Vpel 17.7 0.0	1.000 36.100 37.100	11.722 0.0 3.408		Vel = 6.80		
T.23 to T.24	0.0 12.39	0.863 150.0 0.0919	Vpel 17.7 0.0 0.0	15.000 17.700 32.700	15.130 4.764 3.004		Vel = 6.80		
T.24 to T.22	0.0 12.39	0.863 150.0 0.0919	Vptb 18.4 0.0 0.0	3.000 18.400 21.400	22.898 0.0 1.966		Vel = 6.80		
T.22 to H.1	1.52 13.91	0.863 150.0 0.1138	Vprt 3.8 0.0 0.0	3.000 3.800 6.800	24.864 0.0 0.774		Vel = 7.63		
H.1 to T.27	0.0 13.91	0.863 150.0 0.1138	Vprt 3.8 0.0 0.0	33.000 3.800 36.800	25.638 0.0 4.189		Vel = 7.63		
	0.0 13.91				29.827		K Factor = 2.55		
T.26 to H.9	6.45 6.45	0.863 150.0 0.0275	Vprt 3.8 0.0 0.0	5.000 3.800 8.800	9.715 0.0 0.242		Vel = 3.54		
H.9 to T.32	0.0 6.45	0.863 150.0 0.0274	Vprt 3.8 0.0 0.0	7.000 3.800 10.800	9.957 0.0 0.296		Vel = 3.54		
T.32 to H.14	0.0 6.45	0.863 150.0 0.0275		8.000 0.0 8.000	10.253 0.0 0.220		Vel = 3.54		
H.14 to H.13	0.0 6.45	0.863 150.0 0.0275	Vprt 3.8 0.0 0.0	12.000 3.800 15.800	10.473 0.0 0.434		Vel = 3.54		
H.13 to T.31	0.0 6.45	0.863 150.0 0.0275	Vprt 3.8 0.0 0.0	8.000 3.800 11.800	10.907 0.0 0.325		Vel = 3.54		
T.31 to H.8	-2.45 4.0	0.863 150.0 0.0114	Vptb 18.4 0.0 0.0	8.000 18.400 26.400	11.232 0.0 0.300		Vel = 2.19		
H.8 to T.25	0.0 4.0	0.863 150.0 0.0113	Vprt 3.8 0.0 0.0	13.000 3.800 16.800	11.532 0.0 0.190		Vel = 2.19		
	0.0								

Final Calculations - Hazen-Williams

Viega LLC
 LOT#10 - Two Head Calculation (H.10 & H.4)

Page 7
 Date 2/26/2021

Hyd. Ref. Point	Qa Qt	Dia. "C" Pf/Ft	Fitting or Eqv. Ln.	Pipe Ftn'g's Total	Pt Pe Pf	Pt Pv Pn	*****	Notes	*****
	4.00				11.722			K Factor = 1.17	
T.31 to H.17	2.45	0.863 150.0	Vprt 3.8 0.0	9.000 3.800	11.232 0.0				
H.17 to H.19	2.45	0.0045	0.0	12.800	0.058			Vel = 1.34	
H.17 to H.19	0.0	0.863 150.0	Vprt 3.8 0.0	10.000 3.800	11.290 0.0				
H.19 to H.20	2.45	0.0046	0.0	13.800	0.063			Vel = 1.34	
H.19 to H.20	0.0	0.863 150.0	0.0 0.0	9.000 0.0	11.353 0.0				
H.20 to T.36	2.45	0.0046	0.0	9.000	0.041			Vel = 1.34	
H.20 to T.36	0.0	0.863 150.0	Vprt 3.8 0.0	10.000 3.800	11.394 0.0				
T.36	2.45	0.0046	0.0	13.800	0.064			Vel = 1.34	
	0.0 2.45				11.458			K Factor = 0.72	
T.33 to H.21	3.27	0.863 150.0	Vprt 3.8 0.0	11.000 3.800	24.304 0.0				
H.21 to H.18	3.27	0.0078	0.0	14.800	0.116			Vel = 1.79	
H.21 to H.18	0.0	0.863 150.0	0.0 0.0	14.000 0.0	24.420 0.0				
H.18 to T.30	3.27	0.0078	0.0	14.000	0.109			Vel = 1.79	
H.18 to T.30	0.0	0.863 150.0	Vptb 18.4 Vprt 3.8	12.000 22.200	24.529 0.0				
T.30 to H.11	3.27	0.0078	0.0	34.200	0.267			Vel = 1.79	
T.30 to H.11	-1.53	0.863 150.0	Vprt 3.8 0.0	11.000 3.800	24.796 0.0				
H.11 to H.11	1.74	0.0024	0.0	14.800	0.036			Vel = 0.95	
H.11 to T.29	0.0	0.863 150.0	Vptb 18.4 0.0	4.000 18.400	24.832 0.0				
T.29	1.74	0.0025	0.0	22.400	0.055			Vel = 0.95	
	0.0 1.74				24.887			K Factor = 0.35	
T.30 to H.12	1.52	0.863 150.0	0.0 0.0	4.000 0.0	24.796 0.0				
H.12 to H.2	1.52	0.0018	0.0	4.000	0.007			Vel = 0.83	
H.12 to H.2	0.0	0.863 150.0	Vprt 3.8 0.0	11.000 3.800	24.803 0.0				
H.2 to H.2	1.52	0.0020	0.0	14.800	0.029			Vel = 0.83	
H.2 to T.22	0.0	0.863 150.0	Vprt 3.8 0.0	13.000 3.800	24.832 0.0				
T.22	1.52	0.0019	0.0	16.800	0.032			Vel = 0.83	
	0.0 1.52				24.864			K Factor = 0.30	