





| Most Demanding Single Head Information | | Most Demanding Two Head Information | |
|--|---------------|-------------------------------------|---------------|
| Information | Results | Information | Results |
| Flow Required at Head (GPM): | 17 | Flow Required at Head (GPM): | 13 |
| Source Pressure at Head (PSI): | 12.03 | Source Pressure at Head (PSI): | 7.04 |
| Maximum Spacing (length): | 18 | Maximum Spacing (length): | 16 |
| Maximum Spacing (Width): | 18 | Maximum Spacing (Width): | 16 |
| Domestic Flow Added (GPM): | 0 | Domestic Flow Added (GPM): | 0 |
| Sprinkler Model: | RFC49 | Sprinkler Model: | RFC49 |
| Elevation of Highest Head: | 118 | Elevation of Highest Head: | 118 |
| K-Factor | 4.9 | K-Factor | 4.9 |
| Temperature Rating: | 155 | Temperature Rating: | 155 |
| Flow Required at Source (GPM) | 17 | Flow Required at Source (GPM) | 26.0933 |
| Pressure Required at Source (psi) | 37.41 | Pressure Required at Source (psi) | 48 |
| Source Reference Point: | At Ref Pt STR | Source Reference Point: | At Ref Pt STR |
| C-Factor of Sprinkler Pipe | 150 | C-Factor of Sprinkler Pipe | 150 |
| C-Factor of Service Line | 150 | C-Factor of Service Line | 150 |
| Head Reference Point: | H.8 | Head Reference Point: | H.9 & H.17 |

- 16
 RFC49-16
 RELIABLE Model RFC49 Concealed Pendent Spr FP
 K=4.9, 155F°, 7/16" Orifice, Maximum Spacing 16"x16"
 Sprinkler head demand: 13 gpm @ 7.04
- 3
 RFC49-18
 RELIABLE Model RFC49 Concealed Pendent Spr FP
 K=4.9, 155F°, 7/16" Orifice, Maximum Spacing 18"x18"
 Sprinkler head demand: 17 gpm @ 12.03

SPRINKLER DESCRIPTIONS



| LEGEND | |
|--------|-------------------------------------|
| | Manifold |
| | Inter Level Connection |
| | Hot Water Fixture |
| | Cold Water Fixture |
| | Type K Copper w/ ProPress Fittings |
| | Type L Copper w/ ProPress Fittings |
| | Type M Copper w/ ProPress Fittings |
| | ViegaPEX Ultra Black |
| | ViegaPEX Ultra Blue - Cold Plumbing |
| | ViegaPEX Ultra Red - Hot Plumbing |



WATER SERVICE DETAIL

VEIEGA LLC'S DESIGN SERVICES DEPARTMENT HAS PREPARED THIS SERIES OF DRAWINGS AS THE FIRST DESIGN FOR PLUMBING, RADIANT, SNOW MELTING OR FIRE SUPPRESSION SYSTEMS FOR THE USE OF YOU, OUR CUSTOMER, IN PREPARING / OBTAINING SPECIFICATIONS, BIDS AND PROPOSALS IN RELATION TO THE SALE OF THESE SYSTEMS. THESE DRAWINGS ARE BASED UPON INFORMATION PROVIDED BY YOU AND HAVE BEEN PREPARED TO APPROPRIATE PROFESSIONAL STANDARDS OF DESIGN BASED UPON THAT INFORMATION. THESE DRAWINGS ARE NOT TO BE CONSIDERED FINAL AND, PRIOR TO PERFORMING ANY WORK ASSOCIATED WITH THESE DESIGNS OR DRAWINGS, YOU MUST:

- CHECK AND CONFIRM ALL PIPE SIZES, CALCULATIONS, MATERIALS, PLUMBING AND / OR FIRE CODES USED OR APPLICABLE; AND
- PRESENT THE DRAWINGS TO YOUR PROFESSIONAL ENGINEER FOR REVIEW AND APPROVAL AND HAVE THE DRAWINGS MARKED "FINAL" BY YOUR PROFESSIONAL ENGINEER.

IF YOUR PROFESSIONAL ENGINEER REPORTS ANY ERRORS IN THE DRAWINGS OR MAKES ANY CHANGES IN THE DRAWINGS, THESE ERRORS OR CHANGES MUST BE COMMUNICATED TO VEIEGA LLC'S DESIGN SERVICES DEPARTMENT FOR A DETERMINATION IF A REVISION TO THE DESIGN IS NECESSARY.

VEIEGA LLC DISCLAIMS ANY WARRANTIES, EXPRESS OR IMPLIED, ASSOCIATED WITH THE DESIGN OF THE SYSTEM OR ITS USE. ALL DESIGNS ARE PROVIDED "AS IS" AND IT IS YOUR SOLE RESPONSIBILITY TO CONFIRM AND ENSURE THAT THE SYSTEM TO BE INSTALLED WILL OPERATE AND FUNCTION IN COMPLIANCE WITH ALL APPLICABLE CODES AND IN ACCORDANCE WITH ALL APPLICABLE SPECIFICATIONS.

Design Services Department
 1900 Southwood Drive - Nashua, NH 03063
 Tel: 877-843-4262 x 351 Fax: 316-425-8466

Project:
238 OAKHAVEN DRIVE, LOT 5
HOLLY SPRINGS, NC 27540

Dwg no.:
FP 1

Title:
FIRTS FLOOR PLAN

Quotation no.: FPNM2103-004 NC

| | |
|-----------------|----------------|
| Drawn by: | N.M. |
| Appov. by: | |
| Date Submitted: | 3/4/2021 |
| Scale: | 1/4" = 1' |
| Revision No: | Revision Date: |


VEIGA LLC'S DESIGN SERVICES DEPARTMENT HAS PREPARED THIS SERIES OF DRAWINGS AS THE FIRST DESIGN FOR PLUMBING, RADIANT, SNOW MELTING OR FIRE SUPPRESSION SYSTEMS FOR THE USE OF YOU, OUR CUSTOMER, IN PREPARING / OBTAINING SPECIFICATIONS, BIDS AND PROPOSALS IN RELATION TO THE SALE OF THESE SYSTEMS. THESE DRAWINGS ARE BASED UPON INFORMATION PROVIDED BY YOU AND HAVE BEEN PREPARED TO APPROPRIATE PROFESSIONAL STANDARDS OF DESIGN BASED UP THAT INFORMATION. THESE DRAWINGS ARE NOT TO BE CONSIDERED FINAL AND, PRIOR TO PERFORMING ANY WORK ASSOCIATED WITH THESE DESIGNS OR DRAWINGS, YOU MUST:

- 1) CHECK AND CONFIRM ALL PIPE SIZES, CALCULATIONS, MATERIALS, PLUMBING AND / OR FIRE CODES USED OR APPLICABLE; AND
- 2) PRESENT THE DRAWINGS TO YOUR PROFESSIONAL ENGINEER FOR REVIEW AND APPROVAL AND HAVE THE DRAWINGS MARKED "FINAL" BY YOUR PROFESSIONAL ENGINEER.

IF YOUR PROFESSIONAL ENGINEER REPORTS ANY ERRORS IN THE DRAWINGS OR MAKES ANY CHANGES IN THE DRAWINGS, THESE ERRORS OR CHANGES MUST BE COMMUNICATED TO VEIGA LLC'S DESIGN SERVICES DEPARTMENT FOR A DETERMINATION IF A REVISION TO THE DESIGN IS NECESSARY.

VEIGA LLC DISCLAIMS ANY WARRANTIES, EXPRESS OR IMPLIED, ASSOCIATED WITH THE DESIGN OF THE SYSTEM OR ITS USE. ALL DESIGNS ARE PROVIDED "AS IS" AND IT IS YOUR SOLE RESPONSIBILITY TO CONFIRM AND ENSURE THAT THE SYSTEM TO BE INSTALLED WILL OPERATE AND FUNCTION IN COMPLIANCE WITH ALL APPLICABLE CODES AND IN ACCORDANCE WITH ALL APPLICABLE SPECIFICATIONS.

Design Services Department
 1900 Southwood Drive - Nashua, NH 03063
 Tel: 877-843-4262 x 351 Fax: 316-425-8466



Project:

238 OAKHAVEN DRIVE, LOT 5
HOLLY SPRINGS, NC 27540

Dwg no.:
FP 2

Title:
SECOND FLOOR PLAN

| | |
|--------------------------------|----------------|
| Quotation no.: FPNM2103-004 NC | |
| Drawn by: | N.M. |
| Approv. by: | |
| Date Submitted: | 3/4/2021 |
| Scale: | 1/4" = 1' |
| Revision No: | Revision Date: |
| | |
| | |
| | |

FIRE PROTECTION INSTALLATION NOTES:

- INSTALLATION OF THE FIRE PROTECTION SYSTEM SHALL BE INSTALLED IN ACCORDANCE WITH THE 2016 EDITION OF NFPA 13D OR SECTION P2904 OF THE 2018 INTERNATIONAL RESIDENTIAL CODE (IRC). NFPA 13D IS THE STANDARD FOR THE INSTALLATION OF SPRINKLER SYSTEMS IN ONE- AND TWO-FAMILY DWELLINGS AND MANUFACTURED HOMES.
- INSTALLATION OF THE FIRE PROTECTION SYSTEM SHALL COMPLY WITH ALL LOCAL RESIDENTIAL FIRE PROTECTION CODES AND ALL APPLICABLE STATE REGULATIONS.
- SPRINKLER HEADS SHALL MEET ALL GENERAL CARE AND INSTALLATION REQUIREMENTS OF THE SPRINKLER MANUFACTURER. SUBSTITUTION OF SPRINKLER HEADS IS NOT PERMITTED.
- AFTER INSTALLATION OF THE SPRINKLERS, THE ENTIRE SYSTEM SHALL BE PRESSURE TESTED IN ACCORDANCE WITH STATE AND LOCAL CODE REQUIREMENTS. SPRINKLERS SHALL BE LOCATED PER THE LAYOUT. DO NOT INSTALL SPRINKLERS IN AREAS EXPOSED TO TEMPERATURES THAT EXCEED THE MAXIMUM RECOMMENDED AMBIENT TEMPERATURE FOR THE TEMPERATURE RATING USED. MINIMUM DISTANCE OF SPRINKLER HEADS FROM HEAT SOURCES SHALL COMPLY WITH TABLE 7.5.6.3 IN THE 2016 EDITION OF NFPA 13D, INSTALLATION OF SPRINKLER SYSTEMS IN ONE - AND TWO - FAMILY DWELLINGS AND MANUFACTURED HOMES.
- NO DEVIATIONS FROM THE PLAN SHALL BE ALLOWED WITHOUT APPROVAL FROM THE AUTHORITY HAVING JURISDICTION AND DESIGNER.
- PIPING AND SPRINKLER FITTINGS SHALL BE SUPPORTED IN COMPLIANCE WITH LOCAL PLUMBING CODE AND THE 2016 EDITION OF NFPA 13D, INSTALLATION OF SPRINKLER SYSTEMS IN ONE - AND TWO - FAMILY DWELLINGS AND MANUFACTURED HOMES.
- SMOKE DETECTORS SHALL BE INSTALLED IN ACCORDANCE WITH NFPA 72, NATIONAL FIRE ALARM CODE. WHEN NOT EQUIPPED WITH SMOKE DETECTORS, LOCAL WATERFLOW ALARMS SHALL BE REQUIRED.
- WATER SOFTENERS AND WATER FILTRATION DEVICES SHALL NOT BE INSTALLED IN THE SYSTEM WITHOUT A REVIEW OF THE HYDRAULIC CALCULATIONS OF THE SYSTEM.
- A SIGN SHALL BE AFFIXED ADJACENT TO THE MAIN SHUTOFF VALVE THAT STATES IN MINIMUM 1/4" LETTERS, "WARNING: THE WATER SYSTEM FOR THIS HOME SUPPLIES FIRE SPRINKLERS THAT REQUIRE CERTAIN FLOWS AND PRESSURES TO FIGHT A FIRE. DEVICES THAT RESTRICT THE FLOW OR DECREASE THE PRESSURE OR AUTOMATICALLY SHUT OFF THE WATER TO THE FIRE SPRINKLER SYSTEM, SUCH AS WATER SOFTENERS, FILTRATION SYSTEMS, AND AUTOMATIC SHUT-OFF VALVES, SHALL NOT BE ADDED TO THIS SYSTEM WITHOUT A REVIEW OF THE FIRE SPRINKLER SYSTEM BY A FIRE PROTECTION SPECIALIST. DO NOT REMOVE THIS SIGN."
- ALL PIPING AND FITTINGS SHALL BE PROPERLY INSULATED AND PROTECTED SO THAT THEY ARE NOT EXPOSED TO TEMPERATURES BELOW 40° F.
- WHEN THE MAXIMUM STATIC PRESSURE EXCEEDS 80 PSI, A PRESSURE-REDUCING VALVE SHALL BE INSTALLED. NFPA 13D RESTRICTS THE OPERATING PRESSURE OF PEX SYSTEMS TO 80 PSI. PRESSURE DROP THROUGH THE PRESSURE-REDUCING DEVICE SHALL BE INCLUDED IN THE HYDRAULIC CALCULATIONS.
- WHEN A FIRE DEPARTMENT CONNECTION IS REQUIRED, PEX TUBING SHALL NOT BE PERMITTED. CONSULT WITH THE AUTHORITY HAVING JURISDICTION (AHJ) ABOUT THIS REQUIREMENT PRIOR TO INSTALLATION.

PLUMBING INSTALLATION NOTES:

- INSTALLATION OF HOT AND COLD WATER DISTRIBUTION SYSTEMS SHALL BE IN ACCORDANCE WITH THE LOCAL PLUMBING CODE.
- WATER SOFTENERS AND WATER FILTRATION DEVICES SHALL NOT BE INSTALLED WITHOUT A REVIEW OF THE HYDRAULIC CALCULATIONS OF THE SYSTEM.
- FINAL APPROVAL OF MULTIPURPOSE AND PASSIVE PURGE FIRE SPRINKLER INSTALLATIONS SHALL BE FROM THE AUTHORITY HAVING JURISDICTION.

TESTING:

- EVERY VIEGA NFPA 13D FIRE PROTECTION INSTALLATION SHALL BE PRESSURE TESTED IN ACCORDANCE WITH NFPA 13D, WHICH STATES THAT SYSTEMS WITHOUT FIRE DEPARTMENT CONNECTIONS SHALL BE TESTED FOR LEAKAGE AT THE NORMAL SYSTEM OPERATING WATER PRESSURE.
- THE AUTHORITY HAVING JURISDICTION (AHJ) MAY REQUIRE A FLOW VERIFICATION TEST OF THE MOST HYDRAULICALLY REMOTE SPRINKLER HEAD(S). THIS FLOW VERIFICATION TEST IS AVAILABLE TO ENSURE THE INSTALLED FIRE PROTECTION SYSTEM OPERATES AS DESIGNED. DOCUMENTATION ON HOW TO PERFORM A FLOW VERIFICATION TEST IS AVAILABLE THROUGH VIEGA TECHNICAL SERVICES.
- THE FLOW VERIFICATION TEST SHALL BE PERFORMED AFTER ALL PIPING, FITTINGS, SPRINKLER HEADS AND PLUMBING CONNECTIONS HAVE BEEN INSTALLED AND PRESSURE TESTING OF THE SYSTEM HAS BEEN COMPLETED. THE FLOW TEST SHOULD OCCUR WHILE IN THE "ROUGH" STAGE OF CONSTRUCTION. FLOW TEST RESULTS SHOULD BE COMPARED TO THE SYSTEM DESIGN VALUES. RESIDUAL PRESSURE (PSI) AND FLOW (GPM) MUST BE EQUAL TO OR GREATER THEN THE DESIGN VALUES TO ENSURE A PROPERLY FUNCTIONING SYSTEM.

DRAWING AND DESIGN NOTES:

- DESIGN SHALL ENSURE WATER SUPPLY TO THE MOST HYDRAULICALLY DEMANDING SINGLE AND DUAL SPRINKLER HEADS.
- TUBING AND FITTINGS SHALL BE U.L. LISTED FOR RESIDENTIAL FIRE PROTECTION SYSTEMS IN ACCORDANCE WITH NFPA 13D.
- VIEGAFEX ULTRA (BLACK IN COLOR) LISTED TO U.L. 1821 FOR RESIDENTIAL WET-PIPE FIRE PROTECTION SYSTEMS IN ACCORDANCE WITH NFPA 13D.
- VIEGA PEX PRESS FITTINGS (POLYMER AND BRONZE) LISTED TO U.L. 1821 FOR RESIDENTIAL WET-PIPE FIRE PROTECTION SYSTEMS IN ACCORDANCE WITH NFPA 13D.
- APPROVED SMOKE DETECTION SYSTEMS AND/OR WATER FLOW ALARMS SHALL BE INSTALLED WHERE REQUIRED BY THE AUTHORITY HAVING JURISDICTION (AHJ).

MATERIALS LIST NOTES:

- SERVICE ENTRANCE MATERIALS FROM WATER MAIN CONNECTION TO DISTRIBUTION MANIFOLD ARE EXCLUDED.
- SPRINKLERS AND ASSOCIATED ESCUTCHEONS OR COVER PLATES ARE NOT SUPPLIED BY VIEGA.
- MATERIAL LIST IS SUGGESTED ONLY. CONTRACTOR SHALL CONFIRM REQUIRED MATERIALS PRIOR TO PLACEMENT OF ORDER.




FIGURE A.9.1.1(a) Insulation Recommendations — Arrangement 1.




FIGURE A.9.1.1(b) Insulation Recommendations — Arrangement 2.




FIGURE A.9.1.1(c) Insulation Recommendations — Arrangement 3.




FIGURE A.9.1.1(d) Insulation Recommendations — Arrangement 4.




FIGURE A.9.1.1(e) Insulation Recommendations — Arrangement 5.

INSULATION DETAILS - ANNEX A.9.1.1 (NFPA 13D 2016)





| WATER METER PRESSURE LOSSES (PSI) - TABLE 10.4.4(A) NFPA 13D (2016) | | | | | | |
|---|------------|----|----|----|----|----|
| Meter Size (in.) | Flow (gpm) | | | | | |
| | 18 or less | 23 | 26 | 31 | 39 | 52 |
| 5/8" | 9 | 14 | 18 | 26 | 38 | * |
| 3/4" | 7 | 11 | 14 | 22 | 35 | * |
| 1" | 2 | 3 | 3 | 4 | 6 | 10 |
| 1-1/2" | 1 | 1 | 2 | 2 | 4 | 7 |
| 2" | 1 | 1 | 1 | 1 | 2 | 3 |

TABLE 10.4.4(a) (NFPA 13D 2016)

| DISTANCES FROM HEAT SOURCES - TABLE 7.5.6.3 NFPA 13D (2016) | | |
|---|--------------------------|------------------------------|
| Heat Source | Ordinary Temp. 135°-175° | Intermediate Temp. 175°-225° |
| Side of Fireplace | 36" | 12" |
| Front of Fireplace | 60" | 36" |
| Coal or Wood Burning Stove | 42" | 12" |
| Kitchen Range | 18" | 9" |
| Wall Oven | 18" | 9" |
| Hot Air Flues | 18" | 9" |
| Uninsulated Heat Ducts | 18" | 9" |
| Uninsulated Hot Water Pipes | 12" | 6" |
| Side of Hot Air Diffusers | 24" | 12" |
| Front of Hot Air Diffusers | 36" | 18" |
| Hot Water Heater or Furnace | 6" | 3" |
| Light Fixture 0 W - 250 W | 6" | 3" |
| Light Fixture 250 W - 499 W | 12" | 6" |

TABLE 7.5.6.3 (NFPA 13D 2016)

INSTALLATION NOTES



INSTALLATION DETAIL - SPRINKLER BRACKETS

Project:

238 OAKHAVEN DRIVE, LOT 5
HOLLY SPRINGS, NC 27540

Dwg no.:

FP 3

Title:

NOTES & DETAILS

Quotation no.: FPNM2103-004 NC

Drawn by: N.M.

Approved by:

Date Submitted: 3/4/2021

Scale: N/A

Revision No: Revision Date:



viega

Viega LLC
Technical Services Department
1900 Southwood Drive
Nashua, NH 03063
603-882-7171

Job Name : 238 OAKHAVEN DRIVE, LOT 5 - One Head Calculation (H.8)
Building : SINGLE FAMILY RESIDENCE
Location : HOLLY SPRINGS NC 27540
System : NFPA 13D
Contract : FPNM2103-004 NC
Data File : FPNM2103-004 NC (238 Oakhaven Dr, Lot 5).wx1

HYDRAULIC DESIGN INFORMATION SHEET

Name - 238 OAKHAVEN DRIVE LOT 5 Date - 3/4/2021
Location -
Building - SINGLE FAMILY RESIDENCE System No. - NFPA 13D
Contractor - x Contract No. - FPNM2103-004 NC
Calculated By - VIEGA LLC Drawing No. - FPNM2103-004 NC
Construction: (X) Combustible () Non-Combustible Ceiling Height 9
OCCUPANCY - RESIDENTIAL

S Type of Calculation: ()NFPA 13 Residential ()NFPA 13R (X)NFPA 13D
Y Number of Sprinklers Flowing: (X)1 ()2 ()4 ()
S ()Other

T ()Specific Ruling Made by Date

E
M Listed Flow at Start Point - 17 Gpm System Type
Listed Pres. at Start Point - 12.03Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 18 x 18 () Deluge () PreAction
E Domestic Flow Added - 0 Gpm Sprinkler or Nozzle
S Additional Flow Added - Gpm Make RELIABLE Model RFC49
I Elevation at Highest Outlet - 118 Feet Size 7/16 K-Factor 4.9
G Note: Temperature Rating 155
N

Calculation Gpm Required 17 Psi Required 37.41 At Ref Pt STR
Summary C-Factor Used: Overhead 150 Underground 150

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - x Rated Cap. Cap.
T Time of Test - x @ Psi Elev.
E Static (Psi) - 60 Elev.
R Residual (Psi) - 20 Other Well
Flow (Gpm) - 168 Proof Flow Gpm
S Elevation - 100

P Location: x
P
L Source of Information: x
Y


Water Supply Curve C

Viega LLC
238 OAKHAVEN DRIVE, LOT 5 - One Head Calculation (H.8)

Page 2
Date 3/4/2021

City Water Supply:
C1 - Static Pressure : 60
C2 - Residual Pressure: 20
C2 - Residual Flow : 168

Demand:
D1 - Elevation : 7.796
D2 - System Flow : 16.995
D2 - System Pressure : 37.406
Hose (Demand) :
D3 - System Demand : 16.995
Safety Margin : 22.017



Fittings Used Summary

Viega LLC
238 OAKHAVEN DRIVE, LOT 5 - One Head Calculation (H.8)

Page 3
Date 3/4/2021

Fitting Legend

| Abbrev. | Name | 1/2 | 3/4 | 1 | 1 1/4 | 1 1/2 | 2 | 2 1/2 | 3 | 3 1/2 | 4 | 5 | 6 | 8 | 10 | 12 | 14 | 16 | 18 | 20 | 24 |
|---------|-----------------------------|------|------|------|-------|-------|------|-------|----|-------|----|----|----|----|----|----|----|----|----|-----|-----|
| E | 90' Standard Elbow | 2 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 12 | 14 | 18 | 22 | 27 | 35 | 40 | 45 | 50 | 61 |
| G | Generic Gate Valve | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 11 | 13 |
| T | 90' Flow thru Tee | 3 | 4 | 5 | 6 | 8 | 10 | 12 | 15 | 17 | 20 | 25 | 30 | 35 | 50 | 60 | 71 | 81 | 91 | 101 | 121 |
| Vpel * | PEX Press 90 Elbow - Poly | 12.6 | 18.9 | 17.7 | 18.6 | 29.4 | 36.4 | 0 | 0 | 0 | | | | | | | | | | | |
| Vprt * | PEX Press Tee - Run-Poly | 3.9 | 3.6 | 3.8 | 6.4 | 7.9 | 10.2 | 0 | 0 | 0 | | | | | | | | | | | |
| Vptb * | PEX Press Tee - Branch-Poly | 14 | 19.1 | 18.4 | 18.7 | 28.3 | 37.5 | 0 | 0 | 0 | | | | | | | | | | | |

Units Summary

Diameter Units Inches
Length Units Feet
Flow Units US Gallons per Minute
Pressure Units Pounds per Square Inch

Flow Summary - NFPA 2007

Viega LLC
238 OAKHAVEN DRIVE, LOT 5 - One Head Calculation (H.8)

Page 4
Date 3/4/2021

SUPPLY ANALYSIS

| <i>Node at Source</i> | <i>Static Pressure</i> | <i>Residual Pressure</i> | <i>Flow</i> | <i>Available Pressure</i> | <i>Total Demand</i> | <i>Required Pressure</i> |
|-----------------------|------------------------|--------------------------|-------------|---------------------------|---------------------|--------------------------|
| STR | 60.0 | 20 | 168.0 | 59.423 | 17.0 | 37.406 |

NODE ANALYSIS

| <i>Node Tag</i> | <i>Elevation</i> | <i>Node Type</i> | <i>Pressure at Node</i> | <i>Discharge at Node</i> | <i>Notes</i> |
|-----------------|------------------|------------------|-------------------------|--------------------------|--------------|
| H.8 | 118.0 | 4.9 | 12.03 | 17.0 | |
| T.27 | 118.0 | | 13.06 | | |
| T.26 | 118.0 | | 13.53 | | |
| T.25 | 108.0 | | 18.52 | | |
| T.24 | 108.0 | | 18.93 | | |
| H.6 | 108.0 | | 19.06 | | |
| H.15 | 108.0 | | 19.32 | | |
| T.34 | 108.0 | | 19.43 | | |
| H.19 | 108.0 | | 19.5 | | |
| H.11 | 108.0 | | 19.79 | | |
| H.10 | 108.0 | | 19.98 | | |
| H.14 | 108.0 | | 20.25 | | |
| T.31 | 108.0 | | 20.43 | | |
| T.32 | 108.0 | | 20.73 | | |
| T.36 | 108.0 | | 21.06 | | |
| S.1 | 104.0 | | 27.35 | | |
| MTR | 100.0 | | 35.36 | | |
| STR | 100.0 | | 37.41 | | |
| T.28 | 118.0 | | 12.72 | | |
| H.2 | 118.0 | | 12.94 | | |
| H.1 | 118.0 | | 13.13 | | |
| T.22 | 118.0 | | 13.37 | | |
| T.21 | 118.0 | | 13.73 | | |
| T.20 | 108.0 | | 18.3 | | |
| T.23 | 108.0 | | 18.95 | | |
| H.3 | 108.0 | | 19.27 | | |
| H.13 | 108.0 | | 19.63 | | |
| H.16 | 108.0 | | 19.82 | | |
| H.9 | 118.0 | | 12.84 | | |
| T.29 | 118.0 | | 13.34 | | |
| H.12 | 118.0 | | 13.4 | | |
| T.30 | 118.0 | | 13.52 | | |
| T.35 | 118.0 | | 14.2 | | |
| T.33 | 108.0 | | 20.02 | | |
| H.17 | 118.0 | | 13.34 | | |
| H.18 | 118.0 | | 13.45 | | |
| H.7 | 118.0 | | 13.35 | | |
| H.5 | 108.0 | | 18.93 | | |
| H.4 | 108.0 | | 18.95 | | |

Final Calculations - Hazen-Williams

Viega LLC
238 OAKHAVEN DRIVE, LOT 5 - One Head Calculation (H.8)

Page 5
Date 3/4/2021

| Hyd. Ref. Point | Qa Qt | Dia. "C" Pf/Ft | Fitting or Eqv. | Ln. | Pipe Ftng's Total | Pt Pe Pf | Pt Pv Pn | ***** | Notes | ***** |
|-----------------------|----------|----------------------|-----------------------|--------------|-------------------------|-----------------|----------------|-------|-------------------|-------|
| H.8 to T.27 | 8.96 | 0.863 150.0 | Vptb | 18.4 0.0 | 2.000 18.400 | 12.030 0.0 | | | K Factor = 4.90 | |
| T.27 to T.26 | 8.96 | 0.0505 | | 0.0 | 20.400 | 1.030 | | | Vel = 4.91 | |
| T.27 to T.26 | -3.66 | 0.863 150.0 | Vprt Vpel | 3.8 17.7 | 3.000 21.500 | 13.060 0.0 | | | | |
| T.26 to T.25 | 5.3 | 0.0191 | | 0.0 | 24.500 | 0.467 | | | Vel = 2.91 | |
| T.26 to T.25 | 0.0 | 0.863 150.0 | Vpel | 17.7 0.0 | 17.000 17.700 | 13.527 4.331 | | | | |
| T.25 to T.24 | 5.3 | 0.0190 | | 0.0 | 34.700 | 0.661 | | | Vel = 2.91 | |
| T.25 to T.24 | 0.0 | 0.863 150.0 | Vptb | 18.4 0.0 | 3.000 18.400 | 18.519 0.0 | | | | |
| T.24 to H.6 | 5.3 | 0.0191 | | 0.0 | 21.400 | 0.408 | | | Vel = 2.91 | |
| T.24 to H.6 | -0.93 | 0.863 150.0 | Vprt | 3.8 0.0 | 6.000 3.800 | 18.927 0.0 | | | | |
| H.6 to H.15 | 4.37 | 0.0134 | | 0.0 | 9.800 | 0.131 | | | Vel = 2.40 | |
| H.6 to H.15 | 0.0 | 0.863 150.0 | Vprt | 3.8 0.0 | 16.000 3.800 | 19.058 0.0 | | | | |
| H.15 to T.34 | 4.37 | 0.0134 | | 0.0 | 19.800 | 0.266 | | | Vel = 2.40 | |
| H.15 to T.34 | 0.0 | 0.863 150.0 | Vprt | 3.8 0.0 | 4.000 3.800 | 19.324 0.0 | | | | |
| T.34 to H.19 | 4.37 | 0.0133 | | 0.0 | 7.800 | 0.104 | | | Vel = 2.40 | |
| T.34 to H.19 | 0.0 | 0.863 150.0 | | 0.0 0.0 | 5.000 0.0 | 19.428 0.0 | | | | |
| H.19 to H.11 | 4.37 | 0.0134 | | 0.0 | 5.000 | 0.067 | | | Vel = 2.40 | |
| H.19 to H.11 | 0.0 | 0.863 150.0 | Vprt | 3.8 0.0 | 18.000 3.800 | 19.495 0.0 | | | | |
| H.11 to H.10 | 4.37 | 0.0134 | | 0.0 | 21.800 | 0.292 | | | Vel = 2.40 | |
| H.11 to H.10 | 0.0 | 0.863 150.0 | Vprt | 3.8 0.0 | 11.000 3.800 | 19.787 0.0 | | | | |
| H.10 to H.14 | 4.37 | 0.0134 | | 0.0 | 14.800 | 0.198 | | | Vel = 2.40 | |
| H.10 to H.14 | 0.0 | 0.863 150.0 | Vprt | 3.8 0.0 | 16.000 3.800 | 19.985 0.0 | | | | |
| H.14 to T.31 | 4.37 | 0.0134 | | 0.0 | 19.800 | 0.265 | | | Vel = 2.40 | |
| H.14 to T.31 | 0.0 | 0.863 150.0 | Vprt | 3.8 0.0 | 10.000 3.800 | 20.250 0.0 | | | | |
| T.31 to T.32 | 4.37 | 0.0134 | | 0.0 | 13.800 | 0.185 | | | Vel = 2.40 | |
| T.31 to T.32 | 5.67 | 0.863 150.0 | Vprt | 3.8 0.0 | 1.000 3.800 | 20.435 0.0 | | | | |
| T.32 to T.36 | 10.04 | 0.0621 | | 0.0 | 4.800 | 0.298 | | | Vel = 5.51 | |
| T.32 to T.36 | 6.96 | 0.863 150.0 | | 0.0 0.0 | 2.000 0.0 | 20.733 0.0 | | | | |
| T.36 to S.1 | 17.0 | 0.1650 | | 0.0 | 2.000 | 0.330 | | | Vel = 9.32 | |
| T.36 to S.1 | 0.0 | 0.863 150.0 | Vpel T | 17.7 2.92 | 7.000 20.620 | 21.063 1.732 | | | | |
| S.1 to MTR | 17.0 | 0.1649 | | 0.0 | 27.620 | 4.554 | | | Vel = 9.32 | |
| S.1 to MTR | 0.0 | 1.053 150.0 | 2E | 2.429 0.0 | 50.000 2.429 | 27.349 4.732 | | | ** Fixed Loss = 3 | |
| MTR | 17.0 | 0.0626 | | 0.0 | 52.429 | 3.280 | | | Vel = 6.26 | |

Final Calculations - Hazen-Williams

Viega LLC
238 OAKHAVEN DRIVE, LOT 5 - One Head Calculation (H.8)

Page 6
Date 3/4/2021

| Hyd. Ref. Point | Qa Qt | Dia. "C" Pf/Ft | Fitting or Eqv. | Ln. | Pipe Ftng's Total | Pt Pe Pf | Pt Pv Pn | ***** | Notes | ***** |
|-----------------|---------------|--------------------------|-----------------|-------------------------|----------------------------|--------------------------|-------------|-------|-------|-----------------|
| MTR to STR | 0.0 17.0 | 1.049 150.0 0.0637 | E T G | 3.022 7.555 1.511 | 20.000 12.089 32.089 | 35.361 0.0 2.045 | | | | Vel = 6.31 |
| | 0.0 17.00 | | | | | 37.406 | | | | K Factor = 2.78 |
| H.8 to T.28 | 8.03 8.03 | 0.863 150.0 0.0412 | Vprt | 3.8 0.0 0.0 | 13.000 3.800 16.800 | 12.030 0.0 0.692 | | | | Vel = 4.40 |
| T.28 to H.2 | -4.60 3.43 | 0.863 150.0 0.0085 | Vptb | 18.4 0.0 0.0 | 7.000 18.400 25.400 | 12.722 0.0 0.217 | | | | Vel = 1.88 |
| H.2 to H.1 | 0.0 3.43 | 0.863 150.0 0.0086 | Vprt | 3.8 0.0 0.0 | 18.000 3.800 21.800 | 12.939 0.0 0.187 | | | | Vel = 1.88 |
| H.1 to T.22 | 0.0 3.43 | 0.863 150.0 0.0085 | Vptb Vprt | 18.4 3.8 0.0 | 6.000 22.200 28.200 | 13.126 0.0 0.241 | | | | Vel = 1.88 |
| T.22 to T.21 | 1.31 4.74 | 0.863 150.0 0.0155 | Vprt Vpel | 3.8 17.7 0.0 | 2.000 21.500 23.500 | 13.367 0.0 0.365 | | | | Vel = 2.60 |
| T.21 to T.20 | 0.0 4.74 | 0.863 150.0 0.0155 | | 0.0 0.0 0.0 | 15.000 0.0 15.000 | 13.732 4.331 0.233 | | | | Vel = 2.60 |
| T.20 to T.23 | 0.0 4.74 | 0.863 150.0 0.0155 | Vptb Vpel | 18.4 17.7 0.0 | 6.000 36.100 42.100 | 18.296 0.0 0.654 | | | | Vel = 2.60 |
| T.23 to H.3 | 0.92 5.66 | 0.863 150.0 0.0216 | Vprt | 3.8 0.0 0.0 | 11.000 3.800 14.800 | 18.950 0.0 0.320 | | | | Vel = 3.10 |
| H.3 to H.13 | 0.0 5.66 | 0.863 150.0 0.0215 | Vprt | 3.8 0.0 0.0 | 13.000 3.800 16.800 | 19.270 0.0 0.362 | | | | Vel = 3.10 |
| H.13 to H.16 | 0.0 5.66 | 0.863 150.0 0.0216 | Vprt | 3.8 0.0 0.0 | 5.000 3.800 8.800 | 19.632 0.0 0.190 | | | | Vel = 3.10 |
| H.16 to T.31 | 0.0 5.66 | 0.863 150.0 0.0216 | Vptb | 18.4 0.0 0.0 | 10.000 18.400 28.400 | 19.822 0.0 0.613 | | | | Vel = 3.10 |
| | 0.0 5.66 | | | | | 20.435 | | | | K Factor = 1.25 |
| T.28 to H.9 | 4.60 4.6 | 0.863 150.0 0.0148 | | 0.0 0.0 0.0 | 8.000 0.0 8.000 | 12.722 0.0 0.118 | | | | Vel = 2.52 |
| H.9 to T.29 | 0.0 4.6 | 0.863 150.0 0.0147 | Vptb Vprt | 18.4 3.8 0.0 | 12.000 22.200 34.200 | 12.840 0.0 0.502 | | | | Vel = 2.52 |
| T.29 to H.12 | -1.31 3.29 | 0.863 150.0 0.0078 | Vprt | 3.8 0.0 0.0 | 4.000 3.800 7.800 | 13.342 0.0 0.061 | | | | Vel = 1.80 |

Final Calculations - Hazen-Williams

Viega LLC
238 OAKHAVEN DRIVE, LOT 5 - One Head Calculation (H.8)

Page 7
Date 3/4/2021

| Hyd. Ref. Point | Qa Qt | Dia. "C" Pf/Ft | Fitting or Eqv. Ln. | Pipe Ftg's Total | Pt Pe Pf | Pt Pv Pn | ***** | Notes | ***** |
|-----------------|--------------|--------------------------|----------------------|------------------|-----------------|-------------|-------|-----------------|-------|
| H.12 to T.30 | 0.0 3.29 | 0.863 150.0 0.0079 | Vprt 3.8 0.0 | 11.000 3.800 | 13.403 0.0 | | | Vel = 1.80 | |
| T.30 to T.35 | 3.67 6.96 | 0.863 150.0 0.0316 | Vptb 18.4 0.0 | 3.000 18.400 | 13.520 0.0 | | | Vel = 3.82 | |
| T.35 to T.33 | 0.0 6.96 | 0.863 150.0 0.0316 | 2Vpel 35.4 0.0 | 12.000 35.400 | 14.196 4.331 | | | Vel = 3.82 | |
| T.33 to T.32 | 0.0 6.96 | 0.863 150.0 0.0316 | Vptb 18.4 0.0 | 4.000 18.400 | 20.025 0.0 | | | Vel = 3.82 | |
| | 0.0 6.96 | | | | 20.733 | | | K Factor = 1.53 | |
| T.27 to H.17 | 3.67 3.67 | 0.863 150.0 0.0097 | Vprt 3.8 0.0 | 25.000 3.800 | 13.060 0.0 | | | Vel = 2.01 | |
| H.17 to H.18 | 0.0 3.67 | 0.863 150.0 0.0097 | | 12.000 0.0 | 13.338 0.0 | | | Vel = 2.01 | |
| H.18 to T.30 | 0.0 3.67 | 0.863 150.0 0.0097 | Vprt 3.8 0.0 | 3.000 3.800 | 13.454 0.0 | | | Vel = 2.01 | |
| | 0.0 3.67 | | | | 13.520 | | | K Factor = 1.00 | |
| T.29 to H.7 | 1.31 1.31 | 0.863 150.0 0.0014 | Vprt 3.8 0.0 | 5.000 3.800 | 13.342 0.0 | | | Vel = 0.72 | |
| H.7 to T.22 | 0.0 1.31 | 0.863 150.0 0.0015 | Vprt 3.8 0.0 | 5.000 3.800 | 13.354 0.0 | | | Vel = 0.72 | |
| | 0.0 1.31 | | | | 13.367 | | | K Factor = 0.36 | |
| T.24 to H.5 | 0.92 0.92 | 0.863 150.0 0.0007 | Vprt 3.8 0.0 | 7.000 3.800 | 18.927 0.0 | | | Vel = 0.50 | |
| H.5 to H.4 | 0.0 0.92 | 0.863 150.0 0.0008 | Vprt 3.8 0.0 | 12.000 3.800 | 18.935 0.0 | | | Vel = 0.50 | |
| H.4 to T.23 | 0.0 0.92 | 0.863 150.0 0.0008 | | 4.000 0.0 | 18.947 0.0 | | | Vel = 0.50 | |
| | 0.0 0.92 | | | | 18.950 | | | K Factor = 0.21 | |



viega

Viega LLC
Technical Services Department
1900 Southwood Drive
Nashua, NH 03063
603-882-7171

Job Name : 238 OAKHAVEN DRIVE, LOT 5 - Two Head Calculation (H.9 & H.17)
Building : SINGLE FAMILY RESIDENCE
Location : HOLLY SPRINGS NC 27540
System : NFPA 13D
Contract : FPNM2103-004 NC
Data File : FPNM2103-004 NC (238 Oakhaven Dr, Lot 5).wx2

HYDRAULIC DESIGN INFORMATION SHEET

Name - 238 OAKHAVEN DRIVE LOT 5 Date - 3/4/2021
Location -
Building - SINGLE FAMILY RESIDENCE System No. - NFPA 13D
Contractor - x Contract No. - FPNM2103-004 NC
Calculated By - VIEGA LLC Drawing No. - FPNM2103-004 NC
Construction: (X) Combustible () Non-Combustible Ceiling Height 9
OCCUPANCY - RESIDENTIAL

S Type of Calculation: ()NFPA 13 Residential ()NFPA 13R (X)NFPA 13D

Y Number of Sprinklers Flowing: ()1 (X)2 ()4 ()

S ()Other

T ()Specific Ruling Made by Date

E
M Listed Flow at Start Point - 13 Gpm System Type
Listed Pres. at Start Point - 7.04 Psi (X) Wet () Dry
D MAXIMUM LISTED SPACING 16 x 16 () Deluge () PreAction
E Domestic Flow Added - 0 Gpm Sprinkler or Nozzle
S Additional Flow Added - Gpm Make RELIABLE Model RFC49
I Elevation at Highest Outlet - 118 Feet Size 7/16 K-Factor 4.9
G Note: Temperature Rating 155
N

Calculation Gpm Required 26.0933 Psi Required 48 At Ref Pt STR
Summary C-Factor Used: Overhead 150 Underground 150

W Water Flow Test: Pump Data: Tank or Reservoir:
A Date of Test - x Rated Cap. Cap.
T Time of Test - x @ Psi Elev.
E Static (Psi) - 60 Elev.
R Residual (Psi) - 20 Other Well
Flow (Gpm) - 168 Proof Flow Gpm
S Elevation - 100

P Location: x
P
L Source of Information: x
Y


Water Supply Curve C

Viega LLC
238 OAKHAVEN DRIVE, LOT 5 - Two Head Calculation (H.9 & H.17)

Page 2
Date 3/4/2021

City Water Supply:
C1 - Static Pressure : 60
C2 - Residual Pressure: 20
C2 - Residual Flow : 168

Demand:
D1 - Elevation : 7.796
D2 - System Flow : 26.093
D2 - System Pressure : 47.997
Hose (Demand) : _____
D3 - System Demand : 26.093
Safety Margin : 10.727



Fittings Used Summary

Viega LLC
 238 OAKHAVEN DRIVE, LOT 5 - Two Head Calculation (H.9 & H.17)

Page 3
 Date 3/4/2021

Fitting Legend

| Abbrev. | Name | 1/2 | 3/4 | 1 | 1 1/4 | 1 1/2 | 2 | 2 1/2 | 3 | 3 1/2 | 4 | 5 | 6 | 8 | 10 | 12 | 14 | 16 | 18 | 20 | 24 |
|---------|-----------------------------|------|------|------|-------|-------|------|-------|----|-------|----|----|----|----|----|----|----|----|----|-----|-----|
| E | 90' Standard Elbow | 2 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 12 | 14 | 18 | 22 | 27 | 35 | 40 | 45 | 50 | 61 |
| G | Generic Gate Valve | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 1 | 2 | 2 | 3 | 4 | 5 | 6 | 7 | 8 | 10 | 11 | 13 |
| T | 90' Flow thru Tee | 3 | 4 | 5 | 6 | 8 | 10 | 12 | 15 | 17 | 20 | 25 | 30 | 35 | 50 | 60 | 71 | 81 | 91 | 101 | 121 |
| Vpel * | PEX Press 90 Elbow - Poly | 12.6 | 18.9 | 17.7 | 18.6 | 29.4 | 36.4 | 0 | 0 | 0 | | | | | | | | | | | |
| Vprt * | PEX Press Tee - Run-Poly | 3.9 | 3.6 | 3.8 | 6.4 | 7.9 | 10.2 | 0 | 0 | 0 | | | | | | | | | | | |
| Vptb * | PEX Press Tee - Branch-Poly | 14 | 19.1 | 18.4 | 18.7 | 28.3 | 37.5 | 0 | 0 | 0 | | | | | | | | | | | |

Units Summary

Diameter Units Inches
 Length Units Feet
 Flow Units US Gallons per Minute
 Pressure Units Pounds per Square Inch

Flow Summary - NFPA 2007

Viega LLC
 238 OAKHAVEN DRIVE, LOT 5 - Two Head Calculation (H.9 & H.17)

Page 4
 Date 3/4/2021

SUPPLY ANALYSIS

| <i>Node at Source</i> | <i>Static Pressure</i> | <i>Residual Pressure</i> | <i>Flow</i> | <i>Available Pressure</i> | <i>Total Demand</i> | <i>Required Pressure</i> |
|-----------------------|------------------------|--------------------------|-------------|---------------------------|---------------------|--------------------------|
| STR | 60.0 | 20 | 168.0 | 58.724 | 26.09 | 47.997 |

NODE ANALYSIS

| <i>Node Tag</i> | <i>Elevation</i> | <i>Node Type</i> | <i>Pressure at Node</i> | <i>Discharge at Node</i> | <i>Notes</i> |
|-----------------|------------------|------------------|-------------------------|--------------------------|--------------|
| H.9 | 118.0 | 4.9 | 7.04 | 13.0 | |
| T.29 | 118.0 | | 7.88 | | |
| H.7 | 118.0 | | 7.96 | | |
| T.22 | 118.0 | | 8.04 | | |
| T.21 | 118.0 | | 8.85 | | |
| T.20 | 108.0 | | 13.7 | | |
| T.23 | 108.0 | | 15.14 | | |
| H.3 | 108.0 | | 15.83 | | |
| H.13 | 108.0 | | 16.61 | | |
| H.16 | 108.0 | | 17.01 | | |
| T.31 | 108.0 | | 18.33 | | |
| T.32 | 108.0 | | 18.97 | | |
| T.36 | 108.0 | | 19.7 | | |
| S.1 | 104.0 | | 31.5 | | |
| MTR | 100.0 | | 43.48 | | |
| STR | 100.0 | | 48.0 | | |
| T.28 | 118.0 | | 7.29 | | |
| H.2 | 118.0 | | 7.54 | | |
| H.1 | 118.0 | | 7.76 | | |
| H.8 | 118.0 | | 7.42 | | |
| T.27 | 118.0 | | 7.57 | | |
| T.26 | 118.0 | | 8.54 | | |
| T.25 | 108.0 | | 14.25 | | |
| T.24 | 108.0 | | 15.1 | | |
| H.6 | 108.0 | | 15.38 | | |
| H.15 | 108.0 | | 15.95 | | |
| T.34 | 108.0 | | 16.17 | | |
| H.19 | 108.0 | | 16.32 | | |
| H.11 | 108.0 | | 16.94 | | |
| H.10 | 108.0 | | 17.37 | | |
| H.14 | 108.0 | | 17.93 | | |
| H.17 | 118.0 | 4.9 | 7.14 | 13.09 | |
| H.18 | 118.0 | | 7.68 | | |
| T.30 | 118.0 | | 7.99 | | |
| T.35 | 118.0 | | 9.55 | | |
| T.33 | 108.0 | | 17.34 | | |
| H.12 | 118.0 | | 7.92 | | |
| H.5 | 108.0 | | 15.12 | | |
| H.4 | 108.0 | | 15.14 | | |

Final Calculations - Hazen-Williams

Viega LLC
238 OAKHAVEN DRIVE, LOT 5 - Two Head Calculation (H.9 & H.17)

Page 5
Date 3/4/2021

| Hyd. Ref. Point | Qa Qt | Dia. "C" Pf/Ft | Fitting or Eqv. | Ln. | Pipe Ftg's Total | Pt Pe Pf | Pt Pv Pn | ***** | Notes | ***** |
|-----------------|----------------|--------------------------|-----------------|-------------------------|----------------------------|---------------------------|-------------|-------|---------------------------------|-------|
| H.9 to T.29 | 6.07 | 0.863 150.0 0.0245 | Vptb Vprt | 18.4 3.8 0.0 | 12.000 22.200 34.200 | 7.040 0.0 0.839 | | | K Factor = 4.90 Vel = 3.33 | |
| T.29 to H.7 | -2.51 3.56 | 0.863 150.0 0.0091 | Vprt | 3.8 0.0 0.0 | 5.000 3.800 8.800 | 7.879 0.0 0.080 | | | Vel = 1.95 | |
| H.7 to T.22 | 0.0 3.56 | 0.863 150.0 0.0092 | Vprt | 3.8 0.0 0.0 | 5.000 3.800 8.800 | 7.959 0.0 0.081 | | | Vel = 1.95 | |
| T.22 to T.21 | 3.72 7.28 | 0.863 150.0 0.0344 | Vprt Vpel | 3.8 17.7 0.0 | 2.000 21.500 23.500 | 8.040 0.0 0.808 | | | Vel = 3.99 | |
| T.21 to T.20 | 0.0 7.28 | 0.863 150.0 0.0344 | | 0.0 0.0 0.0 | 15.000 0.0 15.000 | 8.848 4.331 0.516 | | | Vel = 3.99 | |
| T.20 to T.23 | 0.0 7.28 | 0.863 150.0 0.0344 | Vptb Vpel | 18.4 17.7 0.0 | 6.000 36.100 42.100 | 13.695 0.0 1.449 | | | Vel = 3.99 | |
| T.23 to H.3 | 1.28 8.56 | 0.863 150.0 0.0463 | Vprt | 3.8 0.0 0.0 | 11.000 3.800 14.800 | 15.144 0.0 0.685 | | | Vel = 4.70 | |
| H.3 to H.13 | 0.0 8.56 | 0.863 150.0 0.0463 | Vprt | 3.8 0.0 0.0 | 13.000 3.800 16.800 | 15.829 0.0 0.778 | | | Vel = 4.70 | |
| H.13 to H.16 | 0.0 8.56 | 0.863 150.0 0.0462 | Vprt | 3.8 0.0 0.0 | 5.000 3.800 8.800 | 16.607 0.0 0.407 | | | Vel = 4.70 | |
| H.16 to T.31 | 0.0 8.56 | 0.863 150.0 0.0463 | Vptb | 18.4 0.0 0.0 | 10.000 18.400 28.400 | 17.014 0.0 1.315 | | | Vel = 4.70 | |
| T.31 to T.32 | 6.60 15.16 | 0.863 150.0 0.1333 | Vprt | 3.8 0.0 0.0 | 1.000 3.800 4.800 | 18.329 0.0 0.640 | | | Vel = 8.32 | |
| T.32 to T.36 | 10.93 26.09 | 0.863 150.0 0.3645 | | 0.0 0.0 0.0 | 2.000 0.0 2.000 | 18.969 0.0 0.729 | | | Vel = 14.31 | |
| T.36 to S.1 | 0.0 26.09 | 0.863 150.0 0.3644 | Vpel T | 17.7 2.92 0.0 | 7.000 20.620 27.620 | 19.698 1.732 10.065 | | | Vel = 14.31 | |
| S.1 to MTR | 0.0 26.09 | 1.053 150.0 0.1383 | 2E | 2.429 0.0 0.0 | 50.000 2.429 52.429 | 31.495 4.732 7.250 | | | ** Fixed Loss = 3 Vel = 9.61 | |
| MTR to STR | 0.0 26.09 | 1.049 150.0 0.1409 | E T G | 3.022 7.555 1.511 | 20.000 12.089 32.089 | 43.477 0.0 4.520 | | | Vel = 9.69 | |
| | 0.0 26.09 | | | | | 47.997 | | | K Factor = 3.77 | |
| H.9 to T.28 | 6.93 | 0.863 150.0 0.0314 | | 0.0 0.0 0.0 | 8.000 0.0 8.000 | 7.040 0.0 0.251 | | | Vel = 3.80 | |

Final Calculations - Hazen-Williams

Viega LLC
238 OAKHAVEN DRIVE, LOT 5 - Two Head Calculation (H.9 & H.17)

Page 6
Date 3/4/2021

| Hyd. Ref. Point | Qa Qt | Dia. "C" Pf/Ft | Fitting or Eqv. Ln. | Pipe Ftg's Total | Pt Pe Pf | Pt Pv Pn | ***** | Notes | ***** |
|-----------------|---------------|-------------------|---------------------|------------------|------------------|----------------|-------|-----------------|-------|
| T.28 to H.2 | -3.21 3.72 | 0.863 150.0 | Vptb 0.0 | 18.4 0.0 | 7.000 18.400 | 7.291 0.0 | | Vel = 2.04 | |
| H.2 to H.1 | 0.0 3.72 | 0.863 150.0 | Vprt 0.0 | 3.8 0.0 | 18.000 3.800 | 7.543 0.0 | | Vel = 2.04 | |
| H.1 to T.22 | 0.0 3.72 | 0.863 150.0 | Vptb Vprt | 18.4 3.8 | 6.000 22.200 | 7.760 0.0 | | Vel = 2.04 | |
| | 0.0 3.72 | | | | | 8.040 | | K Factor = 1.31 | |
| T.28 to H.8 | 3.21 3.21 | 0.863 150.0 | Vprt 0.0 | 3.8 0.0 | 13.000 3.800 | 7.291 0.0 | | Vel = 1.76 | |
| H.8 to T.27 | 0.0 3.21 | 0.863 150.0 | Vptb 0.0 | 18.4 0.0 | 2.000 18.400 | 7.418 0.0 | | Vel = 1.76 | |
| T.27 to T.26 | 4.66 7.87 | 0.863 150.0 | Vprt Vpel | 3.8 17.7 | 3.000 21.500 | 7.572 0.0 | | Vel = 4.32 | |
| T.26 to T.25 | 0.0 7.87 | 0.863 150.0 | Vpel 0.0 | 17.7 0.0 | 17.000 17.700 | 8.545 4.331 | | Vel = 4.32 | |
| T.25 to T.24 | 0.0 7.87 | 0.863 150.0 | Vptb 0.0 | 18.4 0.0 | 3.000 18.400 | 14.253 0.0 | | Vel = 4.32 | |
| T.24 to H.6 | -1.27 6.6 | 0.863 150.0 | Vprt 0.0 | 3.8 0.0 | 6.000 3.800 | 15.102 0.0 | | Vel = 3.62 | |
| H.6 to H.15 | 0.0 6.6 | 0.863 150.0 | Vprt 0.0 | 3.8 0.0 | 16.000 3.800 | 15.383 0.0 | | Vel = 3.62 | |
| H.15 to T.34 | 0.0 6.6 | 0.863 150.0 | Vprt 0.0 | 3.8 0.0 | 4.000 3.800 | 15.950 0.0 | | Vel = 3.62 | |
| T.34 to H.19 | 0.0 6.6 | 0.863 150.0 | | 0.0 0.0 | 5.000 0.0 | 16.174 0.0 | | Vel = 3.62 | |
| H.19 to H.11 | 0.0 6.6 | 0.863 150.0 | Vprt 0.0 | 3.8 0.0 | 18.000 3.800 | 16.317 0.0 | | Vel = 3.62 | |
| H.11 to H.10 | 0.0 6.6 | 0.863 150.0 | Vprt 0.0 | 3.8 0.0 | 11.000 3.800 | 16.942 0.0 | | Vel = 3.62 | |
| H.10 to H.14 | 0.0 6.6 | 0.863 150.0 | Vprt 0.0 | 3.8 0.0 | 16.000 3.800 | 17.366 0.0 | | Vel = 3.62 | |
| H.14 to T.31 | 0.0 6.6 | 0.863 150.0 | Vprt 0.0 | 3.8 0.0 | 10.000 3.800 | 17.934 0.0 | | Vel = 3.62 | |

Final Calculations - Hazen-Williams

Viega LLC
238 OAKHAVEN DRIVE, LOT 5 - Two Head Calculation (H.9 & H.17)

Page 7
Date 3/4/2021

| Hyd. Ref. Point | Qa Qt | Dia. "C" Pf/Ft | Fitting or Eqv. | Ln. | Pipe Ftg's Total | Pt Pe Pf | Pt Pv Pn | ***** | Notes | ***** |
|-----------------|--------------|-------------------|-----------------|-------------|------------------|----------------|-------------|-------|-----------------|-------|
| | 0.0 6.60 | | | | | 18.329 | | | K Factor = 1.54 | |
| T.27 to H.17 | -4.66 | 0.863 150.0 | Vprt | 3.8 0.0 | 25.000 3.800 | 7.572 0.0 | | | | |
| H.17 to H.18 | -4.66 | -0.0150 | | 0.0 | 28.800 | -0.433 | | | Vel = 2.56 | |
| H.17 to H.18 | 13.09 | 0.863 150.0 | | 0.0 0.0 | 12.000 0.0 | 7.139 0.0 | | | K Factor = 4.90 | |
| H.18 to T.30 | 8.43 | 0.0451 | | 0.0 | 12.000 | 0.541 | | | Vel = 4.62 | |
| H.18 to T.30 | 0.0 | 0.863 150.0 | Vprt | 3.8 0.0 | 3.000 3.800 | 7.680 0.0 | | | | |
| T.30 to T.35 | 8.43 | 0.0450 | | 0.0 | 6.800 | 0.306 | | | Vel = 4.62 | |
| T.30 to T.35 | 2.51 | 0.863 150.0 | Vptb | 18.4 0.0 | 3.000 18.400 | 7.986 0.0 | | | | |
| T.35 to T.33 | 10.94 | 0.0729 | | 0.0 | 21.400 | 1.561 | | | Vel = 6.00 | |
| T.35 to T.33 | 0.0 | 0.863 150.0 | 2Vpel | 35.4 0.0 | 12.000 35.400 | 9.547 4.331 | | | | |
| T.33 to T.32 | 10.94 | 0.0730 | | 0.0 | 47.400 | 3.458 | | | Vel = 6.00 | |
| T.33 to T.32 | 0.0 | 0.863 150.0 | Vptb | 18.4 0.0 | 4.000 18.400 | 17.336 0.0 | | | | |
| T.32 | 10.94 | 0.0729 | | 0.0 | 22.400 | 1.633 | | | Vel = 6.00 | |
| | 0.0 10.94 | | | | | 18.969 | | | K Factor = 2.51 | |
| T.29 to H.12 | 2.50 | 0.863 150.0 | Vprt | 3.8 0.0 | 4.000 3.800 | 7.879 0.0 | | | | |
| H.12 to T.30 | 2.5 | 0.0047 | | 0.0 | 7.800 | 0.037 | | | Vel = 1.37 | |
| H.12 to T.30 | 0.0 | 0.863 150.0 | Vprt | 3.8 0.0 | 11.000 3.800 | 7.916 0.0 | | | | |
| T.30 | 2.5 | 0.0047 | | 0.0 | 14.800 | 0.070 | | | Vel = 1.37 | |
| | 0.0 2.50 | | | | | 7.986 | | | K Factor = 0.88 | |
| T.24 to H.5 | 1.27 | 0.863 150.0 | Vprt | 3.8 0.0 | 7.000 3.800 | 15.102 0.0 | | | | |
| H.5 to H.4 | 1.27 | 0.0014 | | 0.0 | 10.800 | 0.015 | | | Vel = 0.70 | |
| H.5 to H.4 | 0.0 | 0.863 150.0 | Vprt | 3.8 0.0 | 12.000 3.800 | 15.117 0.0 | | | | |
| H.4 to T.23 | 1.27 | 0.0013 | | 0.0 | 15.800 | 0.021 | | | Vel = 0.70 | |
| H.4 to T.23 | 0.0 | 0.863 150.0 | | 0.0 0.0 | 4.000 0.0 | 15.138 0.0 | | | | |
| T.23 | 1.27 | 0.0015 | | 0.0 | 4.000 | 0.006 | | | Vel = 0.70 | |
| | 0.0 1.27 | | | | | 15.144 | | | K Factor = 0.33 | |