

SOIL/SITE EVALUATION
for ON-SITE WASTEWATER SYSTEM

Owner: *Duwayan* Applicant: *Duwayan*
 Address: *148 Bombo Dr* Date Evaluated: *5-17-21*
 Proposed Facility: *SFD* Design Flow (.1949):
 Location of Site: *San* Property Recorded: Property Size:
 Water Supply: Public Individual Well Spring Other
 Evaluation Method: Auger Boring Pit Cut
 Type of Wastewater: Sewage Industrial Process Mixed

P R O F I L E #	.1940 Landscape Position/ Slope %	Horizon Depth (In.)	SOIL MORPHOLOGY .1941		OTHER PROFILE FACTORS				Profile Class & LTAR
			.1941 Structure/ Texture	.1941 Consistence Mineralogy	.1942 Soil Wetness/ Color	.1943 Soil Depth (IN.)	.1956 Sapro Class	.1944 Restr Horiz	
1	L	0-6	LS Gr	Fr/ps/np/np	10YR 7/1	> 48"	—	—	PS-3
	2-52	6-48	sic1 SBk	Fi/ss/sp/sxp	≥ 20"				Group IV
2,3,4	L	0-6	LS Gr	Fr/ps/np/np	10YR 6/1	> 48"	—	—	PS-3
	2-52	6-48	sic1 SBk	Fi/ss/sp/sxp	≥ 24"				Group IV

Description	Initial System	Repair System	Other Factors (.1946):
Available Space (.1945)	✓	???	Site Classification (.1948): <i>PS</i>
System Type(s)	<i>low pro</i>	<i>low pro</i>	Evaluated By: <i>M Osborn-RGH</i>
Site LTAR	<i>.3</i>	<i>.3</i>	Others Present:

(534)

COMMENTS: _____

LANDSCAPE POSITIONS	GROUP	TEXTURES	.1955 LTAR	CONSISTENCE MOIST	WET
R-RIDGE	I	S-SAND	1.2 - 0.8	VFR-VERY FRIABLE	NS-NON-STICKY
S-SHOULDER SLOPE		LS-LOAMY SAND		FR-FRIABLE	SS-SLIGHTLY STICKY
L-LINEAR SLOPE	II	SL-SANDY LOAM	0.8 - 0.6	FI-FIRM	S-STICKY
FS-FOOT SLOPE		L-LOAM		VFI-VERY FIRM	VS-VERY STICKY
N-NOSE SLOPE	III	SI-SILT	0.6 - 0.3	EFI-EXTREMELY FIRM	NP-NON-PLASTIC
H-HEAD SLOPE		SIL-SILT LOAM			SP-SLIGHTLY STICKY
CC-CONCLAVE SLOPE		CL-CLAY LOAM			P-PLASTIC
CV-CONVEX SLOPE		SCL-SANDY CLAY LOAM			VP-VERY PLASTIC
T-TERRACE	IV	SIC-SILTY CLAY	0.4 - 0.1		
FP-FLOOD PLAN		C-CLAY			
		SC-SANDY CLAY			

- STRUCTURE
- SG-SINGLE GRAIN
 - M-MASSIVE
 - CR-CRUMB
 - GR-GRANULAR
 - SBK-SUBANGULAR BLOCKY
 - ABK-ANGULAR BLOCKY
 - PL-PLATY
 - PR-PRISMATIC
- MINERALOGY
- SLIGHTLY EXPANSIVE
 - EXPANSIVE

Show profile locations and other site features (dimensions, references or benchmark, and North)

